from MSG-20 Q11 (SLD-001 sh 2)

from MSG-20 Q21 (SLD-001 sh 2)

Normal: S1 fed from MSG-20 S1, S2 from MSG-20 S2.
Each feeder carries the whole hall: 7.0 MW, 213 A.
IL-2 (S1-Q0, S2-Q0, coupler): coupler closes only with one feeder open
(both feeders + coupler = T1 // T2, 20.9 kA) · TODO B13

CT 400/1 5P20 + 0.5S

S1-Q0 VCB 1 250 A

HV-DH1 S1 24 kV 1 250 A 25 kA

N.O.

HV-DH1 S2 87B, 50ARC

CT 400/1 5P20 + 0.5S

S2-Q0 VCB 1 250 A

S1-Q1A
VCB 630 A
CT 150/1 → R-TX
3×1×95 Al
T-A
2 500 kVA
Dyn11 · uk 6 %
BTS 4 000 A
ACB
4 000 A
MSB-A
UPS-A / SBS-A
SLD-002 sh 2
G 3~ **G-A**
2 750 kVA

S1-Q1C
VCB 630 A
CT 150/1 → R-TX
3×1×95 Al
T-C
2 500 kVA
Dyn11 · uk 6 %
BTS 4 000 A
ACB
4 000 A
MSB-C
UPS-C / SBS-C
SLD-002 sh 2
G 3~ **G-C**
2 750 kVA

S1-Q1M
VCB 630 A
CT 150/1 → R-TX
3×1×95 Al
T-M1
1 600 kVA
Dyn11 · uk 6 %
ACB
2 500 A
MSB-M1
MUPS-1 / mech.
SLD-002 sh 2
G 3~ **G-M1**
1 650 kVA

S2-Q2B
VCB 630 A
CT 150/1 → R-TX
3×1×95 Al
T-B
2 500 kVA
Dyn11 · uk 6 %
BTS 4 000 A
ACB
4 000 A
MSB-B
UPS-B / SBS-B
SLD-002 sh 2
G 3~ **G-B**
2 750 kVA

S2-Q2D
VCB 630 A
CT 150/1 → R-TX
3×1×95 Al
T-D
2 500 kVA
Dyn11 · uk 6 %
BTS 4 000 A
ACB
4 000 A
MSB-D
UPS-D / SBS-D
SLD-002 sh 2
G 3~ **G-D**
2 750 kVA

S2-Q2M
VCB 630 A
CT 150/1 → R-TX
3×1×95 Al
T-M2
1 600 kVA
Dyn11 · uk 6 %
ACB
2 500 A
MSB-M2
MUPS-2 / mech.
SLD-002 sh 2
G 3~ **G-M2**
1 650 kVA

ATS (dash-dot): transformer ACB / genset ACB, open transition only (TODO B14). Gensets via BTS 4 000 A (B5).

Item	Rating (Rev P2)	Check (CALC-002/3)
T-A…T-D	2 500 kVA 20/0.42 kV Dyn11, uk 6 %, Pk 19 kW	N-1 82 %
G-A…G-D	2 750 kVA / 2 200 kWe DCC, Isc ≥ 300 % 2 s	N-1 88 %
MSB-A…D	4 000 A, Icw 65 kA 1 s, Ipk 143 kA	52.3 kA
UPS-A…D	2 × 1 000 kW, 2 × 165 kWh LFP	N-1 83 %
UOSB-A…D	3 200 A, 65 kA 1 s	49.3 kA
T-M1/M2	1 600 kVA kept (1 250 kVA would be 83 %)	65 %
G-M / MUPS	1 650 kVA; mech. UPS 2 × 250 kW	step ≤ 33 %

P2	2026-10-25	CALC-002/3/4 ratings, IEC symbols, ≥2.5 mm text
P1	2026-10-24	First concept issue

Nordic Hyperscale DC Campus (fictional) · 30 MW IT · SE3
Portfolio D. Wu · public standards and [ASSUMED] data only

Data hall DH-1 — sheet 1

HV-DH1, IT power blocks A–D (4N/3), mechanical 2N
CONCEPT · NOT FOR CONSTRUCTION · scale NTS · A3

Drawing no.	Sheet	Rev
DWU-DC-E-SLD-002	**1 / 2**	**P2**