

Specification for XLPE cable for Working voltage up to and including 1.1 KV, IS:7098 (Part-1), 4 x 400 sq.mm (aluminium)

S. No.	Specification Name	Bid Requirement
1	Conformity of the specification for XLPE cable	As per IS:7098(part 1):1988 latest
2	ISI marked	Yes
3	Cable suitable for use in mines	No
4	Cable suitable for use in low temperature applications	No.
5	Nominal area of conductor (in sq.mm.)	400
6	No. of core (in Nos.)	04
7	Classifications of cable for improved fire performance category	01
8	Type of cable	Armoured cable
9	Type of inner sheath	Thermoplastic
10	Material of armouring	Galvanized steel formed wire
11	Type of armouring	Single Strip
12	Material of conductor	Aluminium
13	Conductor material standard	As per IS:8130:2013 latest
14	Construction of Conductor	Stranded and Shaped
15	Cable wound on	ISI marked wooden drum
16	Drum standard	IS: 10418 Latest
17	Type of sequential marking on cable	Screen/Embossed printing on cable
18	Availability of type test report from Govt. lab/NABL accredited lab/ILAC accredited lab	Yes
19	Availability of optional testing report	Not applicable