



BOILER SAFETY BUREAU
1101 MAIL SERVICE CENTER
RALEIGH, NC 27699-1101
PHONE (919) 707-7918
FAX (919) 807-2761

Information Bulletin: IB-19.002
Issue Date: 12/02/2019

POLICY NOTIFICATION
<External Inspections of Boilers & Pressure Vessels>

This policy is being issued to clarify jurisdiction requirements regarding the external inspections of boilers and pressure vessels.

- All boilers and pressure vessels shall be in operation at the time of the required jurisdictional external inspection, to allow for inspection of the external surfaces, appurtenances, controls and safety devices.
- With the owner's permission, inspections may be performed early to allow for external inspections during times of use.
- If a boiler or pressure vessel cannot be operated for the external inspection, a violation may be opened, and the owner must contact the Boiler Safety Bureau to discuss possible alternatives or courses of action.

Don Kinney
Chief Inspector