INTERNATIONAL ISLAMIC UNIVERSITY MALAYSIA
Garden of Knowledge and Virtue

LAB REPORT 5:
UNDERSTANDING BOTH SOFTWARE AND HARDWARE ASPECTS OF PLC INTERFACING WITH MICROCONTROLLERS

GROUP 5

MCTA 3203

SEMESTER 1 2024/2025

MECHATRONICS SYSTEM INTEGRATION

DATE OF SUBMISSION: NOVEMBER 2024

NO	NAME	MATRIC NUMBER
1.	MUHAMMAD AFIQ ADHAM BIN MOHD NADZRI	2227531
2.	MUHAMMAD AMIN BIN MOHAMAD RIZAL	2217535
3.	MUHAMMAD AFIQ BIN MOHD ASRI	2212541
4.	MUHAMMAD AKMAL BIN MOHD FAUZI	2214077
5.	MUHAMMAD AFIQ IKHWAN BIN NOR SHAHRIZAL	2215897

TABLE OF CONTENTS

INTRODUCTION

Programmable Logic Controllers (PLCs) are essential components of modern industrial automation, providing strong and adaptable tools for regulating electromechanical processes in a wide range of applications. These controllers are extensively used in manufacturing plants, automated machinery, and other industrial systems that require high precision and reliability. With technological improvements, merging PLCs with microcontrollers has become a popular technique for expanding functionality, improving performance, and streamlining processes.

This webinar focuses on the OpenPLC Editor, a powerful software platform for programming and simulating PLCs. By connecting it to a microcontroller, we hope to show how this integration improves the ability to develop, implement, and optimize automation systems.

ABSTRACT

A Programmable Logic Controller (PLC) is an industrial computer that automates and controls electromechanical processes in factories, machines, and other settings. This lesson focuses on using the OpenPLC Editor to design a Start-Stop Control Circuit with a ladder diagram. The ladder diagram is compiled, simulated, and then uploaded to an Arduino board for implementation. The circuit's functionality, including pin configuration, is presented and explained, highlighting the integration of PLC programming with microcontroller platforms to improve automation possibilities.

MATERIALS AND EQUIPMENT

• OpenPLC Editor software
• Arduino Board
• 2 Push Button Switches
• Jumper Wires
• LED
• Resistors
• Breadboard

EXPERIMENTAL SETUP

Fig. 4: Start-Stop Control Circuit

#	Name	Class	Type	Location
1	UP_Start	Local	BOOL	%IX0.0
2	DOWN_Stop	Local	BOOL	%IX0.1
3	Latch	Local	BOOL	
4	LED	Local	BOOL	%QX0.0

| Documentation |
|---|
| Will Turn ON the LED |
| Will Turn OFF the LED |
| Latch Bit Instruction |
| Output indicator for Latch_Unlatch Program |

Fig. 5: Ladder Diagram for the Start-Stop Control Circuit

Fig. 6

METHODOLOGY

1. Create the ladder diagram shown in Fig. 5.

2. Specify all variables used in the ladder diagram.

3. Compile and simulate the ladder diagram in OpenPLC Editor.

4. Upload the ladder diagram to the Arduino board.

5. Ensure to selection of the correct COM port number and all pin associations between the OpenPLC variables and the Arduino board.

6. Build the circuit as shown in Fig. 6.

7. Test the functionality.

RESULTS

Video link:
https://github.com/GROUP5-MSI/WEEK-5-PLC-interfacing/blob/main/Video%20W5%20PLC%20Demo.mov

DISCUSSION

In this experiment, we investigated the hardware and software requirements for efficient interface between microcontrollers and Programmable Logic Controllers (PLC). This configuration is crucial for contemporary industrial automation, which calls for a combination of flexible, affordable microcontroller solutions and strong control from PLC.

Developing dependable and transparent communication protocols is one of the main obstacles in PLC-microcontroller interfacing. Microcontrollers typically use protocols like I2C, SPI, UART, or custom serial communication, whereas PLC typically use Ethernet/IP, Profibus, or Modbus. Programming modifications and, occasionally, extra hardware for signal conditioning are needed to close this gap. For example, to avoid possible damage to the microcontroller, it is crucial to make sure that the voltage levels between the two devices match.

On the software side, programming was an essential part of the process. Writing custom code to interpret data correctly on both the PLC and microcontroller was a learning-intensive process, as PLC and microcontrollers typically use different programming languages and environments (ladder logic for PLC, while C/C++ or assembly for microcontrollers). This part of the experiment highlighted the importance of understanding how each system processes commands and data.

Error handling and troubleshooting proved crucial during testing. Debugging involved tracking signal timing discrepancies and interpreting unexpected behaviour that sometimes stemmed from timing mismatches or data loss between the devices. Integrating error handling in the software made it easier to identify where faults occurred in the communication pipeline.

This experiment provided valuable insight into the compatibility and flexibility issues that can arise when interfacing different control systems, underscoring the importance of comprehensive knowledge in both hardware and software aspects. By addressing these complexities, we gained a stronger foundation in control system design, paving the way for more robust applications in automated and industrial environments.

CONCLUSION

In conclusion, this experiment successfully implemented the integration of a PLC with a microcontroller to realize the Start-Stop Control Circuit. This allowed us hands-on experience in learning the basics of PLC programming and interfacing it with a microcontroller. The experiment has proven the effectiveness and practicality of using ladder logic in control processes and the versatility of Arduino in handling programs based on PLC. The Start-Stop Control Circuit worked just fine, and the Arduino responded to the simulated start and stop commands with high accuracy. Overall, this exercise gave a very clear understanding of the software and hardware aspects of PLC-microcontroller interfacing and further solidified the potential of the PLCs in the automation tasks while introducing low-cost means of prototyping industrial control systems.

RECOMMENDATION

Enhancement of ladder diagram complexity by breaking down the ladder diagram into smaller, reusable modules or subroutines. This approach can simplify troubleshooting and allow for easier expansion of the control system in future experiments. Besides, we can utilize more advanced simulation features within the Open PLC Editor to test complex scenarios and ensure the ladder diagram behaves as expected under various conditions. Students need to ensure all electrical connections are secure and insulated to prevent short circuits or accidental disconnections. Use appropriate protective equipment when handling electrical components.

ACKNOWLEDGEMENT

A special thanks goes out to Dr. Wahju Sediono and Dr. Zulkifli Bin Zainal Abidin, my teaching assistant, and my peers for their invaluable help and support in finishing this report. Their advice, feedback, and experience have greatly influenced the level of quality and understanding of this work. Their time, patience, and commitment to supporting my academic success are greatly appreciated.

STUDENT'S DECLARATION

Certificate of Originality and Authenticity

This is to certify that we are responsible for the work submitted in this report, that the original work is our own except as specified in the references and acknowledgment, and that the original work contained herein has not been untaken or done by unspecified sources or persons.

We hereby certify that this report has not been done by only one individual and all of us have contributed to the report. The length of contribution to the reports by each individual is noted within this certificate.

We also hereby certify that we have read and understand the content of the total report and that no further improvement on the reports is needed from any of the individual contributors to the report.

We, therefore, agreed unanimously that this report shall be submitted for marking and this final printed report has been verified by us.

Signature:	Read
Name: MUHAMMAD AFIQ ADHAM BIN MOHD NADZRI	Understand
Matric Number: 2227531	Agree
Signature:	Read
Name: MUHAMMAD AMIN BIN MOHAMAD RIZAL	Understand
Matric Number: 2217535	Agree
Signature: afiq	Read
Name: MUHAMMAD AFIQ BIN MOHD ASRI	Understand
Matric Number: 2212541	Agree
Signature:	Read
Name: MUHAMMAD AKMAL BIN MOHD FAUZI	Understand
Matric Number: 2214077	Agree
Signature: Afiq	Read
Name: MUHAMMAD AFIQ IKHWAN BIN NOR SHAHRIZAL	Understand
Matric Number: 2215897	Agree