

MYLAPS X2 TrackSensor



Quick Start Guide

CONTACT INFORMATION	2
FEATURES & TYPICAL APPLICATION	3
SCHEMATIC, INSTALLATION & SPECIFICATIONS	4
CHARTS & DIAGNOSTICS	6
SOFTWARE IMPLEMENTATION	7

Contact Information

MYLAPS EMEA Office

Haarlem
The Netherlands
Tel: +31 23 7600 100
E-mail: info@mylaps.com

MYLAPS Americas Office

Atlanta
USA
Tel: +1 678 816 4000
E-mail: info.americas@mylaps.com

MYLAPS Japan Office

Tokyo
Japan
Tel: +81 3 5275 4600
Email: info.japan@mylaps.com

MYLAPS Asia Pacific Office

Sydney
Australia
Tel: +61 2 9546 2606
Email: info.asia.pacific@mylaps.com

MYLAPS Asia Office

Kuala Lumpur
Malaysia
Tel: +60 356131235
Email: info.asia@mylaps.com

www.mylaps.com



All rights reserved

Copyright © 2013-2014 MYLAPS

This publication has been written with great care. However, the manufacturer cannot be held responsible, either for any errors occurring in this publication or for their consequences.

The sale of products, services of goods governed under this publication are covered by MYLAPS's standard Terms and Conditions of Sales and this product manual is provided solely for informational purposes. This publication is to be used for the standard model of the product of the type given on the cover page.

Features & Typical Application

Features:

- Track Surface Temperature measurement at every X2 Loop location
 - 1 minute update of the track temperature
 - Integrated with the timing system
- Factory calibrated temperature measurement
 - 0.1 °C Resolution
 - ± 1 °C Accuracy
- Fast thermal response time
- Timing loop diagnostics
 - A test signal is sent to an X2 Decoder every minute
- Permanent installation
 - 5 Year battery life
- Compatible with current loops of the MYLAPS CAR/BIKE and KART systems for loop diagnostics only

Typical application:


- Track Surface Temperature measurement
- Timing Loop Installation Diagnostics



Schematic, Installation & Specifications


Schematic

Please see below a schematic design of the X2 TrackSensor




Installation

Install the Sensor in a position in the middle of the loop (red line in the below drawing)



Install the X2 TrackSensor in a position in the middle of the loop (red line in the drawing on previous page). Recommended drill hole diameter is 24mm. Once you have drilled the hole please put a layer of silicon into it first and then press the X2 TrackSensor in the hole. Please use a rubber headed hammer to get the X2 TrackSensor into the asphalt. Do not use excessive force as this will damage the X2 TrackSensor.




1. Asphalt
2. Silicon
3. X2 TrackSensor


Specifications

- | | |
|-------------------------|---------------------------|
| • Resolution | 0.1 °C |
| • Accuracy | ±1 °C |
| • Measurement Frequency | Every minute |
| • Signal transfer | Magnetic induction |
| • Battery life | 5 year |
| • Overall dimensions | 78mm x \varnothing 25mm |
| • Weight | 45 gram |

Typical track surface temperature chart




Typical signal strength versus loop wire distance



Loop diagnostics, warning example

This type of loop diagnostics warning is shown within the X2 Manager only.



Software implementation

In order to use track temperature information and loop diagnostics in a custom made application, it is possible to extract this information from the X2 server using the example code below:

```
// Request the loop- trigger data from the MTA.
mta_eventdata_subscribe(event_handle, mtaLoopTrigger, 0, false);
// Request the loop-trigger' data from the MTA.
mta_notify_loopstatus(event_handle, NotifyLoopTrigger);

// Loop-trigger notification function.
static void STDCALL NotifyLoopTrigger(mta_eventdata_handle_t handle,
MDP_NOTIFY_TYPE nType, const looptrigger_t* trigger, void* context)
{
    const loop_t* loop;
    mta_handle_t app_handle = mta_eventdata_get_appliance_handle(handle);

    if (nType != MDP_NOTIFY_CLEAR) {
        char str[32], str2[32];
        loop = mta_loop_find(app_handle, trigger ->loopid);
        fprintf(stdout, "Loop trigger received [Loop:%s, UTC:%s, Time:%s,
        Temperature:%0.1f Celcius]\n",
        loop ? loop->name : "",
        mdp_get_time_as_string(str, sizeof(str), trigger ->utctime, false, 0),
        mdp_get_time_as_string(str2, sizeof(str2), trigger->timeofday, false, 0),
        loopstatus_get_trigger_temperature(trigger));
    } else
        fprintf(stdout, "[CLR] Loop-trigger info\n");
}
```


MYLAPS EMEA

Haarlem, The Netherlands

E: info@mylaps.com

MYLAPS AMERICAS

Atlanta, USA

E: info.americas@mylaps.com

MYLAPS JAPAN

Tokyo, Japan

E: info.japan@mylaps.com

MYLAPS AUSTRALIA ASIA PACIFIC

Sydney, Australia

E: info.asia.pacific@mylaps.com

MYLAPS ASIA

Kuala Lumpur, Malaysia

E: info.asia@mylaps.com

www.mylaps.com