BATTERY HEALTH REPORT - DEMO DOCUMENT (fictional, generated by CELLFEE seed)
Tested by: Demo Battery Test Lab (Pune)
Report ID: DBT-7553
Test date: 2026-09-04
Battery serial number: TAT-23-004419
Chemistry: LFP
State of Health: 92.5 %
Measured capacity: 2.31 kWh
Internal resistance: 57.7 mOhm
Tests: capacity discharge at C/3, DCIR pulse, visual inspection, BMS read-out
Limitations: cells not individually opened; thermal imaging not performed