BATTERY HEALTH REPORT - DEMO DOCUMENT (fictional, generated by CELLFEE seed)
Tested by: Metro Cell Diagnostics
Report ID: MCD-7762
Test date: 2026-07-06
Battery serial number: TAT-21-004739
Chemistry: LFP
State of Health: 80.8 %
Measured capacity: 24.4 kWh
Internal resistance: 41.8 mOhm
Tests: capacity discharge at C/3, DCIR pulse, visual inspection, BMS read-out
Limitations: cells not individually opened; thermal imaging not performed