BATTERY HEALTH REPORT - DEMO DOCUMENT (fictional, generated by CELLFEE seed)
Tested by: Demo Cell Testing Centre (Delhi)
Report ID: DCT-7907
Test date: 2026-07-13
Battery serial number: TAT-21-004926
Chemistry: LFP
State of Health: 82.1 %
Measured capacity: 24.79 kWh
Internal resistance: 31.9 mOhm
Tests: capacity discharge at C/3, DCIR pulse, visual inspection, BMS read-out
Limitations: cells not individually opened; thermal imaging not performed