BATTERY HEALTH REPORT - DEMO DOCUMENT (fictional, generated by CELLFEE seed)
Tested by: Demo Battery Test Lab (Pune)
Report ID: DBT-7393
Test date: 2026-08-18
Battery serial number: MGM-20-004230
Chemistry: NMC
State of Health: 88.4 %
Measured capacity: 3.27 kWh
Internal resistance: 42.0 mOhm
Tests: capacity discharge at C/3, DCIR pulse, visual inspection, BMS read-out
Limitations: cells not individually opened; thermal imaging not performed