গবেষণা, পরীক্ষণ ও কনসালটেনসি কেন্দ্র
পুর ও পরিবেশ কৌশল বিভাগ
শাহজালাল বিজ্ঞান ও প্রযুক্তি বিশ্ববিদ্যালয়
সিলেট-৩১১৪, বাংলাদেশ।
যোগাযোগঃ +৮৮ ০১৩১৮ ২১০ ২৮৬/২৮৭/২৮৮/২৮৯/২৯০
Website: www.crtc-cee-sust.com

Center for Research, Testing and Consultancy
Department of Civil and Environmental Engineering
Shahjalal University of Science and Technology
Sylhet-3114, Bangladesh.
Contact: +88 01318 210 286/ 287/ 288/ 289/ 290
Email: crtc-cee@sust.edu

Ref. no: CRTC/CEE/G20220483/S- 91

SUB-SOIL INVESTIGATION REPORT

FOR PROPOSED
CONSTRUCTION OF 04 STORIED GIRLS HOSTEL BUILDING AT AGRICULTURAL TRAINING INSTITUTE(ATI), JAGANNATHPUR, SUNAMGONJ.

CLIENT

EXECUTIVE ENGINEER, PWD, SUNAMGONJ.

Verification Code: bwX293Cg
Verify report at: crtc-cee-sust.com

CONDUCTED BY

CENTER FOR RESEARCH TESTING & CONSULTANCY
DEPARTMENT OF CIVIL & ENVIRONMENTAL ENGINEERING
SHAHJALAL UNIVERSITY OF SCIENCE & TECHNOLOGY, SYLHET

SAMPLE COLLECTED BY

I.B. ENGINEERS
40 JALALABAD R/A, SYLHET.
Mob- 01733905792

Introduction

A reasonably accurate conception about the sub-soil parameters of any project site is an essential prerequisite for proper planning and designing the foundation of the structure so that the same after its construction would remain safe and serviceable. A detailed study on the sub-surface elements in this regard would necessary to select proper type of foundation.

Objectives

The purpose of sub-soil investigation program is to obtain the following information

1. To classify the formation of soil layers
2. To estimate the safe bearing capacities of the foundation at different soil layers
3. To suggest the safe and appropriate type of foundations.

Scope of work

Centre for research, testing and consultancy (CRTC), Department of Civil and Environmental Engineering, Shahjalal University of Science & Technology (SUST), Sylhet; execute only the laboratory tests and other computational works with the supplied disturbed and/or undisturbed samples to determine the geotechnical properties of the soil.

Table – 1: Items of the supplied samples

No	Name	Bore hole no	Depth	Quantities
01	Disturbed sample	01	0-75 ft	15
02	Disturbed sample	02	0-75 ft	15
03	Disturbed sample	03	0-75 ft	15
04	Disturbed sample	04	0-75 ft	15
05	Disturbed sample	05	0-75 ft	15
06	Disturbed sample	06	0-75 ft	15
-	-	-	-	-
-	-	-	-	-
-	-	-	-	-
-	-	-	-	-

Laboratory Classifications

The disturbed soil samples, supplied by the client were thoroughly examined and classified roughly (color and type) and noted in accordance with bore hole (BH) and depth (Please see enclosed Tables).

Laboratory Works & Analysis

In addition to visual examination of the sample, Bearing Capacity of soil samples including skin friction & end bearing were calculated.

Bearing capacity for shallow foundation

The N value gives useful information with regards to consistency of cohesive soil and relative density of cohesion less soil. These relationships are given in the following Tables for cohesive and cohesion less soil, respectively.

Table 2: Relation of N-value with the Consistency and the Unconfined Compressive Strength of Cohesive Soils (after Bowles 1997)

N-values	Consistency	Unconfined Compressive Strength (q_u)	
		tsf	kPa
0-2	Very soft	0 to 0.25	0 to 25
3-5	Soft	0.25 to 0.50	25 to 50
6-9	Medium	0.50 to 1	50 to 100
10-16	Stiff	1 to 2	100 to 200
17-30	Very stiff	2 to 4	200 to 400
>30	Hard	>4	>400

Table 3: N and ϕ Relation to Relative Density for Fine Sand (after Bowles 1997)

N values	Compactness	Relative Density, Dr %	ϕ (degree)	Unit Weight (pcf)
1 – 2	Very Loose	0 – 15	26 – 28	70 – 100
3 – 6	Loose	15 – 35	28 – 30	90 – 115
7 – 15	Medium	35 – 65	30 – 34	110 – 130
16 – 30	Dense	65 – 85	33 – 38	110 – 140
>30	Very Dense	>85	>50	130 – 150

Table 4: N and ϕ Relation to Relative Density for Medium Sand (after Bowles 1997)

N values	Compactness	Relative Density, Dr %	ϕ (degree)	Unit Weight (pcf)
2 – 3	Very Loose	0 – 15	27 – 28	70 – 100
4 – 7	Loose	15 – 35	30 – 32	90 – 115
8 – 20	Medium	35 – 65	32 – 36	110 – 130
21 – 40	Dense	65 – 85	36 – 42	110 – 140

Table 5: N and ϕ Relation to Relative Density for Coarse Sand (after Bowles 1997)

N values	Compactness	Relative Density, Dr %	ϕ (degree)	Unit Weight (pcf)
3 – 6	Very Loose	0 – 15	28 – 30	70 – 100
5 – 9	Loose	15 – 35	30 – 34	90 – 115
10 – 25	Medium	35 – 65	33 – 40	110 – 130
26 – 40	Dense	65 – 85	40 – 50	110 – 140
>40	Very Dense	>85	>50	130 – 150

<u>Bearing capacity for deep foundation</u>

Foundations, preferably piles are considered to transmit heavy load from superstructure to deep and hard strata. As the formation of soil strata consists of cohesive and non-cohesive type, the evaluation criteria for the determination of skin friction and the end bearing capacities of piles also vary. Details of the evaluation are provided in the following sub-headings.

Table 6: Formula Used to Determine Bearing Capacity of Soil

Shallow Foundation	
For Cohesive Soil	
$q_a = q_u + \gamma \frac{D}{3}$ $q_a = q_u$(Common Practice)	Where, q_a = Allowable bearing capacity, q_u = Unconfined Compressive Strength, γ = Unit Weight of soil, D = Depth of footing
For Cohesion less Soil	
$q_{ult} = 30N$; $q_a = q_{ult}/FS$	q_{ult} = Ultimate bearing capacity in kPa, N = SPT Number, FS = Factor of Safety
Source: Bowles, J. E., "Physical and Geotechnical Properties of Soils", 2nd Edition	
Deep Foundation	
For Cohesive Soil	
$f_{su} = \alpha C_u$; $q_{pu} = N_c C_u$	α = Adhesion factor, f_{su} = Ultimate skin friction, C_u = Undrained Shear Strength, q_{pu} = Ultimate end bearing of pile, N_c = Bearing capacity factor for deep foundation = 9
For Cohesion less Soil	
$f_{su} = N/50\ tsf$; $q_{pu} = 4N\ tsf$	f_{su} = Ultimate skin friction, q_{pu} = Ultimate end bearing of pile, N = SPT Number
Source: Rajapakse RA (2008), "Geotechnical Engineering Calculations and Rules of Thumb"	

Based on the above formula, the important parameters for foundation design have been determined and are given in **Tables 7-11**.

Table 7: The allowable bearing capacity for shallow foundation in Tsf (FS=2.5) **

Bore Hole No.	Depth	Design N	Clay						Sand
			Continuous			Square (Isolated)			
	(ft)	-	D/B=0.25	D/B=0.5	D/B=1	D/B=0.25	D/B=0.5	D/B=1	
BH01	2.5-5.0	2	0.278	0.293	0.319	0.329	0.355	0.386	0.300
	5.0-10	3	0.348	0.366	0.399	0.411	0.444	0.483	0.375
BH02	2.5-5.0	3	0.325	0.342	0.372	0.384	0.414	0.451	0.350
	5.0-10	3	0.352	0.370	0.404	0.416	0.449	0.489	0.379
BH03	2.5-5.0	3	0.302	0.317	0.346	0.356	0.385	0.419	0.325
	5.0-10	3	0.352	0.370	0.404	0.416	0.449	0.489	0.379
BH04	2.5-5.0	3	0.348	0.366	0.399	0.411	0.444	0.483	0.375
	5.0-10	3	0.388	0.408	0.445	0.458	0.495	0.539	0.418
BH05	2.5-5.0	3	0.302	0.317	0.346	0.356	0.385	0.419	0.325
	5.0-10	3	0.348	0.366	0.399	0.411	0.444	0.483	0.375
BH06	2.5-5.0	3	0.325	0.342	0.372	0.384	0.414	0.451	0.350
	5.0-10	3	0.392	0.412	0.449	0.463	0.500	0.544	0.422
BH07	2.5-5.0	-	-	-	-	-	-	-	-
	5.0-10	-	-	-	-	-	-	-	-
BH08	2.5-5.0	-	-	-	-	-	-	-	-
	5.0-10	-	-	-	-	-	-	-	-
BH09	2.5-5.0	-	-	-	-	-	-	-	-
	5.0-10	-	-	-	-	-	-	-	-
BH10	2.5-5.0	-	-	-	-	-	-	-	-
	5.0-10	-	-	-	-	-	-	-	-

**** Design engineer should consider the settlement issue along with the tabulated bearing capacity for designing the shallow foundation.**

Table 8: Table 8: The allowable skin friction for Precast driven piles in Tsf (FS=2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	0.049	0.096	0.074	0.074	0.074	0.049	-	-	-	-
10	0.074	0.049	0.049	0.074	0.074	0.049	-	-	-	-
15	0.049	0.074	0.074	0.074	0.049	0.096	-	-	-	-
20	0.096	0.096	0.096	0.096	0.096	0.096	-	-	-	-
25	0.118	0.096	0.138	0.156	0.118	0.156	-	-	-	-
30	0.096	0.174	0.118	0.196	0.138	0.138	-	-	-	-
35	0.196	0.240	0.156	0.261	0.156	0.174	-	-	-	-
40	0.230	0.226	0.246	0.254	0.281	0.214	-	-	-	-
45	0.268	0.388	0.241	0.240	0.226	0.294	-	-	-	-
50	0.214	0.268	0.226	0.294	0.294	0.268	-	-	-	-
55	0.128	0.294	0.136	0.361	0.334	0.321	-	-	-	-
60	0.152	0.144	0.152	0.160	0.160	0.152	-	-	-	-
65	0.184	0.168	0.176	0.160	0.168	0.168	-	-	-	-
70	0.176	0.176	0.184	0.176	0.184	0.176	-	-	-	-
75	0.184	0.184	0.192	0.184	0.184	0.184	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

Table 9: The allowable end bearing for Precast driven piles in Tsf (FS = 2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	0.450	0.900	0.675	0.675	0.675	0.450	-	-	-	-
10	0.675	0.450	0.450	0.675	0.675	0.450	-	-	-	-
15	0.450	0.675	0.675	0.675	0.450	0.900	-	-	-	-
20	0.900	0.900	0.900	0.900	0.900	0.900	-	-	-	-
25	1.125	0.900	1.350	1.575	1.125	1.575	-	-	-	-
30	0.900	1.800	1.125	2.025	1.350	1.350	-	-	-	-
35	2.025	3.825	1.575	2.700	1.575	1.800	-	-	-	-
40	3.150	3.600	3.375	4.275	4.725	2.925	-	-	-	-
45	4.500	6.525	4.050	3.825	3.600	4.950	-	-	-	-
50	2.925	4.500	3.600	4.950	4.950	4.500	-	-	-	-
55	25.600	4.950	27.200	6.075	5.625	5.400	-	-	-	-
60	30.400	28.800	30.400	32.000	32.000	30.400	-	-	-	-
65	36.800	33.600	35.200	32.000	33.600	33.600	-	-	-	-
70	35.200	35.200	36.800	35.200	36.800	35.200	-	-	-	-
75	36.800	36.800	38.400	36.800	36.800	36.800	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

Table 10: The allowable skin friction for Bored piles in Tsf (FS = 2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	0.032	0.062	0.048	0.048	0.048	0.032	-	-	-	-
10	0.048	0.032	0.032	0.048	0.048	0.032	-	-	-	-
15	0.032	0.048	0.048	0.048	0.032	0.062	-	-	-	-
20	0.062	0.062	0.062	0.062	0.062	0.062	-	-	-	-
25	0.077	0.062	0.090	0.101	0.077	0.101	-	-	-	-
30	0.062	0.113	0.077	0.127	0.090	0.090	-	-	-	-
35	0.127	0.156	0.101	0.170	0.101	0.113	-	-	-	-
40	0.149	0.147	0.160	0.165	0.183	0.139	-	-	-	-
45	0.174	0.252	0.156	0.156	0.147	0.191	-	-	-	-
50	0.139	0.174	0.147	0.191	0.191	0.174	-	-	-	-
55	0.083	0.191	0.088	0.235	0.217	0.209	-	-	-	-
60	0.099	0.094	0.099	0.104	0.104	0.099	-	-	-	-
65	0.120	0.109	0.114	0.104	0.109	0.109	-	-	-	-
70	0.114	0.114	0.120	0.114	0.120	0.114	-	-	-	-
75	0.120	0.120	0.125	0.120	0.120	0.120	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

Table 11: The allowable end bearing for Bored piles in Tsf (FS = 2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	0.203	0.405	0.304	0.304	0.304	0.203	-	-	-	-
10	0.304	0.203	0.203	0.304	0.304	0.203	-	-	-	-
15	0.203	0.304	0.304	0.304	0.203	0.405	-	-	-	-
20	0.405	0.405	0.405	0.405	0.405	0.405	-	-	-	-
25	0.506	0.405	0.608	0.709	0.506	0.709	-	-	-	-
30	0.405	0.810	0.506	0.911	0.608	0.608	-	-	-	-
35	0.911	1.721	0.709	1.215	0.709	0.810	-	-	-	-
40	1.418	1.620	1.519	1.924	2.126	1.316	-	-	-	-
45	2.025	2.936	1.823	1.721	1.620	2.228	-	-	-	-
50	1.316	2.025	1.620	2.228	2.228	2.025	-	-	-	-
55	11.520	2.228	12.240	2.734	2.531	2.430	-	-	-	-
60	13.680	12.960	13.680	14.400	14.400	13.680	-	-	-	-
65	16.560	15.120	15.840	14.400	15.120	15.120	-	-	-	-
70	15.840	15.840	16.560	15.840	16.560	15.840	-	-	-	-
75	16.560	16.560	17.280	16.560	16.560	16.560	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

CONCLUSION AND RECOMMENDATION

On the basis of analysis and information provided by the owner following recommendations are suggested for the proposed four-storied building.

Soil profile scenario

Overall soil information of the investigated site is little irregular in between the boreholes, and vertical inconsistency exists in the soil formation. Grey soft clay soil with poor bearing capacity exists up to the top 30 ft in boreholes 01, 02, 04, 05, 06 and 35 ft in borehole 03 respectively. Then, grey stiff clay soil with poor to moderate bearing capacity has been found from 31 ft (or 36 ft) to 50 ft in boreholes 01, 03, and 55 ft in boreholes 02, 04, 05, 06 respectively. Finally, grey fine sand with silt and clay with moderate to good bearing capacity has been observed in boreholes 01, 02, 03, 04, 05, and 06.

Foundation options

In this situation, the foundation should be selected considering both the dimension and design load for the proposed building. Deep foundation (Bored/precast pile) may be selected to ensure the stability of the structure and to overcome the ground improvement complication. For designing any suitable deep foundation, the necessary data for skin friction and end bearing can be found from the attached table (8 to 11) in the report which is based on existing soil conditions.

Safety provisions

From the practical viewpoint, it has been found in many buildings that the structure failed due to soil settlement or judging the soil parameters incorrectly, providing no signs of structural damage. The earthquake vulnerability of the project area as well as the quality management of the construction work including workmanship should be taken into account for the safe design of the foundation.

Attachments

The layout of the boreholes of the investigated site and the bore-log profiles with SPT values is shown in the Appendix.

Special notes

These suggestions are absolutely tentative and the selection of type, depth, and dimensions of foundation would be decided by the Geotechnical Consultant or Design Engineer. It is also to be noted that the above recommendation is restricted only to the existing soil condition of 75 ft as the client provided.

Test Assisted By	Report Prepared By	Countersigned By
A. H. M. Humayun Kabir	**Dr. Ahmad Hasan Nury**	**Prof. Dr. H M A Mahzuz**
Senior Technical Officer Dept. of CEE, SUST-3114	Associate Professor Dept. of CEE, SUST-3114	Coordinator, CRTC Dept. of CEE, SUST, Sylhet-3114