গবেষণা, পরীক্ষণ ও কনসালটেনসি কেন্দ্র
পুর ও পরিবেশ কৌশল বিভাগ
শাহজালাল বিজ্ঞান ও প্রযুক্তি বিশ্ববিদ্যালয়
সিলেট-৩১১৪, বাংলাদেশ।
যোগাযোগঃ +৮৮ ০১৩১৮ ২১০ ২৮৬/২৮৭/২৮৮/২৮৯/২৯০
Website: www.crtc-cee-sust.com

Center for Research, Testing and Consultancy
Department of Civil and Environmental Engineering
Shahjalal University of Science and Technology
Sylhet-3114, Bangladesh.
Contact: +88 01318 210 286/ 287/ 288/ 289/ 290
Email: crtc-cee@sust.edu

Ref. no: CRTC/CEE/G20220611/S- 110

SUB-SOIL INVESTIGATION REPORT FOR PROPOSED ON 06 STORIED RESIDENTIAL BUILDING AT AKOTA-293, UTTAR BAGBARI, SYLHET. DAG # 10427, KHA # 10328, J.L # 75, MOUJA- BAGBARI.

CLIENT

SOYED ATAUR RAHMAN
S/O- SOYED ABDUL MOTIN

Verification Code: HHg6btD4
Verify report at: crtc-cee-sust.com

CONDUCTED BY
CENTER FOR RESEARCH TESTING & CONSULTANCY
DEPARTMENT OF CIVIL & ENVIRONMENTAL ENGINEERING
SHAHJALAL UNIVERSITY OF SCIENCE & TECHNOLOGY, SYLHET

Sample Collected by
THE UNIVERSAL SOIL & ENGINEERING
Moktosor Market (2nd Floor), Shop # 6, Bagbari Point, Sylhet.
Mobile: 01741-217881

Introduction

A reasonably accurate conception about the sub-soil parameters of any project site is an essential prerequisite for proper planning and designing the foundation of the structure so that the same after its construction would remain safe and serviceable. A detailed study on the sub-surface elements in this regard would necessary to select proper type of foundation.

Objectives

The purpose of sub-soil investigation program is to obtain the following information

1. To classify the formation of soil layers
2. To estimate the safe bearing capacities of the foundation at different soil layers
3. To suggest the safe and appropriate type of foundations.

Scope of work

Centre for research, testing and consultancy (CRTC), Department of Civil and Environmental Engineering, Shahjalal University of Science & Technology (SUST), Sylhet; execute only the laboratory tests and other computational works with the supplied disturbed and/or undisturbed samples to determine the geotechnical properties of the soil.

Table – 1: Items of the supplied samples

No	Name	Bore hole no	Depth	Quantities
01	Disturbed sample	01	0-30 ft	06
02	Disturbed sample	02	0-30 ft	06
03	Disturbed sample	03	0-30 ft	06
04	-	-	-	-
05	-	-	-	-
06	-	-	-	-
07	-	-	-	-
08	-	-	-	-
09	-	-	-	-
10	-	-	-	-

Laboratory Classifications

The disturbed soil samples, supplied by the client were thoroughly examined and classified roughly (color and type) and noted in accordance with bore hole (BH) and depth (Please see enclosed Tables).

Laboratory Works & Analysis

In addition to visual examination of the sample, Bearing Capacity of soil samples including skin friction & end bearing were calculated.

Bearing capacity for shallow foundation

The N value gives useful information with regards to consistency of cohesive soil and relative density of cohesion less soil. These relationships are given in the following Tables for cohesive and cohesion less soil, respectively.

Table 2: Relation of N-value with the Consistency and the Unconfined Compressive Strength of Cohesive Soils (after Bowles 1997)

N-values	Consistency	Unconfined Compressive Strength (q_u)	
		Tsf	kPa
0-2	Very soft	0 to 0.25	0 to 25
3-5	Soft	0.25 to 0.50	25 to 50
6-9	Medium	0.50 to 1	50 to 100
10-16	Stiff	1 to 2	100 to 200
17-30	Very stiff	2 to 4	200 to 400
>30	Hard	>4	>400

Table 3: N and ϕ Relation to Relative Density for Fine Sand (after Bowles 1997)

N values	Compactness	Relative Density, Dr %	ϕ (degree)	Unit Weight (pcf)
1 – 2	Very Loose	0 – 15	26 – 28	70 – 100
3 – 6	Loose	15 – 35	28 – 30	90 – 115
7 – 15	Medium	35 – 65	30 – 34	110 – 130
16 – 30	Dense	65 – 85	33 – 38	110 – 140
>30	Very Dense	>85	>50	130 – 150

Table 4: N and ϕ Relation to Relative Density for Medium Sand (after Bowles 1997)

N values	Compactness	Relative Density, Dr %	ϕ (degree)	Unit Weight (pcf)
2 – 3	Very Loose	0 – 15	27 – 28	70 – 100
4 – 7	Loose	15 – 35	30 – 32	90 – 115
8 – 20	Medium	35 – 65	32 – 36	110 – 130
21 – 40	Dense	65 – 85	36 – 42	110 – 140

Table 5: N and ϕ Relation to Relative Density for Coarse Sand (after Bowles 1997)

N values	Compactness	Relative Density, Dr %	ϕ (degree)	Unit Weight (pcf)
3 – 6	Very Loose	0 – 15	28 – 30	70 – 100
5 – 9	Loose	15 – 35	30 – 34	90 – 115
10 – 25	Medium	35 – 65	33 – 40	110 – 130
26 – 40	Dense	65 – 85	40 – 50	110 – 140
>40	Very Dense	>85	>50	130 – 150

<u>Bearing capacity for deep foundation</u>

Foundations, preferably piles are considered to transmit heavy load from superstructure to deep and hard strata. As the formation of soil strata consists of cohesive and non-cohesive type, the evaluation criteria for the determination of skin friction and the end bearing capacities of piles also vary. Details of the evaluation are provided in the following sub-headings.

Table 6: Formula Used to Determine Bearing Capacity of Soil

Shallow Foundation	
For Cohesive Soil	
$q_a = q_u + \gamma \frac{D}{3}$ $q_a = q_u$(Common Practice)	Where, q_a=Allowable bearing capacity, q_u= Unconfined Compressive Strength, γ= Unit Weight of soil, D= Depth of footing
For Cohesion less Soil	
$q_{ult} = 30N$; $q_a = q_{ult}/FS$	q_{ult}= Ultimate bearing capacity in kPa, N = SPT Number, FS= Factor of Safety
Source: Bowles, J. E., "Physical and Geotechnical Properties of Soils", 2nd Edition	
Deep Foundation	
For Cohesive Soil	
$f_{su} = \alpha C_u$; $q_{pu} = N_c C_u$	α = Adhesion factor, f_{su} = Ultimate skin friction, C_u = Undrained Shear Strength, q_{pu} = Ultimate end bearing of pile, N_c = Bearing capacity factor for deep foundation=9
For Cohesion less Soil	
$f_{su} = N/50\ tsf$; $q_{pu} = 4N\ tsf$	f_{su} = Ultimate skin friction, q_{pu} = Ultimate end bearing of pile, N = SPT Number
Source: Rajapakse RA (2008), "Geotechnical Engineering Calculations and Rules of Thumb"	

Based on the above formula, the important parameters for foundation design have been determined and are given in **Table 7**, **Table 8, Table 9, Table 10 and Table 11** respectively.

Table 7: The allowable bearing capacity for shallow foundation in Tsf (FS=2.5)

Bore Hole No.	**Depth**	**Design N**	**Clay**						**Sand**
			Continuous			**Square(Isolated)**			
	(ft)	**-**	**D/B=0.25**	**D/B=0.5**	**D/B=1**	**D/B=0.25**	**D/B=0.5**	**D/B=1**	
BH01	**2.5-5.0**	**15**	1.763	1.854	2.022	2.082	2.250	2.447	1.900
	5.0-10	**19**	2.252	2.368	2.582	2.660	2.873	3.126	2.427
BH02	**2.5-5.0**	**16**	1.856	1.952	2.128	2.192	2.368	2.576	2.000
	5.0-10	**20**	2.328	2.448	2.669	2.749	2.970	3.231	2.509
BH03	**2.5-5.0**	**13**	1.531	1.610	1.756	1.808	1.954	2.125	1.650
	5.0-10	**18**	2.108	2.217	2.417	2.490	2.690	2.926	2.272
BH04	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-
BH05	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-
BH06	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-
BH07	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-
BH08	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-
BH09	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-
BH10	**2.5-5.0**	**-**	-	-	-	-	-	-	-
	5.0-10	**-**	-	-	-	-	-	-	-

Table 8: The allowable skin friction for Precast driven piles in Tsf (FS=2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	0.192	0.192	0.176	-	-	-	-	-	-	-
10	0.136	0.144	0.104	-	-	-	-	-	-	-
15	0.072	0.080	0.072	-	-	-	-	-	-	-
20	0.256	0.256	0.256	-	-	-	-	-	-	-
25	0.248	0.248	0.248	-	-	-	-	-	-	-
30	0.232	0.232	0.232	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-
45	-	-	-	-	-	-	-	-	-	-
50	-	-	-	-	-	-	-	-	-	-
55	-	-	-	-	-	-	-	-	-	-
60	-	-	-	-	-	-	-	-	-	-
65	-	-	-	-	-	-	-	-	-	-
70	-	-	-	-	-	-	-	-	-	-
75	-	-	-	-	-	-	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

Table 9: The allowable end bearing for Precast driven piles in Tsf (FS=2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	38.400	38.400	35.200	-	-	-	-	-	-	-
10	27.200	28.800	20.800	-	-	-	-	-	-	-
15	14.400	16.000	14.400	-	-	-	-	-	-	-
20	51.200	51.200	51.200	-	-	-	-	-	-	-
25	49.600	49.600	49.600	-	-	-	-	-	-	-
30	46.400	46.400	46.400	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-
45	-	-	-	-	-	-	-	-	-	-
50	-	-	-	-	-	-	-	-	-	-
55	-	-	-	-	-	-	-	-	-	-
60	-	-	-	-	-	-	-	-	-	-
65	-	-	-	-	-	-	-	-	-	-
70	-	-	-	-	-	-	-	-	-	-
75	-	-	-	-	-	-	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

Table 10: The allowable skin friction for Bored piles in Tsf (FS=2.5)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	0.125	0.125	0.114	-	-	-	-	-	-	-
10	0.088	0.094	0.068	-	-	-	-	-	-	-
15	0.047	0.052	0.047	-	-	-	-	-	-	-
20	0.166	0.166	0.166	-	-	-	-	-	-	-
25	0.161	0.161	0.161	-	-	-	-	-	-	-
30	0.151	0.151	0.151	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-
45	-	-	-	-	-	-	-	-	-	-
50	-	-	-	-	-	-	-	-	-	-
55	-	-	-	-	-	-	-	-	-	-
60	-	-	-	-	-	-	-	-	-	-
65	-	-	-	-	-	-	-	-	-	-
70	-	-	-	-	-	-	-	-	-	-
75	-	-	-	-	-	-	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

Table 11: The allowable end bearing for Bored piles in Tsf (FS=3.0)

Depth	Bore Hole									
ft	BH01	BH02	BH03	BH04	BH05	BH06	BH07	BH08	BH09	BH10
5	17.280	17.280	15.840	-	-	-	-	-	-	-
10	12.240	12.960	9.360	-	-	-	-	-	-	-
15	6.480	7.200	6.480	-	-	-	-	-	-	-
20	23.040	23.040	23.040	-	-	-	-	-	-	-
25	22.320	22.320	22.320	-	-	-	-	-	-	-
30	20.880	20.880	20.880	-	-	-	-	-	-	-
35	-	-	-	-	-	-	-	-	-	-
40	-	-	-	-	-	-	-	-	-	-
45	-	-	-	-	-	-	-	-	-	-
50	-	-	-	-	-	-	-	-	-	-
55	-	-	-	-	-	-	-	-	-	-
60	-	-	-	-	-	-	-	-	-	-
65	-	-	-	-	-	-	-	-	-	-
70	-	-	-	-	-	-	-	-	-	-
75	-	-	-	-	-	-	-	-	-	-
80	-	-	-	-	-	-	-	-	-	-
85	-	-	-	-	-	-	-	-	-	-
90	-	-	-	-	-	-	-	-	-	-
95	-	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-	-

CONCLUSION AND RECOMMENDATION

On the basis of analysis and information provided by the owner following recommendations are suggested for the proposed six storied residential building.

Soil profile scenario

Overall soil information of the investigated site is nearly regular in between the boreholes and vertical inconsistency exists in the soil formation. In case of all bore holes (BH 01 and BH 02 and BH03), sandy soil with good bearing capacity is observed in top 10ft of the EGL followed by sandy clay soil at the depth of 15ft from EGL. From 20ft of the EGL, dense sandy soil with good bearing capacity is observed.

Foundation options

In this situation, the foundation should be selected considering both the dimension and design load for the proposed building. Since sandy soil with good bearing capacity is found at the top soil in case of all boreholes, shallow foundation can be considered. The bearing capacity of the existing soil for shallow foundation is given in the **Table 7**.

Deep foundation (pre-cast pilling) can also be considering to ensure the stability of the structure. Size and depth of the pile should be selected in the light of bearing capacity given in the report (Table 8-11).

Safety provisions

It is recommended to check the **settlement** of the site considering building load while designing shallow foundation. P**ile load test** covering the entire project area should be carried out for confirming the design parameters of the service pile (*if pile foundation is considered*). Moreover, the earthquake vulnerability of the project area as well as the quality management of the construction work including workmanship should be taken into account for the safe design of shallow or deep foundation.

Attachments

The layout of the bore holes of the investigated site and the bore-log profiles with SPT values is shown in the Appendix. Client performed no special laboratory test for the proposed site.

Special notes

These suggestions are absolutely tentative and selection of type, depth and dimensions of foundation would be decided by the Consultant or Design Engineer. It is also to be noted that the above recommendation is restricted only to the existing soil condition of **30** ft as client provided.

Report Prepared By	**Test Assisted By**	**Counter Signed By**
A. H. M. Humayun Kabir	**Dr. Md Bashirul Haque**	**Prof. Dr. H.M.A Mahzuz**
Senior Technical Officer Dept. of CEE, SUST	Associate Professor Dept. of CEE, SUST	Coordinator, CRTC Dept. of CEE, SUST