

Heating System Fault Codes - Demo Reference

Fictional fault-code catalogue for retrieval testing | Ref: DEMO-FAULT-100

Important: This document is fictional material created for an AI-agent demonstration. Values and procedures must be validated against the actual appliance manual, installation standard and site conditions before field use.

1. Demo fault-code table

Code	Demo description	Agent-guided first checks
F10	Low system water pressure	Confirm gauge reading; check for recent bleeding/leaks; verify approved fill range in model manual
F21	Flow-temperature sensor implausible	Compare displayed temperature with pipe condition; inspect sensor connection if authorised
F32	Insufficient circulation detected	Check pump operation, isolation valves, air, filter/strainer and system pressure
F44	Excessive temperature rise	Check circulation, demand, valves and heat dissipation before reset
F57	External interlock / control demand issue	Check thermostat/controller demand and wiring only within competence
F71	Repeated pressure excursion	Record cold/hot pressure; inspect relief discharge; investigate expansion control

2. Retrieval rule

These codes are deliberately fictional. In a real deployment, the AI agent must retrieve the code from the exact Firebird product manual or approved service bulletin. It should never infer a fault-code meaning from another manufacturer or product family.