
NETWORK SECURITY INCIDENT REPORT

REPORT DATE : 18/05/2026
ANALYST : Gaurav Shukla

INCIDENT TIMELINE

First packet : 2014-05-20 06:23:19.329569
Last packet : 2014-05-20 06:24:15.173919
Duration : 55.844350 seconds

AFFECTED SYSTEMS

Infected IP : No
Hostname : Not found
Location : [department/floor/VLAN]

INDICATORS OF COMPROMISE (IOCs)

Suspicious Ip : 118.189.96.132
Source IP : 118.189.96.132
DST IP : 118.189.96.132
Dst Port : 502(ICS and SCADA port)
Src Port : 55480-55490 modbus (Protocol inherent plane text)

Protocol Hierarchy Statistics

Filter:

Frame	frames:166 bytes:12198
Eth	frames:166 bytes:12198
TCP	frames:160 bytes:11200
mbtcp	frames:32 bytes:2496
modbus	frames:32 bytes:2496

Observation

Traffic observed on TCP Port 502 (Modbus Protocol)
Source and Destination IP address appear same
No direct indication of Malicious activity

Security Note

NO malicious activity found from the analysed captured packets
However monitor Modbus communication because the protocol lacks
encryption and authentication.