

BRUHAT BENGALURU MAHANAGARA PALIKE

GREATER BENGALURU AUTHORITY (GBA)

Office of the Assistant Director of Town Planning
Mahadevapura Zone

Application No.: BPA/MDP/2026/04/0782

Date: 22 April 2026

To,
Sri/Smt. Property Owner
Site No. 47, 5th Cross, 1st Stage,
Whitefield, Bengaluru - 560066

Subject: Plan-check corrections for proposed residential building
at Site No. 47, Whitefield - Required revisions for resubmission

Sir / Madam,

With reference to your application dated 18 March 2026 for sanction of the building plan for the captioned property, the submitted drawings have been scrutinized and the following objections are raised. You are requested to rectify the same and resubmit the revised plans within 30 days from the date of this letter, failing which the application is liable to be treated as withdrawn under Sakala Mission provisions.

OBJECTIONS:

1. The front setback shown in the plan is 0.6 m, which is below the minimum prescribed setback of 0.75 m as per the amended Zonal Regulations dated 5-6 January 2026. Kindly revise the front setback and update all affected sheets.
2. The FAR calculation provided on the cover sheet does not include the staircase core area. As per BBMP Building Bye-Laws read with KTCP Act Section 19, total built-up area for FAR shall include all enclosed floor area. The calculation must be revised.
3. EV charging infrastructure provision is not indicated in the parking layout. As per the amended Zonal Regulations 2026, 20% of total parking spaces shall include EV charging readiness (conduit and meter). Please incorporate.
4. Latest property tax receipt has not been enclosed with the application. Please submit the receipt for the financial year 2025-26.
5. The plan does not show the rainwater harvesting (RWH) pit, which is mandatory for all new constructions in BBMP limits. Please indicate the RWH structure with capacity calculation on the site plan.
6. The structural stability certificate from a registered structural engineer has not been attached. As the proposed construction is G+2 with a planned G+3 provision, this is required.
7. The architect's empanelment certificate number is not legible on the title block of Sheet A1. Please reprint with the empanelment number clearly visible.

You are advised to address each objection point-wise in your resubmission. The revised plans should be uploaded to the BPAS portal (bpas.bbmpgov.in) along with this corrections letter.

Yours faithfully,

Assistant Director of Town Planning
Mahadevapura Zone, BBMP / GBA