

Sofia Lopez Mendoza

Task 1:

Use a weather forecast website, and utilize the psychrometric chart and the formula we went through in the class to determine the absolute humidity, the wet-bulb temperature and the mass of water vapour in the air in Classroom A (Aula A) of Piacenza campus in the moment that you are solving this exercise (provide the inputs that you utilized).

Room Aula A (aprox measures) : 14 * 7.4 * 4

T= 25 C

P= 100 kPa

ϕ Humidity according with Piacenza's cast = 85%

Saturation pressure of water 25 C = 3.1698 kPa

$$\phi = \frac{P_v}{P_g} \rightarrow P_v = \phi \times P_g = 0.85 \times 3.1698 = 2.69 \text{ kPa}$$

$$\text{partial pressure of dry air: } P_a = P - P_v = 100 \text{ kPa} - 2.69 \text{ kPa} = 97.31 \text{ kPa}$$

$$\omega = 0.622 \frac{P_v}{P_a} = 0.622 \frac{2.69}{97.31} = 0.0171 \frac{\text{Kg}_{\text{vapour}}}{\text{kg}_{\text{dryAir}}}$$

$$\text{For air: } m_a = \frac{P_a V_a}{R_a T} \quad R_{sp.} = \frac{R_{global}}{M_{gas}} \rightarrow R_a = 0.287 \quad R_v = 0.4615$$

$$m_a = \frac{97.31 \times (14 \times 7.4 \times 4)}{0.287 \times (273 + 25)} = \frac{40,325.26}{85.52} = 471.53 \text{ kg}$$

$$m_v = \frac{2.69 \times (14 \times 7.4 \times 4)}{0.4615 \times (273 + 25)} = \frac{1114.73}{137.52} = 8.10 \text{ kg}$$

$$\omega = 0.017 \text{ kg air vapour}$$

$$T_{wb} = 25 \text{ C}$$

Task 2:

Utilize the same methodology we went through in the class and determine the sensible and latent load corresponding to internal gains, the ventilation, and the infiltration in a house with a good construction quality and with the same geometry as that of the example which is located in Brindisi, Italy.

Building height = 2.5m

Floor area = 200 m²

Number of occupants = 2

Number of bedrooms = 1

Wall area = 144 m²

Temperature difference calculation

$$\Delta T_{\text{cooling}} = 31.1 - 24 = 7.1^{\circ}\text{C}$$

$$\Delta T_{\text{heating}} = 20 - 4.1 = 15.9^{\circ}\text{C}$$

$$DR = 7.1^{\circ}\text{C}$$

Internal gains

$$\dot{Q}_{ig \text{ sensible}} = 136 + 2.2 A_{cf} + 22 N_{oc} = 136 + 2.2 \times 200 + 22 \times 2 = 620 \text{ W}$$

$$\dot{Q}_{ig \text{ latent}} = 20 + 0.22 A_{cf} + 12 N_{oc} = 20 + 0.22 \times 200 + 12 \times 2 = 88 \text{ W}$$

Infiltration

$$A_{ul} = 14 \frac{\text{cm}^2}{\text{m}^2}$$

$$A_{es} = 200 + 144 = 344 \text{ m}^2$$

$$AL = A_{es} \times A_{ul} = 344 \times 1.4 = 481.6 \text{ cm}^2$$

$$IDF_{\text{heating}} = 0.063 \frac{L}{s \cdot \text{cm}^2}$$

$$IDF_{\text{cooling}} = 0.053 \frac{L}{s \cdot \text{cm}^2}$$

$$\dot{Q}_{ig \text{ heating}} = AL \times IDF = 481.6 \times 0.063 = 30.34 \frac{L}{s}$$

$$\dot{Q}_{ig \text{ cooling}} = AL \times IDF = 481.6 \times 0.053 = 25.52 \frac{L}{s}$$

Ventilation

$$\dot{Q}_v = 0.05 A_{cf} + 3.5 (N_{br} + 1) = 0.05 \times 200 + 3.5 \times 2 = 17 \frac{L}{s}$$

$$\dot{Q}_{\text{inf-ventilation heating}} = 30.34 + 17 = 47.34 \frac{L}{s}$$

$$\dot{Q}_{\text{inf-ventilation cooling}} = 25.52 + 17 = 42.52 \frac{L}{s}$$