



WEEK 8 – ASSIGNMENT

Task 1 Using the diagrams given in the presentation calculate how much (%) is the effect of applying different modifications (changing the gas, adding an extra pane, using a low emissivity coating) on the U value with respect to a benchmark case of double layer with air and no coating ? (keep the gap thickness to be 13 mm)



PANEL WITH AIR GAP 13mm			U-VALUE	EFFECT %
D-PG	AIR BETWEEN	N-COATING	2.80	0%
D-P	ARGON	N-COATING	2.65	5%
D-P	KRYPTON	N-COATING	2.60	7%
D-P	AIR	COATING IP	1.80	36%
D-P	ARGON	COATING IP	1.55	45%
D-P	KRYPTON	COATING IP	1.40	50%
TP	AIR	NO-COATING	1.80	36%
TP	ARGON	NO-COATING	1.65	41%
TP	KRYPTON	NO-COATING	1.55	45%
TP	AIR	COATING IP	1.00	64%
TP	ARGON	COATING IP	0.8	71%
TP	KRYPTON	COATING IP	0.70	75%

Task 2 Consider the house that we analysed in the alst two examples, calculate the heating and cooling load of the other windows which are fixed 14.4 m² on the west, fixed 3.6 m² on the south and an operable 3.6 m² on the south (the same window and frame type). How much does the total value change if I change the frame of the window from wooden one to aluminium ?

CASE 1 : FIXED WINDOW ON WEST :

Cooling load :

Frame : wood

$$q_{\text{windowW}} = A \cdot C_{\text{windowW}} ; A = 14,4 \text{ m}^2$$

$$C_{\text{windowWheattransfer}} = U_{\text{windowW}} (\Delta T_{\text{cooling}} - 0,46 \text{ DR}) = 2,84 \cdot (7,9 - 0,46 \cdot 11,9)$$

$$\mathbf{C_{windowWheattransfer} = 6,89 \text{ w/m}^2}$$

$$P_{\text{XlwindowW}} = E_{\text{D}} + E_{\text{d}} = 559 + 188 = 747 ; \text{SHGC} = 0,54 ; \quad \text{IAC} = 1 ; \quad F_{\text{fs}} = 0,56$$

$$C_{\text{windowWirradiation}} = P_{\text{Xl}} \cdot \text{SHGC} \cdot \text{IAC} \cdot F_{\text{fs}} = 747 \cdot 0,54 \cdot 1 \cdot 0,56$$

$$\mathbf{C_{windowWirradiation} = 225,9}$$

$$q_{\text{windowW}} = A \cdot C_{\text{windowW}} = A \cdot (C_{\text{windowWheattransfer}} + C_{\text{windowWirradiation}}) = 14,4 \cdot (6,89 + 225,9)$$

$$\mathbf{q_{windowW} = 3352,17 \text{ W}}$$

Heating load :

Frame : aluminium

$$q_{\text{windowW}} = A \cdot H_{\text{windowW}} = A \cdot U_{\text{windowW}} \Delta T_{\text{heating}} = 14,4 \cdot 2,84 \cdot 24,8$$

$$\mathbf{q_{windowW} = 1014,22 \text{ W}}$$

$$U_{\text{windowW}} = 3,61 ; \text{HSGC} = 0,56$$

$$C_{\text{F'windowWheattransfer}} = U'_{\text{windowW}} \cdot ((\Delta T_{\text{cooling}} - 0,46 \text{ DR}) = 3,61 \cdot (7,9 - 0,46 \cdot 11,9)$$

$$\mathbf{C_{F'windowWheattransfer} =}$$

$$\mathbf{8,76 \text{ Cooling load :}}$$

$$q'_{\text{windowW}} = A \cdot C_{\text{F'windowW}} = A \cdot (C_{\text{F'windowWheattransfer}} + C_{\text{F'windowWirradiation}}) = 14,4 \cdot (8,76 + 234,26)$$

$$\mathbf{q'_{windowW} = 3499,49 \text{ W}}$$

Heating load :

$$q'_{\text{windowW}} = A \cdot H'_{\text{windowW}} = A \cdot U'_{\text{windowW}} \cdot \Delta T_{\text{heating}} = 14,4 \cdot 3,61 \cdot 24,8$$

$$\mathbf{q'_{\text{windowW}} = 1289,2 \text{ W}}$$

CASE 2: FIXED WINDOW ON SOUTH:

Cooling load :

Frame : wood

$$q_{\text{windowS}} = A \cdot C_{\text{windowS}} ; A = 3,6 \text{ m}^2$$

$$C_{\text{windowSheattransfer}} = U_{\text{windowS}} (\Delta T_{\text{cooling}} - 0,46 \text{ DR}) = 2,84 \cdot (7,9 - 0,46 \cdot 11,9)$$

$$\mathbf{C_{\text{windowSheattransfer}} = 6,89 \text{ w/m}^2}$$

$$P_{\text{IwindowS}} = E_D + E_d = 348 + 209 = 557 ; \text{SHGC} = 0,56 ; \quad \text{IAC} = 1 ; \quad F_{\text{fs}} = 0,47$$

$$C_{\text{windowSirradiation}} = P_{\text{I}} \cdot \text{SHGC} \cdot \text{IAC} \cdot F_{\text{fs}} = 557 \cdot 0,56 \cdot 1 \cdot 0,47$$

$$\mathbf{C_{\text{windowSirradiation}} = 146,60}$$

$$q_{\text{windowS}} = A \cdot C_{\text{windowS}} = A \cdot (C_{\text{windowSheattransfer}} + C_{\text{windowSirradiation}}) = 3,6 \cdot (6,89 + 146,60)$$

$$\mathbf{q_{\text{windowW}} = 552,56 \text{ W}}$$

Heating load :

Frame : aluminium

$$q_{\text{windowS}} = A \cdot H'_{\text{windowS}} = A \cdot U_{\text{windowS}} \cdot \Delta T_{\text{heating}} = 3,6 \cdot 2,84 \cdot 24,8$$

$$\mathbf{q_{\text{windowW}} = 253,56 \text{ W}}$$

$$U_{\text{windowS}} = 3,61 ; \text{HSGC} = 0,56$$

$$C'_{\text{windowSheattransfer}} = U'_{\text{windowS}} \cdot (\Delta T_{\text{cooling}} - 0,46 \text{ DR}) = 3,61 \cdot (7,9 - 0,46 \cdot 11,9)$$

$$\mathbf{C'_{\text{windowWheattransfer}} = 8,76 \text{ W/m}^2}$$

Cooling load :

$$q'_{\text{windowS}} = A \cdot C'_{\text{windowS}} = A \cdot (C'_{\text{windowSheattransfer}} + C'_{\text{windowSirradiation}}) = 3,6 \cdot (8,76 + 146,60)$$

$$\mathbf{q'_{\text{windowS}} = 559,3 \text{ W}}$$

Heating load :

$$q'_{\text{windowS}} = A * HF'_{\text{windowS}} = A * U'_{\text{windowS}} * \Delta T_{\text{heating}} = 3,6 * 3,61 * 24,8$$

$$\mathbf{q'_{\text{windowW}} = 322,3 \text{ W}}$$

CASE 3: OPERABLE WINDOW ON SOUTH:

COOLING LOAD FOR THE OPERABLE:

$$q_{\text{windowS}} = A * CF_{\text{windowS}} ; A = 3,6 \text{ m}^2$$

$$CF_{\text{windowSheattransfer}} = U_{\text{windowS}} (\Delta T_{\text{cooling}} - 0,46 \text{ DR}) = 2,87 * (7,9 - 0,46 * 11,9)$$

$$\mathbf{CF_{\text{windowSheattransfer}} = 6,96 \text{ w/m}^2}$$

$$PXI_{\text{windowS}} = ED + Ed = 348 + 209 = 557 ; SHGC = 0,46 ; \quad IAC = 1 ; Ffs = 0,47$$

$$CF_{\text{windowSirradiation}} = PXI * SHGC * IAC * FFs = 557 * 0,46 * 1 * 0,47$$

$$\mathbf{CF_{\text{windowSirradiation}} = 120,42}$$

$$q_{\text{windowS}} = A * CF_{\text{windowS}} = A * (CF_{\text{windowSheattransfer}} + CF_{\text{windowSirradiation}}) = 3,6 * (6,96 + 120,42)$$

$$\mathbf{q_{\text{windowS}} = 533,97 \text{ W}}$$

HEATING LOAD (fixed window):

$$q_{\text{windowS}} = A * HF_{\text{windowS}} = A * U_{\text{windowS}} * \Delta T_{\text{heating}} = 3,6 * 2,87 * 24,8$$

$$\mathbf{q_{\text{windowW}} = 256,23 \text{ W}}$$

with aluminium frame :

$$U_{\text{windowS}} = 3,61 ; HSGC = 0,56$$

$$CF'_{\text{windowSheattransfer}} = U'_{\text{windowS}} * (\Delta T_{\text{cooling}} - 0,46 \text{ DR}) = 4,62 * (7,9 - 0,46 * 11,9)$$

$$\mathbf{CF'_{\text{windowWheattransfer}} = 11,21 \text{ W/m}^2}$$

Cooling load :

$$q'_{\text{windowS}} = A * CF'_{\text{windowS}} = A * (CF'_{\text{windowSheattransfer}} + CF'_{\text{windowSirradiation}}) = 3,6 * (11,21 + 143,98)$$

$$\mathbf{q'_{\text{windowS}} = 558,7 \text{ W}}$$

Heating load :

$$q'_{\text{window}} = A \cdot H_{F'_{\text{window}}} = A \cdot U'_{\text{window}} \cdot \Delta T_{\text{heating}} = 3,6 \cdot 4,62 \cdot 24,8$$

$$\mathbf{q'_{\text{window}} = 412,47 \text{ W}}$$

