

## Task 1

$$A=10*25*5 \quad T=10 \quad P=100\text{kPa} \quad \phi = 65\%$$

$$\phi = \frac{m_v}{m_g} = \frac{P_v}{P_g} \rightarrow P_g = P_{sat} 10^\circ\text{C} = 1.2276 \text{ kPa}$$

$$\phi = \frac{P_v}{P_g} \rightarrow P_v = \phi \times P_g = 0.65 * 1.2276 = 0.7979 \text{ kPa}$$

$$P_a = P - P_v = 100 \text{ kPa} - 0.80 \text{ kPa} = 99.20 \text{ kPa}$$

$$\omega = 0.622 \frac{P_v}{P_a} = 0.622 \frac{0.80}{99.20} = 0.005 \frac{\text{kg}_{\text{vapour}}}{\text{kg}_{\text{dryAir}}}$$

$$R_a = 0.287, R_v = 0.4615$$

$$m_a = \frac{99.20 * (10 * 25 * 5)}{0.287 * (273 + 10)} = 1526.70 \text{ kg of dry air}$$

$$m_v = \frac{0.80 * (10 * 25 * 5)}{0.4615 * (273 + 10)} = 7.66 \text{ kg}$$

$$h_a = 1.005 * T = 1.005 * 10 = 10.05 \frac{\text{kJ}}{\text{kg}_{\text{dryAir}}}$$

$$h_v = 2501.3 + 1.82 * 10 = 2519.5 \frac{\text{kJ}}{\text{kg}_{\text{water}}}$$

$$h_{\square} = h_a + \omega h_v = 10.05 + 0.005 * 2519.5 = 22.65 \frac{\text{kJ}}{\text{kg}_{\text{dryAir}}}$$

## Task 2

A building with a height of 2.5 m and a good construction quality, is located in Piacenza, considering two occupants and one bed room calculate, and a conditioned floor area of 200 m<sup>2</sup> wall area is 144 m<sup>2</sup>, calculate the internal gains, infiltration, and ventilation loads.

Internal gains

$$Q_{ig_{sensible}} = 136 + 2.2 * A_{cf} + 22 N_{oc} = 136 + 2.2 * 200 + 22 * 2 = 620 W$$

$$Q_{ig_{latent}} = 20 + 0.22 * A_{cf} + 12 N_{oc} = 20 + 0.22 * 200 + 12 * 2 = 88 W$$

**Table 3 Unit Leakage Areas**

Construction	Description	$A_{ul}, \text{cm}^2/\text{m}^2$
Tight	Construction supervised by air-sealing specialist	0.7
Good	Carefully sealed construction by knowledgeable builder	1.4
Average	Typical current production housing	2.8
Leaky	Typical pre-1970 houses	5.6
Very leaky	Old houses in original condition	10.4

Good quality  $\rightarrow A_{ul} = 1.4 \frac{\text{cm}^2}{\text{m}^2}$

Exposed surface = Wall area + roof area

$$A_{es} = 200 + 144 = 344 \text{ m}^2$$

$$A_L = A_{es} \times A_{ul} = 344 \times 1.4 = 481.6 \text{ cm}^2$$

**Table 5 Typical IDF Values,  $\text{L}/(\text{s} \cdot \text{cm}^2)$**

$H, \text{m}$	Heating Design Temperature, °C					Cooling Design Temperature, °C			
	-40	-30	-20	-10	0	10	30	35	40
2.5	0.10	0.095	0.086	0.077	0.069	0.060	0.031	0.035	0.040
3	0.11	0.10	0.093	0.083	0.072	0.061	0.032	0.038	0.043
4	0.14	0.12	0.11	0.093	0.079	0.065	0.034	0.042	0.049
5	0.16	0.14	0.12	0.10	0.086	0.069	0.036	0.046	0.055
6	0.18	0.16	0.14	0.11	0.093	0.072	0.039	0.050	0.061
7	0.20	0.17	0.15	0.12	0.10	0.075	0.041	0.051	0.068
8	0.22	0.19	0.16	0.14	0.11	0.079	0.043	0.058	0.074

$$IDF_{heating} = 0.073 \frac{L}{\text{s} \cdot \text{cm}^2}$$

$$IDF_{cooling} = 0.033 \frac{L}{\text{s} \cdot \text{cm}^2}$$

$$\begin{aligned} V_{infiltration_{heating}} &= A_L \times IDF \\ &= 481.6 * 0.073 = 35.16 \frac{L}{s} \end{aligned}$$

$$\begin{aligned} V_{infiltration_{cooling}} &= A_L \times IDF = 481.6 * 0.033 \\ &= 15.89 \frac{L}{s} \end{aligned}$$

## BRINDISI, Italy

WMO#: 163200

Lat: 40.65N Long: 17.95E Elev: 10 StdP: 101.2 Time Zone: 1.00 (EUW) Period: 86-10 WBAN: 99999

## Annual Heating and Humidification Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD to 99.6% DB	
			99.6%			99%			0.4%		1%			
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
2	2.9	4.1	-5.1	2.5	7.2	-3.0	3.0	7.4	13.4	10.2	12.4	10.6	3.4	250

(1)

## Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	32.8	23.6	31.1	24.3	29.9	24.3	27.2	29.7	26.3	29.0	25.6	28.3	4.2	180

(2)

Dehumidification DPMCDB and HR									Enthalpy/MCDB						Hours 8 to 4 & 12.8/20.6
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	29.2	25.4	20.7	28.5	24.7	19.7	27.9	86.0	30.1	82.2	29.1	78.5	28.3	1236

(3)

## Extreme Annual Design Conditions

Extreme Annual WS			Extreme Max WB	Extreme Annual DB				n-Year Return Period Values of Extreme DB							
1%		2.5%		Mean		Standard deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(4) 11.3	9.9	8.7	31.4	0.4	37.3	1.4	3.0	-0.6	39.4	-1.4	41.1	-2.2	42.8	-3.2	44.9

(4)

$$V_{\text{ventilation}} = 0.05 A_{cf} + 3.5 (N_{br} + 1) = .05 * 200 + 3.5 * 2 = 17 \text{ L/S}$$

$$V_{\text{inf-ventilation}_{\text{heating}}} = 35.16 + 17 = 52.16 \text{ L/s}$$

$$V_{\text{inf-ventilation}_{\text{cooling}}} = 15.89 + 17 = 32.89 \text{ L/s}$$

$$C_{\text{sensible}} = 1.23, C_{\text{latent}} = 3010$$

$$Q_{\text{inf-ventilation}_{\text{cooling}_{\text{sensible}}}} = C_{\text{sensible}} V \Delta T_{\text{cooling}} = 1.23 * 32.89 * (31.1 - 24.3) = 275.09 \text{ W}$$

$$Q_{\text{inf-ventilation}_{\text{cooling}_{\text{latent}}}} = C_{\text{latent}} V \Delta \omega_{\text{cooling}} = 3010 * 32.89 * 0.0039 = 386.09 \text{ W}$$

$$Q_{\text{inf-ventilation}_{\text{heating}_{\text{sensible}}}} = C_{\text{sensible}} V \Delta T_{\text{heating}} = 1.23 * 52.16 * (20 - 4.1) = 1020.09 \text{ W}$$