From Passive Estates to Flexible Generators

A Multi-Vector Digital Twin for Decarbonising Business Parks

Gift Udoh · CDT-GIF · Heriot-Watt University / University of St Andrews

Progress review — Paper 1 (modelling) & Paper 1 (RSER review)

What I set out to do

- **Question:** can PV + multi-vector storage turn a UK business park from a passive load into a flexible, low-carbon generator?
- **Method:** a physics-based **digital-twin framework** (PyPSA + pvlib + HiGHS) of **Eden Campus**, a real innovation campus in Fife.
- **Approach:** five configurations over **8,760 hours** of optimised dispatch — PV-only (S0) through full hybrid (S4: PV + battery + thermal + hydrogen).
- **Two outputs:** the modelling paper (this review's focus) and a systematic review positioning business parks as a flexibility resource.

The system modelled

Three coupled energy vectors, optimised for least cost:

Vector	Components
Electricity	Solar PV (1 MW), grid import/export, battery (500 kW / 2 MWh)
Hydrogen	Electrolyser → 5 MWh tank → fuel cell (long-duration storage)
Heat	Heat pump (COP 3), PCM thermal store (200 kW / 1.6 MWh), backup boiler

- Weather from committed **PVGIS 2023** (St Andrews, 56.34°N) — reproducible offline.
- Costs on the **capacity-charge tariff basis** (£120/kW/yr, UK commercial DUoS).

Headline result — S1 (PV + Battery) is operationally optimal

Scenario	Solar Fraction (%)	CO_2 Saved (t/yr)	Peak Reduction (%)	Annual Cost (£k)
S0: PV Only	31.8	178.0	1.4	539.0
S1: PV + BESS	**38.8**	**217.2**	**39.7**	**468.0**
S2: PV + PCM TES	35.0	195.7	1.4	683.3
S3: PV + H_2 LDES	39.4	220.5	8.8	515.6
S4: Full Hybrid	42.7	238.8	40.0	628.4

S1 saves £71k/yr (£1.42M over 20 yr) vs baseline, cuts 217 tCO_2/yr, and reduces peak grid import by ~40%.

The novel finding — the tariff-dependent heat-pump peak

Heat-pump electrification (S2, S4) has **opposite** peak effects depending only on the tariff signal:

- **Energy-only tariff:** cost-minimising dispatch drives peak imports **+35%** (672 → 904 kW) — cheap heat is dispatched without regard to system peak.
- **Capacity/demand charge:** the same system **reduces** the peak by up to **40%** — the objective now values peak management.

The "objective-function trap"

> A cost-minimising model delivers what the objective *rewards* — not necessarily what the flexibility transition *needs*. The tariff signal must be in the objective.

The honest limitation — demand is synthetic

- Electrical & thermal demand are **representative CIBSE-benchmark profiles**, not metered site data (2,401 MWh/yr, 682 kW peak).
- This is **stated explicitly** in the manuscript as the primary limitation.
- **I have built the pipeline to replace it the moment real data arrives:**
  - `ingest_real_demand.py` — normalises any HH/kWh supplier format
  - `compare_demand_synthetic_vs_real.py` — quantifies how reality differs
  - synthetic baseline preserved; `data_prep.py` swaps in real data, no code change

Why the limitation doesn't change my conclusions

Stress test: re-ran all five scenarios with demand scaled **0.70× – 1.30×** (1,681–3,121 MWh/yr) — bracketing where real data could plausibly land.

Conclusion	Across the whole ±30% band
S1 is cost-optimal	**YES — at every scale**
Cost ranking stable	**YES — S1 < S3 < S0 < S4 < S2 throughout**
Peak-reduction pattern	**YES — S1/S4 high, S2/S3 low throughout**

> My conclusions are **structural**, not artefacts of the demand calibration. Real data will refine magnitudes — it will not reverse the findings.

Marginal abatement cost — reinforces the trap

Abatement cost vs S0, against the **UK ETS price of £49.41/tCO₂** (2026):

Scenario	MAC (£/tCO₂)	Reading
S1: PV + BESS	**−1,811**	**cost-negative — paid to decarbonise**
S3: PV + H₂	**−551**	**cost-negative**
S4: Full Hybrid	+1,470	**expensive — far above carbon price**
S2: PV + PCM TES	very high	**not cost-effective (tiny ΔCO₂)**

Electrical storage (S1, S3) abates **below zero cost**; heat-pump options cost far more per tonne than any carbon market — the objective-function trap, quantified.

Paper 2 (RSER review) — first output, well-architected

"From passive estates to flexible generators: a systematic review of UK business parks in electricity markets."

- **Spine:** structural fit → institutional invisibility → objective-function trap.
- **Original contribution:** a 5-type typology (T1–T5) of UK business parks mapped to the FES 2025 flexibility categories — the first such characterisation.
- **Method:** PRISMA 2020 + PRISMA-S, 3 databases + grey corpus, Rayyan, Cohen's κ, with field-specific appraisal (data / scale / market realism).

RSER review — verification status

Verified this session	Status
FES 2025 flexibility figures (127 TWh, 51 GW EV, 10→96 GW storage)	✅ **vs NESO source**
Legal: Class E, Scottish/NI use classes, RED II Art. 22	✅ **primary sources**
Regulatory: TCR, P415, DFS year-round, REMA	✅ **(dates corrected)**
Method refs (PRISMA, Rayyan, Cohen)	✅ **supplied**
Typology exemplars (Edinburgh Park, Eurocentral, MSIP, Catalyst)	✅ **confirmed**

Remaining (the evidence phase): screened-corpus citations & findings, PRISMA flow counts, data-spine park counts — the irreducible systematic-review legwork.

Reproducibility & provenance — built in

- **Every manuscript number traces to a committed artifact:**
  - Tables 3 & 4 → `generate_manuscript_tables.py` (from model output)
  - Table 5 (meteorology) → `table5_meteorological_summary.py` (from raw CSVs)
  - Stress test, MAC, all figures (300 dpi) → committed scripts
- **Single source of truth:** `data_prep.py` — no hand-transcription.
- **All on GitHub**, version-controlled, re-runnable in the `eden_phd` environment.

Where I am and what's next

Done & defensible

- Modelling paper: numerically sound, internally consistent, stress-tested
- Review paper: architected, every verifiable claim checked

Immediate next steps

1. **Ingest real Eden Campus demand** → run comparison harness
   → re-run model (pipeline ready)
2. Fill RSER review from screened corpus (the evidence phase)
3. Paper 2 (co-optimised dispatch) & Paper 3 (peak-aware thermal storage)

Thank you — discussion

Key artifacts (all committed to GitHub):

- `Paper1_Eden_Campus_Manuscript.docx` — modelling paper
- `generate_manuscript_tables.py`, `stress_test_demand_sensitivity.py` — reproducible results
- `paper1_RSER_review/` — review sections + verification records
- `REVIEW_2026-11-07…md` — independent editorial review
- `data_prep.py`, `ingest_real_demand.py`, `compare_demand_synthetic_vs_real.py` — data pipeline

Happy to take questions — including on the synthetic-demand limitation.

Q&A Annex — prep (not for projection)

"Your demand is synthetic — how do you know anything?"
Stated as the primary limitation. Stress test shows S1-optimal, ranking, and peak findings hold across ±30% demand. Conclusions are structural; magnitudes will refine with your data. Pipeline is built to ingest it with no code change.

"Isn't this just a simulation, not a digital twin?"
Correct distinction. It's a digital-twin **framework** demonstrated with synthetic inputs. The bidirectional measured-data coupling is the next phase — which is exactly why the ingest/validation harness already exists.

"Why is S1 better than the full hybrid S4?"
Under the capacity-charge tariff, battery storage of electricity is the cheapest marginal improvement. S4 adds heat-pump electrical load that raises cost more than its extra CO_2/solar-fraction benefit — see the MAC split.

"Your peak finding — 35% or 40%?"
Both, and that's the point: +35% peak *increase* under energy-only tariff; ~40% *reduction* under a capacity charge. Same system, opposite outcomes, tariff-driven.

"Is the review finished?"
No — it's architected and every fact-checkable claim is verified. The evidence phase (corpus screening, data-spine counts) is the remaining systematic-review work.