# Rate of Change of Frequency under line contingencies

Robin Delabays

robin. delabays @ hevs.ch

R. D., M. Tyloo, and P. Jacquod, arXiv preprint 1906.05698 (2019)




#### Where is HES-SO?




Introduction

000000



#### Motivation



Line contingencies and RoCoF

OFEN, Statistique Suisse de l'électricité 2018.

IEA, Global EV Outlook 2019 (www.iea.org/publications/reports/globalevoutlook2019/).

Introduction

0000000

What is the impact of a given contingency?

What are the critical elements in a grid?

How to identify (efficiently) critical operating states?

## The Swing Equations

We consider:

$$m_i\ddot{\theta}_i + d_i\dot{\theta}_i = P_i - \sum_i b_{ij}(\theta_i - \theta_j), \qquad i \in \{1,...,n\},$$

Line contingencies and RoCoF

 $m_i$ : inertia,  $d_i$ : damping,  $b_{ii}$ : susceptance,  $P_i$ : generation/load.

$$M\ddot{\theta} + D\dot{\theta} = \mathbf{P} - \mathbb{L}\boldsymbol{\theta}$$
,

 $M = \operatorname{diag}(\mathbf{m}), D = \operatorname{diag}(\mathbf{d}), \mathbb{L}$  Laplacian matrix.

Shorthand notation:  $\omega_i := \dot{\theta}_i$ .

A. R. Bergen and V. Vittal. Power System Analysis (Prentice Hall, 2000).

Line contingencies and RoCoF

## Analytical solution

Introduction

0000000

Assume  $m_i \equiv m$ ,  $d_i \equiv d$ , and consider angle deviations

$$\delta heta(t) = heta(t) - heta^* \,, \hspace{0.5cm} heta^* = \mathbb{L}^\dagger extsf{P}_0 \,, \hspace{0.5cm} extsf{P}(t) = extsf{P}_0 + \delta extsf{P}(t) \,.$$

$$m \dot{\delta heta} + d \dot{\delta heta} = \delta extbf{P}(t) - \mathbb{L} \delta heta$$
 .

Expanding on the eigenmodes of  $\mathbb{L}$ :

$$\mathbb{L}\mathbf{u}^{(\alpha)} = \lambda_{\alpha}\mathbf{u}^{(\alpha)}, \qquad \delta\theta(t) = \sum_{\alpha=1}^{n} c_{\alpha}(t)\mathbf{u}^{(\alpha)}.$$

Line contingencies and RoCoF

## Analytical solution

Introduction

0000000

Assume  $m_i \equiv m$ ,  $d_i \equiv d$ , and consider angle deviations

$$\delta heta(t) = heta(t) - heta^* \,, \hspace{0.5cm} heta^* = \mathbb{L}^\dagger extsf{P}_0 \,, \hspace{0.5cm} extsf{P}(t) = extsf{P}_0 + \delta extsf{P}(t) \,.$$

$$m\ddot{c}_{lpha}(t)+d\dot{c}_{lpha}(t)=\delta\mathbf{P}(t)\cdot\mathbf{u}^{(lpha)}-\lambda_{lpha}c_{lpha}(t)\,,\quad lpha=1,...,n\,.$$

Expanding on the eigenmodes of  $\mathbb{L}$ :

$$\mathbb{L}\mathbf{u}^{(lpha)} = \lambda_{lpha}\mathbf{u}^{(lpha)}\,, \qquad \qquad oldsymbol{\delta}oldsymbol{ heta}(t) = \sum_{lpha=1}^n c_{lpha}(t)\mathbf{u}^{(lpha)}\,.$$

Line contingencies and RoCoF

## Analytical solution

Assume  $m_i \equiv m$ ,  $d_i \equiv d$ , and consider angle deviations

$$\delta heta(t) = heta(t) - heta^* \,, \hspace{0.5cm} heta^* = \mathbb{L}^\dagger extsf{P}_0 \,, \hspace{0.5cm} extsf{P}(t) = extsf{P}_0 + \delta extsf{P}(t) \,.$$

$$\mbox{\it m}\ddot{c}_{lpha}(t)+\mbox{\it d}\dot{c}_{lpha}(t)=m{\delta}\mathbf{P}(t)\cdot\mathbf{u}^{(lpha)}-\lambda_{lpha}c_{lpha}(t)\,,\quad lpha=1,...,n\,.$$

Analytical solution:

$$c_{lpha}(t)=m^{-1}e^{-(\gamma+\Gamma_{lpha})t/2}\int_{0}^{t}e^{\Gamma_{lpha}t_{1}}\int_{0}^{t_{1}}\delta\mathbf{P}(t_{2})\cdot\mathbf{u}^{(lpha)}e^{(\gamma-\Gamma_{lpha})t_{2}/2}dt_{2}dt_{1}$$
 .

M. Tyloo and P. Jacquod, Phys. Rev. E 100 032303 (2019).

## Contingencies

Swing Equations,  $i \in \{1, ..., n\}$ :

•0000

Contingencies and measures

$$M\ddot{\theta} + D\dot{\theta} = \mathbf{P} - \mathbb{L}\boldsymbol{\theta}$$
.

**Nodal perturbations:** additive,  $P \rightarrow P + \delta P$ .










Line perturbations: multiplicative,  $\mathbb{L} \to \mathbb{L} - \beta \mathbf{e}_{ij} \mathbf{e}_{ij}^{\top}$ .




## Measures of the impact

**Transmission losses**:  $\mathcal{L}_2$ -norm of angle deviations.

Primary control effort:  $\mathcal{L}_2$ -norm of frequency deviations.

**Nadir**:  $\mathcal{L}_{\infty}$ -norm of frequency deviations.

**RoCoF**:  $\mathcal{L}_{\infty}$ -norm of the time derivative of the frequency.



Line contingencies and RoCoF

$$\sup_t |\dot{\omega}(t)|$$

E. Tegling, B. Bamieh, and D. F. Gayme, IEEE Trans. Control Netw. Syst. 2 254 (2015).

T. W. Grunberg and D. F. Gayme, IEEE Trans. Control Netw. Syst. 5, 456 (2018).

B. K. Poolla, S. Bolognani, and F. Dörfler, IEEE Trans. Autom. Control 62 6209 (2017).

F. Paganini and E. Mallada. Proc. of the 55th ACCC (2017).

T. Coletta and P. Jacquod, IEEE Trans. Control Netw. Syst. Early access (2019).

#### The RoCoF

Maximal local RoCoF:

$$\operatorname{RoCoF} = \max_{i} \|\dot{\omega}_{i}(t)\|_{\infty}.$$

ω [a.u.] -0.1 t [a.u.]

Line contingencies and RoCoF

•0000


RoCoF is maximal at  $t = 0^+$ .

$$\omega(0) = 0, \qquad \mathbf{P} = \mathbb{L} \; \boldsymbol{\theta}(0), \qquad \mathbb{L}^* = \mathbb{L} - b_{ij} \mathbf{e}_{ij} \mathbf{e}_{ij}^{\top},$$

$$M\dot{\omega}(0) + D\omega(0) = \mathbf{P} - \mathbb{L}^*\theta(0)$$
,

$$\implies \dot{\omega}_k = (\delta_{ik} - \delta_{jk}) \frac{b_{ij}(\theta_i - \theta_j)}{m_i}. \rightarrow \text{RoCoF at nodes } i \text{ and } j.$$


## Numerics (IEEE 118-Bus)



Line contingencies and RoCoF

00000

## Numerics (IEEE 118-Bus)



Line contingencies and RoCoF

00000

Black line: theory.

x: 100% inertia at loads, RoCoF at all nodes.

x: 100% inertia at loads, RoCoF at generators only.

x: 1% inertia at loads, RoCoF at generators only.

x: 0% inertia at loads, RoCoF at generators only.


#### Including uncertainties

Statistics on generation and loads:

$$\mathbb{E}[P_k] = \mu_k, \qquad \mathbb{E}[(P_k - \mu_k)(P_\ell - \mu_\ell)] = \Pi_{k\ell}.$$

One gets:


$$\mathbb{E}(\dot{\omega}_i) = rac{b_{ij}}{m_i} \mathbf{e}_{ij}^{ op} \mathbb{L}^{\dagger} oldsymbol{\mu} \,,$$



$$ext{var}(\dot{\omega}_i) = rac{b_{ij}^2}{m_i^2} \mathbf{e}_{ij}^ op \mathbb{L}^\dagger \mathsf{\Pi} \mathbb{L}^\dagger \mathbf{e}_{ij} \,.$$

Line contingencies and RoCoF

00000




#### Including uncertainties

Statistics on generation and loads:

$$\mathbb{E}[P_k] = \mu_k, \qquad \mathbb{E}[(P_k - \mu_k)(P_\ell - \mu_\ell)] = \Pi_{k\ell}.$$

One gets:

$$\mathbb{E}(\dot{\omega}_i) = \frac{b_{ij}}{m_i} \mathbf{e}_{ij}^{\top} \mathbb{L}^{\dagger} \boldsymbol{\mu} , \qquad \operatorname{var}(\dot{\omega}_i) = \frac{b_{ij}^2}{m_i^2} \mathbf{e}_{ij}^{\top} \mathbb{L}^{\dagger} \boldsymbol{\Pi} \mathbb{L}^{\dagger} \mathbf{e}_{ij} .$$



Conclusion

#### Conclusion

The RoCoF after a line loss is:

- proportional to the flow on the line;
- inversely propotional to the inertia of the node where it is measured.

If we have only statistics on the power injections, we derive statistics on the RoCoFs.

#### **Consequences:**

- The most loaded lines are the most critical (expected);
- Less inertia means more critical systems, but...

**Caveat:** We assume inertia at every nodes, which is not true (yet...).

