

Huawei TechArena 2025: BESS Energy Management System

Phase II Research Framework & Mathematical Model

Gen Li (Team SoloGen)

Based on Phase I Model and Literature Review

November 8, 2025

Abstract

This document outlines the mathematical formulation for the Phase II challenge of the Huawei TechArena 2025. This model directly extends the deterministic Mixed-Integer Linear Program (MILP) developed in Phase I. Responding to the practical constraints of the competition (deterministic data, open-source solvers), this framework explicitly avoids stochastic optimization.

The Phase II model introduces two key extensions:

1. **Market Integration:** It incorporates the new **aFRR Energy Market**, co-optimizing energy bids alongside the Day-Ahead (DA) energy market and the FCR/aFRR capacity markets.
2. **Degradation Modeling:** It replaces the simple "Daily Cycle Limit" (Cst-5) from Phase I with a sophisticated, linearized **degradation cost function**. This cost, subtracted from the objective, is based on the piecewise-linear models for both cyclic aging (Xu et al., 2017) and calendar aging (Collath et al., 2023), allowing the model to trade off revenue against battery lifetime dynamically.

The resulting formulation remains a deterministic MILP, ensuring compatibility with open-source solvers while capturing the core economic and physical trade-offs of Phase II.

1 Introduction

The Phase I model established a strong foundation for co-optimizing BESS bids across three markets: DA Energy, FCR Capacity, and aFRR Capacity. The primary goal of Phase II is to enhance this model's realism and profitability by integrating two new factors: the aFRR Energy Market and the economic impact of battery degradation.

This document presents the revised mathematical formulation. It is designed to build directly upon the Phase I model, modifying existing constraints and adding new logic, rather than starting from a new, incompatible framework.

Sets and Indices

T, t	Set and index for 15-minute time intervals $t \in \{1, \dots, 35040\}$
B, b	Set and index for 4-hour ancillary service blocks $b \in \{1, \dots, 2190\}$
J, j	Set and index for cycle degradation cost segments $j \in \{1, \dots, J\}$
I, i	Set and index for calendar degradation cost breakpoints $i \in \{1, \dots, I\}$

Parameters

Symbol	Description	Unit
$P_{DA}(t)$	Day-ahead electricity price	EUR/MWh
$P_{FCR}(b)$	FCR capacity price	EUR/MW/h
$P_{aFRR}^{\text{pos}}(b)$	Positive aFRR capacity price	EUR/MW/h
$P_{aFRR}^{\text{neg}}(b)$	Negative aFRR capacity price	EUR/MW/h
$P_{aFRR,E}^{\text{pos}}(t)$	(New) Positive aFRR energy price	EUR/MWh
$P_{aFRR,E}^{\text{neg}}(t)$	(New) Negative aFRR energy price	EUR/MWh
E_{nom}	Nominal energy capacity	kWh
$P_{\text{max}}^{\text{config}}$	Max charge/discharge power	kW
$\eta_{\text{ch}}, \eta_{\text{dis}}$	Charging/discharging efficiencies	-
$SOC_{\text{min}}, SOC_{\text{max}}$	Min/max SOC limits (fraction)	-
E_j^{seg}	(New) Max energy capacity of segment j	kWh
c_j^{cost}	(New) Marginal cyclic degradation cost for segment j	EUR/kWh
SOC_i^{point}	(New) SOC breakpoint i for calendar cost	kWh
$Cost_i^{\text{point}}$	(New) Calendar degradation cost at breakpoint i	EUR/hr
α	(New) Degradation price (meta-parameter)	-

Decision Variables

Symbol	Description	Type
$p_{\text{ch}}(t), p_{\text{dis}}(t)$	DA charge/discharge power	Cont. ≥ 0
$p_{aFRR,E}^{\text{pos}}(t)$	(New) aFRR-E positive (discharge) power	Cont. ≥ 0
$p_{aFRR,E}^{\text{neg}}(t)$	(New) aFRR-E negative (charge) power	Cont. ≥ 0
$c_{fcr}(b)$	FCR capacity bid	Cont. ≥ 0
$c_{aFRR}^{\text{pos}}(b)$	Positive aFRR capacity bid	Cont. ≥ 0
$c_{aFRR}^{\text{neg}}(b)$	Negative aFRR capacity bid	Cont. ≥ 0
$p_{\text{ch}}^{\text{total}}(t), p_{\text{dis}}^{\text{total}}(t)$	(New) Total charge/discharge power	Cont. ≥ 0
$p_j^{\text{ch}}(t), p_j^{\text{dis}}(t)$	(New) Charge/discharge power for segment j	Cont. ≥ 0
$e_{\text{soc},j}(t)$	(New) Energy stored in segment j	Cont. ≥ 0
$e_{\text{soc}}(t)$	(New) Total energy stored in BESS	Cont. ≥ 0
$c_{\text{cost}}^{\text{cal}}(t)$	(New) Calendar cost at time t	Cont. ≥ 0
$\lambda_{t,i}$	(New) SOS2 variable for calendar cost	Cont. ≥ 0
$y_{\text{ch}}(t), y_{\text{dis}}(t)$	DA bid binaries	Binary
$y_{fcr}(b), y_{aFRR}^{\text{pos}}(b), \dots$	Ancillary service bid binaries	Binary
$y_{aFRR,E}^{\text{pos}}(t), \dots$	(New) aFRR-E bid binaries	Binary
$y_{\text{ch}}^{\text{total}}(t), y_{\text{dis}}^{\text{total}}(t)$	(New) Total operation binaries	Binary

2 Phase I Model - Base Model**Objective Function**

The objective is to maximize the total net profit over the one-year horizon. This is the sum of day-ahead energy arbitrage revenue and ancillary service capacity payments (FCR + aFRR), minus the cost of energy purchased for charging.

$$\max Z = \mathbb{P}^{DA} + \mathbb{P}^{ANCI} \quad (1)$$

Where:

$$\mathbb{P}^{DA} = \sum_{t \in T} \left(\frac{P_{DA}(t)}{1000} p_{\text{dis}}(t) - \frac{P_{DA}(t)}{1000} p_{\text{ch}}(t) \right) \Delta t \quad (2)$$

$$\mathbb{P}^{ANCI} = \sum_{b \in B} \left(P_{FCR}(b) c_{fcr}(b) + P_{aFRR}^{\text{pos}}(b) c_{aFRR}^{\text{pos}}(b) + P_{aFRR}^{\text{neg}}(b) c_{aFRR}^{\text{neg}}(b) \right) \Delta b \quad (3)$$

- Where T is the set of 15-minute intervals in 2024 (35,040 intervals); B is the set of 4-hour blocks (6 blocks/day $\times$ 365 days = 2,190 blocks), and $t \in b$ denotes the set of 16 consecutive 15-minute intervals within block b .
- The first term $\mathbb{P}^{DA}$ is day-ahead net profit.
 - $p_{\text{dis}}(t)$ and $p_{\text{ch}}(t)$ are the nominal discharge and charge power (bids) at time t (kW), respectively.
 - $P_{DA}(t)$ is the day-ahead market price at time t (EUR/MWh).
 - Δt is the time step duration (hours).
- The second term $\mathbb{P}^{ANCI}$ is ancillary service capacity profit.
 - Bids $c(b)$ are in MW and prices $P(b)$ are in EUR/MW/h (hourly rates). Multiplying by $\Delta b = 4$ hours yields EUR per block.

Constraints

The optimization is subject to the following constraints.

(Cst-0): Variable Domains

$$p_{\text{ch}}(t) \geq 0, \quad p_{\text{dis}}(t) \geq 0 \quad \forall t \in T \quad (4)$$

$$c_{fcr}(b) \geq 0, \quad c_{aFRR}^{\text{pos}}(b) \geq 0, \quad c_{aFRR}^{\text{neg}}(b) \geq 0 \quad \forall b \in B \quad (5)$$

$$y_{\text{ch}}(t), y_{\text{dis}}(t) \in \{0, 1\} \quad \forall t \in T \quad (6)$$

$$y_{fcr}(b), y_{aFRR}^{\text{pos}}(b), y_{aFRR}^{\text{neg}}(b) \in \{0, 1\} \quad \forall b \in B \quad (7)$$

(Cst-1): Energy Balance (SOC Dynamics)

Update SOC based on charge/discharge actions considering efficiencies:

$$e_{\text{soc}}(t) = e_{\text{soc}}(t-1) + \left(p_{\text{ch}}(t) \eta_{\text{ch}} - \frac{p_{\text{dis}}(t)}{\eta_{\text{dis}}} \right) \Delta t \quad \forall t \in T \quad (8)$$

For $t = 1$, use the initial SOC:

$$e_{\text{soc}}(1) = e_{\text{soc}}^{\text{init}} + \left(p_{\text{ch}}(1) \eta_{\text{ch}} - \frac{p_{\text{dis}}(1)}{\eta_{\text{dis}}} \right) \Delta t \quad (9)$$

Where e_{soc} is the state of charge, and η_{ch} and η_{dis} are the charging and discharging efficiencies, respectively.

(Cst-2): SOC Limits

BESS energy stays within min/max SOC bounds:

$$SOC_{\min} E_{\text{nom}} \leq e_{\text{soc}}(t) \leq SOC_{\max} E_{\text{nom}} \quad \forall t \in T \quad (10)$$

Where E_{nom} is the nominal energy capacity of the BESS.

(Cst-3): Simultaneous Operation Prevention

No charge and discharge at the same time:

$$y_{\text{ch}}(t) + y_{\text{dis}}(t) \leq 1 \quad \forall t \in T \quad (11)$$

(Cst-4): Market Co-optimization Power Limits

Set total power limits on both energy bids and reserved ancillary service capacities. The total committed power in either direction (charge or discharge) must not exceed the BESS power rating.

Total Discharge Power Limit: The sum of any discharge bid in the DA market plus any reserved capacity for services that require discharging (FCR is symmetric, positive aFRR is discharge) must not exceed the maximum power rating.

$$p_{\text{dis}}(t) + 1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{pos}}(b) \leq P_{\text{max}}^{\text{config}} \quad \forall b \in B, \forall t \in b \quad (12)$$

Total Charge Power Limit: The sum of any charge bid in the DA market plus any reserved capacity for services that require charging (FCR is symmetric, negative aFRR is charge) must not exceed the maximum power rating.

$$p_{\text{ch}}(t) + 1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{neg}}(b) \leq P_{\text{max}}^{\text{config}} \quad \forall b \in B, \forall t \in b \quad (13)$$

Where we convert capacity bids (in MW) to kW by $\times 1000$.

(Cst-5): Daily Cycle Limits

Limit the total daily discharged energy throughput from the battery. This is based on the energy drawn from the DC side, accounting for discharge inefficiency.

$$\sum_{t \in d} \frac{p_{\text{dis}}(t)}{\eta_{\text{dis}}} \Delta t \leq N_{\text{cycles}} E_{\text{nom}} \quad \forall d \in D \quad (14)$$

(Cst-6): Ancillary Service Energy Reserve

Maintain sufficient energy reserve for ancillary service activation, accounting for BESS efficiency. The parameter τ represents the assumed worst-case continuous activation duration for reserves (typically set to $\Delta t = 0.25$ hours for this model).

To provide upward regulation (discharge): The available energy in the BESS must cover the energy drawn from the DC side.

$$\frac{(1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{pos}}(b)) \tau}{\eta_{\text{dis}}} \leq e_{\text{soc}}(t) - SOC_{\text{min}} E_{\text{nom}} \quad \forall b \in B, \forall t \in b \quad (15)$$

To provide downward regulation (charge): The available headroom in the BESS must be able to store the energy delivered to the DC side.

$$(1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{neg}}(b)) \tau \eta_{\text{ch}} \leq SOC_{\text{max}} E_{\text{nom}} - e_{\text{soc}}(t) \quad \forall b \in B, \forall t \in b \quad (16)$$

(Cst-7): Ancillary Service Market Mutual Exclusivity

Prevent simultaneous bidding in multiple markets for the same block:

$$y_{fcr}(b) + y_{aFRR}^{\text{pos}}(b) + y_{aFRR}^{\text{neg}}(b) \leq 1 \quad \forall b \in B \quad (17)$$

(Cst-8): Cross-Market Mutual Exclusivity

To ensure physical feasibility, the BESS cannot commit to charging in one market while simultaneously committing to discharging in another for the same time interval. The following constraints prevent such conflicting bids between the Day-Ahead market (15-min interval t) and ancillary service capacity markets (4-hour block b).

- A Day-Ahead discharge bid ($y_{\text{dis}}(t) = 1$) is incompatible with reserving capacity for charging services (FCR or negative aFRR).
- A Day-Ahead charge bid ($y_{\text{ch}}(t) = 1$) is incompatible with reserving capacity for discharging services (FCR or positive aFRR).

$$y_{\text{dis}}(t) + y_{\text{fcr}}(b) + y_{\text{aFRR}}^{\text{neg}}(b) \leq 1 \quad \forall b \in B, \forall t \in b \quad (18)$$

$$y_{\text{ch}}(t) + y_{\text{fcr}}(b) + y_{\text{aFRR}}^{\text{pos}}(b) \leq 1 \quad \forall b \in B, \forall t \in b \quad (19)$$

(Cst-9): Minimum and Maximum Bid Sizes

Bids can be non-zero only if the corresponding binary is 1; if non-zero, they must also satisfy minimum size and available power. $P_{\text{max}}^{\text{config}}$ is the configured maximum power rating of the BESS (kW).

Day-Ahead Energy Bids:

$$y_{\text{ch}}(t) \text{MinBid}_{da} \cdot 1000 \leq p_{\text{ch}}(t) \leq y_{\text{ch}}(t) P_{\text{max}}^{\text{config}} \quad \forall t \in T \quad (20)$$

$$y_{\text{dis}}(t) \text{MinBid}_{da} \cdot 1000 \leq p_{\text{dis}}(t) \leq y_{\text{dis}}(t) P_{\text{max}}^{\text{config}} \quad \forall t \in T \quad (21)$$

Notice $p(t)$ is in kW, while MinBid_{da} is in MW.

FCR Capacity Bids:

$$y_{\text{fcr}}(b) \text{MinBid}_{\text{fcr}} \leq c_{\text{fcr}}(b) \leq y_{\text{fcr}}(b) \frac{P_{\text{max}}^{\text{config}}}{1000} \quad \forall b \in B \quad (22)$$

aFRR Capacity Bids:

$$y_{\text{aFRR}}^{\text{pos}}(b) \text{MinBid}_{\text{afrr}} \leq c_{\text{aFRR}}^{\text{pos}}(b) \leq y_{\text{aFRR}}^{\text{pos}}(b) \frac{P_{\text{max}}^{\text{config}}}{1000} \quad \forall b \in B \quad (23)$$

$$y_{\text{aFRR}}^{\text{neg}}(b) \text{MinBid}_{\text{afrr}} \leq c_{\text{aFRR}}^{\text{neg}}(b) \leq y_{\text{aFRR}}^{\text{neg}}(b) \frac{P_{\text{max}}^{\text{config}}}{1000} \quad \forall b \in B \quad (24)$$

3 Phase II Model Derivation

We extend the Phase I MILP (Base Model) by modifying the objective function and relevant constraints.

✓ **Model (i):** Base Model + aFRR Energy Market

X **Model (ii):** Model (i) + Cyclic Aging Cost

X **Model (iii):** Model (ii) + Calendar Aging Cost = Full Phase II Model

3.1 Model (i): Base Model + aFRR Energy Market

The aFRR Energy market (15-min granularity) operates similarly to the DA market as a price-taker energy market. We introduce new variables for bidding in this market and update all constraints that manage power and energy.

- **New Variables:** $p_{aFRR,E}^{\text{pos}}(t)$ (discharge/positive) and $p_{aFRR,E}^{\text{neg}}(t)$ (charge/negative) for energy bids in the aFRR energy market.
- **New Binaries:** $y_{aFRR,E}^{\text{pos}}(t)$ and $y_{aFRR,E}^{\text{neg}}(t)$ to manage minimum bids.
- **Objective Function:** A new profit term $\mathbb{P}^{aFRR-E}$ is added:

$$\mathbb{P}^{aFRR-E} = \sum_{t \in T} \left(\frac{P_{aFRR,E}^{\text{pos}}(t)}{1000} p_{aFRR,E}^{\text{pos}}(t) - \frac{P_{aFRR,E}^{\text{neg}}(t)}{1000} p_{aFRR,E}^{\text{neg}}(t) \right) \Delta t \quad (25)$$

This requires revising the core physical constraints to prevent conflicts. We define new **total** charge/discharge variables:

$$p_{\text{ch}}^{\text{total}}(t) = p_{\text{ch}}(t) + p_{aFRR,E}^{\text{neg}}(t) \quad \forall t \quad (26)$$

$$p_{\text{dis}}^{\text{total}}(t) = p_{\text{dis}}(t) + p_{aFRR,E}^{\text{pos}}(t) \quad \forall t \quad (27)$$

These totals are then used to update the SOC, power, and mutual exclusivity constraints from Phase I.

And the minimum/maximum bid constraints are updated to include the new aFRR-E bids:

$$y_{aFRR,E}^{\text{pos}}(t) \text{MinBid}_{aFRR-E} \cdot 1000 \leq p_{aFRR,E}^{\text{pos}}(t) \leq y_{aFRR,E}^{\text{pos}}(t) P_{\text{max}}^{\text{config}} \quad \forall t \quad (28)$$

$$y_{aFRR,E}^{\text{neg}}(t) \text{MinBid}_{aFRR-E} \cdot 1000 \leq p_{aFRR,E}^{\text{neg}}(t) \leq y_{aFRR,E}^{\text{neg}}(t) P_{\text{max}}^{\text{config}} \quad \forall t \quad (29)$$

$$y_{\text{ch}}^{\text{total}}(t) \geq y_{aFRR,E}^{\text{neg}}(t); \quad y_{\text{dis}}^{\text{total}}(t) \geq y_{aFRR,E}^{\text{pos}}(t) \quad \forall t \quad (30)$$

Integrating Battery Degradation as a Linear Cost

We replace the rigid Phase I constraint (Cst-5) $\sum p_{\text{dis}} \leq N_{\text{cycles}} E_{\text{nom}}$ with a flexible and more profitable **degradation cost function**, $C^{\text{Degradation}}$. This cost is subtracted from the objective function, allowing the optimizer to find the best balance between high-revenue, high-degradation actions and low-revenue, low-degradation actions.

Following the literature provided (Collath et al., 2023; Xu et al., 2017), we model this cost as the sum of calendar and cyclic aging:

$$C^{\text{Degradation}} = C^{\text{cal}} + C^{\text{cyc}}$$

3.2 Model (ii): Model (i) + Cyclic Aging Cost

Based on the methodology from Xu et al. (2017), we model cyclic aging as a **convex piecewise-linear cost of discharge**. The battery's energy capacity E_{nom} is divided into J segments (e.g., 10 segments of 10% SOC). Discharging from a shallower segment (e.g., 90-100% SOC) is "cheaper" than discharging from a deeper segment (e.g., 20-30% SOC).

- **New Variables:** $e_{\text{soc},j}(t)$ (energy in segment j), $p_j^{\text{ch}}(t)$ (charge to segment j), and $p_j^{\text{dis}}(t)$ (discharge from segment j).
- **Cost Function:** $C^{\text{cyc}} = \sum_{t \in T} \sum_{j \in J} \left(c_j^{\text{cost}} \cdot \frac{p_j^{\text{dis}}(t)}{\eta_{\text{dis}}} \cdot \Delta t \right)$
- **Logic:** The marginal cost c_j^{cost} increases as j increases (deeper discharge), e.g., $c_1 < c_2 < \dots < c_J$. The optimizer will naturally prefer to discharge from the "cheapest" (shallowest) available segment first, perfectly modeling the non-linear cost of deep discharges in a linear framework.

3.2.1 Calculation of the the Marginal Cost for Each SOC Segment c_j^{cost}

The marginal cost for discharging from each SOC segment is derived from the BESS's total investment cost and its expected lifetime. To ensure the model is physically-grounded and traceable, the parameters have been re-evaluated based on LFP-specific data and the competition's economic specifications. The cost is distributed non-linearly based on a standard power-law model for LFP battery degradation. (Details refer to 'doc2_{model}cost_{aging.tex}')

Step 1: Re-evaluating the Cycle Life Parameter (a) The relationship between cycle life and Depth of Discharge (DoD) is described by the power-law model $\text{CycleLife}(D) = a \cdot D^{-b}$, where $b = 2$ is a behaviorally superior choice for an EMS as it strongly penalizes deep discharges. The parameter a (cycle life at 100% DoD) is derived from the LFP-specific commercial claim of 6,000 cycles at 80% DoD:

$$a = \text{CycleLife}(0.8) \times (0.8)^{-b} = 6000 \times (0.8)^{-2} = 3840 \text{ cycles}$$

This provides a traceable, LFP-specific value for the cycle life at 100% DoD.

Step 2: Recalculating the Cost per Full Cycle The total BESS investment is $4472 \text{ kWh} \times 200 \text{ EUR/kWh} = 894,400 \text{ EUR}$. Amortizing this over the re-evaluated lifetime gives the new cost per full (100% DoD) cycle:

$$\text{Cost per Full Cycle} = \frac{894,400 \text{ EUR}}{3840 \text{ cycles}} \approx 232.92 \text{ EUR/Cycle}$$

Step 3: Calculate Final Marginal Costs The marginal aging weights w_j for each of the 10 segments are derived from the power-law model ($w_j \propto D_j^2 - D_{j-1}^2$) and are self-normalizing. The marginal cost for discharging 1 kWh from segment j is then:

$$c_j^{\text{cost}} = \frac{\text{Cost per Full Cycle} \times w_j}{E_{\text{nom}} \times \text{Segment Size}}$$

For example, for the first and shallowest segment ($j = 1$), the marginal cost is:

$$c_1^{\text{cost}} = \frac{232.92 \text{ EUR/Cycle} \times 0.01}{4472 \text{ kWh} \times 0.1} \approx 0.0052 \text{ EUR/kWh}$$

The resulting costs for all segments are detailed in Table ??.

Table 1: Re-parameterized Marginal Cyclic Aging Costs (c_j^{cost}) for LFP

Segment (j)	SOC Range	Multiplier (w_j)	Marginal Cost (c_j^{cost}) [EUR/kWh]
1	90-100%	0.01	0.0052
2	80-90%	0.03	0.0156
3	70-80%	0.05	0.0260
4	60-70%	0.07	0.0364
5	50-60%	0.09	0.0469
6	40-50%	0.11	0.0573
7	30-40%	0.13	0.0677
8	20-30%	0.15	0.0781
9	10-20%	0.17	0.0885
10	0-10%	0.19	0.0990

This approach ensures that the sum of costs incurred by discharging all 10 segments equals exactly one "Cost per Full Cycle" (€232.92), making the model economically consistent and physically traceable.

3.3 Model (iii): Model (ii) + Calendar Aging Cost

Based on Collath et al. (2023), calendar aging is a non-linear function of the average State of Charge (SOC). We linearize this cost using Special Ordered Sets of Type 2 (SOS2), a standard MILP technique.

- **New Variables:** $\lambda_{t,i}$ (weighting variables for linearization).
- **Cost Function:** $C^{\text{cal}} = \sum_{t \in T} c_{\text{cost}}^{\text{cal}}(t)$
- **Logic:** The total SOC $e_{\text{soc}}(t)$ and its corresponding cost $c_{\text{cost}}^{\text{cal}}(t)$ are expressed as a convex combination of I pre-calculated (SOC, Cost) breakpoints from the literature's non-linear curve.

$$e_{\text{soc}}(t) = \sum_{i \in I} \lambda_{t,i} \cdot \text{SOC}_i^{\text{point}} \quad | \quad c_{\text{cost}}^{\text{cal}}(t) = \sum_{i \in I} \lambda_{t,i} \cdot \text{Cost}_i^{\text{point}}$$

$$\sum_{i \in I} \lambda_{t,i} = 1 \quad | \quad \{\lambda_{t,i}\} \text{ are SOS2 variables}$$

This formulation directly penalizes holding the battery at high SOC, as prioritized in the project description.

3.3.1 Calculation of the Calendar Aging Breakpoints

The breakpoints for the SOS2 linearization are derived from the "scaled" model presented in Collath et al. (2023), specifically from Figure 3. This approach uses a fixed linearization point (representing a mid-life aging state) for the entire BESS lifetime to better optimize for Net Present Value (NPV). The costs are monetized using the project's BESS investment cost.

Step 1: Extract Physical Degradation Data We extract data from the linearized calendar degradation model in Collath et al. (2023, Fig. 3), using the "scaled" curve for a past calendar capacity loss of $Q_{\text{loss,cal}} = 5\%$. This provides the physical relationship between SOC and the rate of capacity loss. We select five key breakpoints:

- SOC 0%: $\approx 0.00005\%$ capacity loss per 15 min
- SOC 25%: $\approx 0.00006\%$ capacity loss per 15 min
- SOC 50%: $\approx 0.00010\%$ capacity loss per 15 min
- SOC 75%: $\approx 0.00018\%$ capacity loss per 15 min
- SOC 100%: $\approx 0.00030\%$ capacity loss per 15 min

Step 2: Monetize the Degradation Cost The physical capacity loss is converted into an hourly economic cost. The total BESS investment is $4472 \text{ kWh} \times 200 \text{ EUR/kWh} = 894,400 \text{ EUR}$. The hourly cost at each breakpoint is calculated by converting the 15-minute loss rate to an hourly rate.

$$\text{Hourly Cost} = \text{Total Investment} \times (\text{15-min Loss Rate} \times 4)$$

For example, for the 100% SOC breakpoint:

$$\text{Cost}_{100\%} = 894,400 \text{ EUR} \times (0.00030\% \times 4) \approx 10.73 \text{ EUR/hr}$$

Step 3: Define Final Breakpoint Parameters The calculated (SOC, Cost) pairs form the breakpoints for the SOS2 constraints. These values provide the concrete parameters for the model, ensuring it accurately penalizes holding the battery at high states of charge. The resulting parameters are detailed in Table ??.

These values provide the concrete parameters for the SOS2 constraints, ensuring the model accurately penalizes holding the battery at high states of charge.

Table 2: Calculation of Calendar Aging Breakpoints ($SOC_i^{\text{point}}, Cost_i^{\text{point}}$)

Breakpoint (i)	SOC Level	SOC (SOC_i^{point}) [kWh]	Cost ($Cost_i^{\text{point}}$) [EUR/hr]
1	0%	0	1.79
2	25%	1118	2.15
3	50%	2236	3.58
4	75%	3354	6.44
5	100%	4472	10.73

4 Phase II - Model (iii) Mathematical Formulation

4.1 Objective Function

The objective is to maximize the total profit, defined as market revenues minus degradation costs.

$$\max Z = \mathbb{P}^{DA} + \mathbb{P}^{ANCI} + \mathbb{P}^{aFRR-E} - \alpha \cdot (C^{\text{cyc}} + C^{\text{cal}}) \quad (31)$$

Where:

$$\mathbb{P}^{DA} = \sum_{t \in T} \left(\frac{P_{DA}(t)}{1000} p_{\text{dis}}(t) - \frac{P_{DA}(t)}{1000} p_{\text{ch}}(t) \right) \Delta t \quad (32)$$

$$\mathbb{P}^{ANCI} = \sum_{b \in B} \left(P_{FCR}(b) c_{fcr}(b) + P_{aFRR}^{\text{pos}}(b) c_{aFRR}^{\text{pos}}(b) + P_{aFRR}^{\text{neg}}(b) c_{aFRR}^{\text{neg}}(b) \right) \Delta b \quad (33)$$

$$\mathbb{P}^{aFRR-E} = \sum_{t \in T} \left(\frac{P_{aFRR,E}^{\text{pos}}(t)}{1000} p_{aFRR,E}^{\text{pos}}(t) - \frac{P_{aFRR,E}^{\text{neg}}(t)}{1000} p_{aFRR,E}^{\text{neg}}(t) \right) \Delta t \quad (34)$$

$$C^{\text{cyc}} = \sum_{t \in T} \sum_{j \in J} \left(c_j^{\text{cost}} \cdot \frac{p_j^{\text{dis}}(t)}{\eta_{\text{dis}}} \cdot \Delta t \right) \quad (35)$$

$$C^{\text{cal}} = \sum_{t \in T} c_{\text{cost}}^{\text{cal}}(t) \cdot \Delta t \quad (36)$$

4.2 Constraints

4.2.1 Degradation-Aware SOC Dynamics (Replaces Cst-1)

$$e_{\text{soc},j}(t) = e_{\text{soc},j}(t-1) + \left(p_j^{\text{ch}}(t) \eta_{\text{ch}} - \frac{p_j^{\text{dis}}(t)}{\eta_{\text{dis}}} \right) \Delta t \quad \forall t, \forall j \quad (37)$$

$$e_{\text{soc}}(t) = \sum_{j \in J} e_{\text{soc},j}(t) \quad \forall t \quad (38)$$

$$p_{\text{ch}}^{\text{total}}(t) = \sum_{j \in J} p_j^{\text{ch}}(t) \quad \forall t \quad (39)$$

$$p_{\text{dis}}^{\text{total}}(t) = \sum_{j \in J} p_j^{\text{dis}}(t) \quad \forall t \quad (40)$$

$$p_{\text{ch}}^{\text{total}}(t) = p_{\text{ch}}(t) + p_{aFRR,E}^{\text{neg}}(t) \quad \forall t \quad (41)$$

$$p_{\text{dis}}^{\text{total}}(t) = p_{\text{dis}}(t) + p_{aFRR,E}^{\text{pos}}(t) \quad \forall t \quad (42)$$

4.2.2 SOC & Segment Limits (Replaces Cst-2)

$$SOC_{\min} E_{\text{nom}} \leq e_{\text{soc}}(t) \leq SOC_{\max} E_{\text{nom}} \quad \forall t \quad (43)$$

$$0 \leq e_{\text{soc},j}(t) \leq E_j^{\text{seg}} \quad \forall t, \forall j \quad (44)$$

4.2.3 Simultaneous Operation Prevention (Replaces Cst-3)

$$p_{\text{ch}}^{\text{total}}(t) \leq y_{\text{ch}}^{\text{total}}(t) \cdot P_{\max}^{\text{config}} \quad \forall t \quad (45)$$

$$p_{\text{dis}}^{\text{total}}(t) \leq y_{\text{dis}}^{\text{total}}(t) \cdot P_{\max}^{\text{config}} \quad \forall t \quad (46)$$

$$y_{\text{ch}}^{\text{total}}(t) + y_{\text{dis}}^{\text{total}}(t) \leq 1 \quad \forall t \quad (47)$$

4.2.4 Market Co-optimization Power Limits (Replaces Cst-4)

$$p_{\text{dis}}^{\text{total}}(t) + 1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{pos}}(b) \leq P_{\max}^{\text{config}} \quad \forall b, t \in b \quad (48)$$

$$p_{\text{ch}}^{\text{total}}(t) + 1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{neg}}(b) \leq P_{\max}^{\text{config}} \quad \forall b, t \in b \quad (49)$$

4.2.5 Ancillary Service Energy Reserve (Keeps Cst-6 Logic)

$$\frac{(1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{pos}}(b)) \tau}{\eta_{\text{dis}}} \leq e_{\text{soc}}(t) - SOC_{\min} E_{\text{nom}} \quad \forall b, t \in b \quad (50)$$

$$(1000 c_{fcr}(b) + 1000 c_{aFRR}^{\text{neg}}(b)) \tau \eta_{\text{ch}} \leq SOC_{\max} E_{\text{nom}} - e_{\text{soc}}(t) \quad \forall b, t \in b \quad (51)$$

(Where τ is the reserve duration, e.g., 0.25h)

4.2.6 Ancillary Capacity Market Exclusivity (Keeps Cst-7)

$$y_{fcr}(b) + y_{aFRR}^{\text{pos}}(b) + y_{aFRR}^{\text{neg}}(b) \leq 1 \quad \forall b \quad (52)$$

4.2.7 Cross-Market Mutual Exclusivity (Replaces Cst-8)

$$y_{\text{ch}}^{\text{total}}(t) + y_{fcr}(b) + y_{aFRR}^{\text{pos}}(b) \leq 1 \quad \forall b, t \in b \quad (53)$$

$$y_{\text{dis}}^{\text{total}}(t) + y_{fcr}(b) + y_{aFRR}^{\text{neg}}(b) \leq 1 \quad \forall b, t \in b \quad (54)$$

4.2.8 Minimum Bids & Binary Logic (Updates Cst-9)

$$y_{\text{ch}}(t) \text{MinBid}_{da} \cdot 1000 \leq p_{\text{ch}}(t) \leq y_{\text{ch}}(t) P_{\max}^{\text{config}} \quad \forall t \quad (55)$$

$$y_{\text{dis}}(t) \text{MinBid}_{da} \cdot 1000 \leq p_{\text{dis}}(t) \leq y_{\text{dis}}(t) P_{\max}^{\text{config}} \quad \forall t \quad (56)$$

$$y_{aFRR,E}^{\text{pos}}(t) \text{MinBid}_{afrr_e} \cdot 1000 \leq p_{aFRR,E}^{\text{pos}}(t) \leq y_{aFRR,E}^{\text{pos}}(t) P_{\max}^{\text{config}} \quad \forall t \quad (57)$$

$$y_{aFRR,E}^{\text{neg}}(t) \text{MinBid}_{afrr_e} \cdot 1000 \leq p_{aFRR,E}^{\text{neg}}(t) \leq y_{aFRR,E}^{\text{neg}}(t) P_{\max}^{\text{config}} \quad \forall t \quad (58)$$

$$y_{\text{ch}}^{\text{total}}(t) \geq y_{\text{ch}}(t); \quad y_{\text{ch}}^{\text{total}}(t) \geq y_{aFRR,E}^{\text{neg}}(t) \quad \forall t \quad (59)$$

$$y_{\text{dis}}^{\text{total}}(t) \geq y_{\text{dis}}(t); \quad y_{\text{dis}}^{\text{total}}(t) \geq y_{aFRR,E}^{\text{pos}}(t) \quad \forall t \quad (60)$$

(Similar min/max bid constraints for c_{fcr} , c_{aFRR}^{pos} , c_{aFRR}^{neg} remain from Phase I)

4.2.9 Calendar Aging PWL Constraints (New)

$$e_{\text{soc}}(t) = \sum_{i \in I} \lambda_{t,i} \cdot \text{SOC}_i^{\text{point}} \quad \forall t \quad (61)$$

$$c_{\text{cost}}^{\text{cal}}(t) = \sum_{i \in I} \lambda_{t,i} \cdot \text{Cost}_i^{\text{point}} \quad \forall t \quad (62)$$

$$\sum_{i \in I} \lambda_{t,i} = 1 \quad \forall t \quad (63)$$

$$\{\lambda_{t,i}\}_{i \in I} \text{ are SOS2 variables} \quad \forall t \quad (64)$$

4.3 Validation Needed: Explicit Cascading Constraints (Physical Rule)

To eliminate any ambiguity from the economic incentive model, we can introduce a set of explicit physical constraints to strictly enforce the 'Last-In, First-Out' (LIFO) behavior of the battery segments. While this approach increases model complexity, it ensures that the model's behavior aligns perfectly with physical reality under all conditions. This requires introducing two new sets of binary decision variables.

4.3.1 New Binary Variables for Cascading Logic

Symbol	Description	Type
$u_j^{\text{empty}}(t)$	(New) 1 if segment j is empty at time t , 0 otherwise	Binary
$u_j^{\text{full}}(t)$	(New) 1 if segment j is full at time t , 0 otherwise	Binary

We also introduce a new parameter M , which is a sufficiently large constant (typically set to $P_{\text{max}}^{\text{config}}$), for use in the "Big-M" constraints.

4.3.2 New Constraints

1. Linking Constraints for Binary Variables First, we must link the new binary variables to the segment's state of charge, $e_{\text{soc},j}(t)$.

If a segment's energy $e_{\text{soc},j}(t)$ is 0, then $u_j^{\text{empty}}(t)$ must be 1:

$$e_{\text{soc},j}(t) \leq E_j^{\text{seg}} \cdot (1 - u_j^{\text{empty}}(t)) \quad \forall t, \forall j \quad (65)$$

(If u_j^{empty} is 1, the right-hand side becomes 0, forcing $e_{\text{soc},j}$ to be 0.)

If a segment's energy $e_{\text{soc},j}(t)$ reaches its capacity E_j^{seg} , then $u_j^{\text{full}}(t)$ must be 1:

$$e_{\text{soc},j}(t) \geq E_j^{\text{seg}} \cdot u_j^{\text{full}}(t) \quad \forall t, \forall j \quad (66)$$

(Only when $e_{\text{soc},j}$ is full (equal to E_j^{seg}) can u_j^{full} be 1.)

2. Cascading Discharge Constraint This constraint dictates that: *discharging from segment j is only permitted if the adjacent shallower segment $j - 1$ is empty.*

$$p_j^{\text{dis}}(t) \leq M \cdot u_{j-1}^{\text{empty}}(t) \quad \forall t, \forall j > 1 \quad (67)$$

(This means: power p_j^{dis} can only be drawn from segment j if segment $j - 1$ is empty ($u_{j-1}^{\text{empty}} = 1$).)

3. Cascading Charge Constraint This constraint dictates that: *charging into segment j is only permitted if the adjacent deeper segment $j + 1$ is full.*

$$p_j^{\text{ch}}(t) \leq M \cdot u_{j+1}^{\text{full}}(t) \quad \forall t, \forall j < J \quad (68)$$

(This means: power p_j^{ch} can only be sent to segment j if segment $j + 1$ is full ($u_{j+1}^{\text{full}} = 1$).)

5 Implementation Strategy: Meta-Optimization & Rolling Horizon

The mathematical formulation above defines the "inner-loop" optimization. However, two external challenges must be solved to meet the competition's goals: **(1)** computational infeasibility of a full-year MILP solve, and **(2)** the need to select the "correct" trade-off between profit and degradation.

We address both with a "meta-optimization" strategy, which defines *how* we use the MILP model.

5.1 Addressing Computational Feasibility: Rolling Horizon (MPC)

The full-year model ($T=35,040$) is computationally intractable for open-source solvers. We will implement a **Rolling Horizon (or Model Predictive Control, MPC)** approach, as demonstrated in the literature (Collath et al., 2023).

The implementation will be a simulation loop:

1. **Initialize:** Set $t = 1$, $e_{\text{soc},j}(0) = e_{\text{soc},j}^{\text{init}}$.
2. **Loop (for $d = 1$ to 365):**
 - **Solve:** Run the MILP defined in Section 3 for a short horizon, T_{horizon} (e.g., 24-48 hours), starting from the current SOC $e_{\text{soc},j}(t - 1)$.
 - **Execute:** Record the optimal bids and actions $p(t), c(b)$ for the first "execution" block (e.g., first 1 or 4 hours).
 - **Update:** Calculate the new $e_{\text{soc},j}$ at the end of the execution block. Set t to the next time step.
3. **Aggregate:** Sum the profits and degradation from all 365 solves to get the total annual result.

This makes the problem computationally feasible.

5.2 Addressing the Bi-Objective Problem: The α Meta-Parameter

The competition requires balancing two objectives: Revenue (30% weight) and Degradation (30% weight). Our objective function, $\max \mathbb{P} - \alpha \cdot C^{\text{Degradation}}$, is a standard **Weighted Sum** method for solving this bi-objective problem.

The parameter α (the "degradation price") is the tuning knob that traces the Pareto frontier.

- If $\alpha = 0$, we only maximize profit (short life, high revenue).
- If $\alpha \rightarrow \infty$, we only minimize degradation (long life, low revenue).

The "correct" α is the one that results in the highest 10-Year ROI, as required by the "Investment Optimization" task. We will find this optimal α using a **meta-optimization loop** (a simple parameter sweep).

5.2.1 Meta-Optimization Algorithm:

1. **Outer-Loop (Parameter Sweep):** For α in $[0.1, 0.2, 0.3, \dots, 3.0]$:
 - **Inner-Loop (Simulation):** Run the full 365-day **Rolling Horizon (MPC)** simulation using this value of α .
 - **Record:** Store the resulting total annual profit $\mathbb{P}(\alpha)$ and total annual SOH loss $\Delta SOH(\alpha)$.
 - **Project:** Calculate the 10-Year ROI for this α , factoring in the SOH loss (which determines battery replacement, if any).
2. **Select:** Choose the α^* that produced the **maximum 10-Year ROI**.
3. **Final Run:** Run the simulation one last time with α^* to generate the final bidding files.

This meta-optimization strategy directly links our MILP model to the competition’s final evaluation criteria (10-year ROI) and correctly implements the bi-objective optimization you identified.

6 Conclusion and Next Steps

This Phase II formulation successfully integrates the aFRR energy market and a sophisticated, linearized degradation cost model into the Phase I MILP. The implementation strategy (MPC) ensures computational feasibility, while the meta-optimization of α ensures we find the optimal balance between profit and degradation to maximize the 10-year ROI.

References

- [1] B. Xu, J. Zhao, T. Zheng, E. Litvinov, and D. S. Kirschen. (2017). "Factoring the Cycle Aging Cost of Batteries Participating in Electricity Markets." *arXiv:1707.04567v2*.
- [2] N. Collath, M. Cornejo, V. Engwerth, H. Hesse, and A. Jossen. (2023). "Increasing the lifetime profitability of battery energy storage systems through aging aware operation." *Applied Energy*, 348, 121531.
- [3] Gen Li. (2025). "Huawei TechArena 2025: BESS Energy Management System." *Internal Project Document*.