SV-603-03 Software High Level Design

Portview

Software High Level Design

Report no. : SV-603-03

Rev. : 1.6

By	Title	Name	Sign
Prepared	Manager	J. W. Lee	
	Staff	J. B. Kim	
	General Manager	S. I. Choi	
Reviewed	Manager	M. C. Boo	
Approved	CTO (Director)	K. Y. Ro	

GENORAY Co., Ltd.

Revision History

Rev#	Description	Date	Remark
0.0	Initial Version	2012.07.02	
0.1	User Interface Update	2015.01.12	
0.2	New Function Implemented	2016.01.19	
0.3	System Issue	2017.01.13	
0.4	New Device Added	2018.01.12	
0.5	Device Compatibility	2019.01.21	
0.6	Device Compatibility	2020.01.30	
0.7	GUI update	2020.10.08	
0.8	Linkage usability improve	2021.02.26	
0.9	Program Issue	2021.09.10	
1.0	Device Compatibility	2021.10.08	
1.1	Connection status improve	2022.03.04	
1.2	Increasing image capacity	2023.01.04	
1.3	Device Compatibility	2023.04.21	
1.4	Device Compatibility	2024.01.08	
1.5	Document number changed from 603 to Z01 according to OP-709	2024.01.16	
1.6	Added description and revised architecture content	2025.08.14	

Table of Contents

1. Purpose 4
2. Scope 4
4. Safety Classification Framework 5
5. Portview Software Decomposition 5
6. Software Item Details And Risk Links 6
7. Traceability To Requirements And Design 6
8. Platform And Common Architecture 7
    8.1 Hardware Platform And Operating System 7
    8.2 Interface Relationships 7
    8.3 Architecture View 8
9. SOUP And OTS Assessment 8
    9.1 Development Environment SOUP 8
    9.2 Operating System OTS 9
10. Portview Architecture Controls 9
    10.1 UI 9
    10.2 Security 9
    10.3 Data Integrity 10

1. Purpose

This document presents the decomposition of Portview into software items and units and explains how design inputs are mapped into the high-level software structure and interfaces.

The document is intended to:

- define the high-level Portview software structure
- describe software-unit safety classification and interface relationships
- document platform, SOUP, and OTS assumptions
- provide architecture-level traceability to requirements and design documents

2. Scope

This high-level design covers the Portview PC application, including its principal software units, platform requirements, external interfaces, and architecture-level design constraints.

In scope:

- Portview software decomposition and software-unit descriptions
- software safety classification context
- requirement/document traceability at architecture level
- hardware platform and operating-system assumptions
- Portview architecture, interfaces, security, and data-integrity principles

3. Referenced Documents

The following references support the high-level design.

Reference	Use
`SV-603-01` Software Validation Report	Validation basis and release conclusion
`SV-603-02` Software Development Planning	Lifecycle and configuration-management context
`SV-603-04` Software Verification Plan	Verification planning and procedure references
`SV-603-05` Software Verification Report	Verification execution results
`RS-603` RS for Portview	System-level requirement input

Reference	Use
`CSRS-603` SwRS for Cybersecurity	Cybersecurity design input
`SRS-603` SwSRS for Portview	Software requirement input
`SDS-603` SwSDS for Portview	Lower-level design reference
`TM-603` Traceability Matrix	Requirement and design traceability reference

4. Safety Classification Framework

The software safety classification scheme follows IEC 62304, with severity levels mapped to software safety classes.

Severity Of Harm Class	Meaning	IEC 62304 Software Safety Class
`1`	No injury or damage to health is possible	`A`
`2`	Non-serious injury is possible	`B`
`3`, `4`, `5`	Death or serious injury is possible	`C`

Within the current Portview scope, the documented unit classifications indicate Class `A` and Class `B` items. Class `B` applies where delayed diagnosis or other non-serious injury scenarios remain possible.

5. Portview Software Decomposition

Portview is the parent software item in the current document scope. The high-level unit structure is organized so that patient workflow, device communication, image display, and export functions remain separated into distinct units with defined responsibilities.

The decomposition follows these principles:

- each software unit inherits its safety-classification context from the parent structure unless a lower classification is justified by reduced severity of harm
- device communication is mediated through a dedicated service layer rather than direct UI-to-device coupling
- patient data and image data are handled as controlled information objects that must remain attributable and recoverable

- export behavior is separated from viewing and acquisition logic so that downstream file-format handling remains isolated from image display workflows

Parent Software Item	Portview Unit
Portview	Patient Management
Portview	Device Service
Portview	Image Viewer
Portview	Exportation Service



6. Software Item Details And Risk Links

The Portview software units and their classification and risk context are summarized below. Risk references are aligned to the normalized `FR-xxx` identifiers defined in `PV-FMEA-01`.

Unit Title	Class	Risk ID / Severity	Description
Patient Management	`A`	`FR-014 / 1`, `FR-015 / 1`, `FR-016 / 1`, `FR-017 / 1`	Patient registration, search, load, and reopen behavior is limited to no-injury workflow failures in the current scope
Device Service	`A`, `B`	`FR-012 / 1`, `FR-018 / 2`	Device detection, driver support, and acquisition availability include both no-harm and non-serious-injury contexts

Unit Title	Class	Risk ID / Severity	Description
Image Viewer	`A`	`FR-001 / 1`, `FR-002 / 1`, `FR-004 / 1`, `FR-013 / 1`	Viewer availability, audit support, and annotation-display behavior remain in the no-injury class in the current scope
Exportation Service	`A`, `B`	`FR-006 / 2`, `FR-008 / 1`, `FR-009 / 1`, `FR-010 / 1`, `FR-011 / 1`	Output, exchange, and external communication functions include confidentiality and interoperability risks

7. Traceability To Requirements And Design

The high-level design maintains architecture-level traceability from Portview units to controlled requirement and design documents.

Unit	Primary Requirement Reference	Primary Design Reference
Portview software units	`SRS-603` SwSRS for Portview	`SDS-603` SwSDS for Portview
System-level architecture context	`RS-603` RS for Portview	This high-level design document
Cybersecurity-related design input	SwRS for Cybersecurity	Security-related architecture sections

8. Platform And Common Architecture

8.1 Hardware Platform And Operating System

Part	Specification
OS	Windows 10 or higher (32-bit or 64-bit)
CPU	Core Duo / Core2 Processor
RAM	4 GB or higher

Part	Specification
Storage	100 GB free space or more
Ethernet	100/1000 Mbps Ethernet
VGA	Onboard chipset or higher
ODD	DVD Multi
Monitor	1280 x 1024 resolution or higher
Keyboard	103/106 key
Mouse	Optical mouse

8.2 Interface Relationships

Portview is designed around controlled data exchange between units rather than direct shared-function coupling. The principal interface relationships are summarized below.

Interface	Description
Device Service -> Image Viewer	Acquired image data is transferred to the display workflow after modality communication is completed
Patient Management -> Image Viewer	The selected patient context determines which image set is loaded and displayed
Patient Management -> Data Store	Patient demographic and registration data is stored and retrieved through the local data structure
Image Viewer -> Data Store	Displayed images and related metadata are retrieved from and committed to the controlled data set
Image Viewer -> Exportation Service	The requested export action is handed off to the export workflow after user selection
Exportation Service -> External data formats	Images are converted and written to DICOM files, TWAIN data, image files, or database-related outputs

8.3 Architecture View

The architecture is centered on a workstation application in which the user-facing image workflow, device communication, persistence layer, and export functions are separated but coordinated.



9. SOUP And OTS Assessment

9.1 Development Environment SOUP

Item	Value
Program language	`C++`
OTS software	`Microsoft Visual C++`
Version	`2017 Professional Edition`

The coding environment is treated as a generally used OTS development tool and is governed through the applicable quality procedures.

9.2 Operating System OTS

Item	Value
OTS software	`Windows`
Manufacturer	`Microsoft`
Version basis	`Windows 10` with platform support defined as Windows 10 or higher

The operating system supports memory allocation, storage-device management, and input/output handling for the workstation platform. The risk associated with this OTS software is treated as minor in the current design context because the worst credible harm is inconvenience or diagnostic delay.

10. Portview Architecture Controls

10.1 UI

The Portview user interface is intended to support a multi-language environment and to present acquisition, patient-management, image-viewing, and export workflows in a single operator-facing application.

UI expectations include:

- multiple-language support
- direct access to patient selection and image review workflows
- consistent presentation of acquisition, display, annotation, and export actions

10.2 Security

External network access is limited to the minimum interfaces required for intended operation:

- DICOM data services for transmitting and receiving images
- transmitting and receiving control commands between the device and the workstation

Security-oriented design expectations include:

- limiting external connectivity to approved operational interfaces
- preventing uncontrolled modification of the workstation software environment
- preserving the integrity of patient and image data during transfer and storage

10.3 Data Integrity

The basic data set consists of images and patient information. These data are treated as significant assets that must not be mixed, corrupted, misattributed, or lost.

Data-integrity design principles include:

- patient data and image data remain associated through controlled identifiers
- stored data must remain recoverable after routine workflow operations
- export functions must preserve data attribution and output consistency
- architecture decisions should avoid unintended overwrite or cross-patient data mixing

Data Field	Description
ID	Chart ID
Name	Patient name

Data Field	Description
Sex	Patient sex
Birth	Patient birthdate
SSN	Patient social security number
Phone	Patient phone number
Email	Patient email