

Description of above mention PFD

- As calculated by Daniella with assuming alkalinity as 60 ppm.
- The quantity of acid required to be produced will be **77 Kg/hr** (pure) HCl.
HCl will be used in **scrubber + reducing RO water pH**
- Requirement for acid for scrubbing was not considered by us previously.
- We have quoted 56 Kg/hr (pure) HCl in our quotation for the BPED.
- With the HV BPED calculator the number of cell pairs to achieve increase acid production from **56 Kg/hr** to **77 Kg/hr** number of CP's will increase by **~25 - 40%**.
- Note: The quantity of acid required depends highly on alkalinity of water.