



CHAPTER

Shutdown, storage and disposal

IN THIS CHAPTER

20.1	Short shutdown	132
20.2	Long-term storage	133
20.3	Restarting after storage	134
20.4	Disposal and recycling	135

20.1 Short shutdown

Use **Controlled Shutdown** (Mode 4) from the Mode Control HMI screen (chapter 6) rather than simply removing power, so pumps and valves stop in a defined sequence. If the unit is to be fully powered down (as opposed to left in Controlled Shutdown/standby), isolate at the incoming-supply breakers (main isolator, MCBs, RCDs) per the unit's own electrical schematic (chapter 14).

20.2 Long-term storage

No storage/preservation procedure specific to the whole SalinBloc™ unit was found. Where the optional pretreatment container is fitted (chapter 8), the UF membrane manufacturer's preservation procedure is the best-documented reference available for that stage: soak the UF module in a glycerol/sodium-metabisulfite preservation solution before an extended shutdown, and flush with $\geq 14 \text{ m}^3$ of feed water for at least 4 hours before restart. TODO: no equivalent preservation guidance (membrane wetting, antifouling flush, dosing-system winterization) was found for the SonixED™ stack itself or the dosing system — for the dosing system, at minimum follow the chemical storage guidance in chapter 12 (15–25 °C, tightly closed original containers) for the duration of the shutdown.

20.3 Restarting after storage

Treat a restart after storage as a fresh commissioning (chapter 5).

20.4 Disposal and recycling

Component datasheets (e.g. dosing pumps, chapter 12) may carry manufacturer disposal notes; dispose of dosing chemicals per their Safety Data Sheets (section 2.4) and local regulations.

