
Exhibit Hall Level 4ABC Electrical Power Specifications



Platform B	4 EA 100 AMP 120/208V 1 EA 200 AMP 120/208V 1 EA 100 AMP 480V	Platform H	4 EA 100 AMP 1 EA 200 AMP 1 EA 100 AMP	120/208V	
Platform C	4 EA 100 AMP 120/208V 1 EA 200 AMP 208V 1 EA 100 AMP 480V	Platform J	4 EA 100 AMP 1 EA 200 AMP		
Platform D	4 EA 100 AMP 120/208V 1 EA 200 AMP 120/208V 1 EA 100 AMP 480V	Exhibit Hall 4A W Exhibit Hall 4B W Exhibit Hall 4C W	all Power	10 ea 100 10 ea 100 3 ea 100 1 ea 100	AMP AMP AMP
Platform F	4.EA 100 AMP 120/208V	South Lobby		1 ea 60	AMP
i lattoriii i	1 EA 200 AMP 120/208V	Exhibit Hall 4A Fl Exhibit Hall 4B Fl Exhibit Hall 4C Fl	oor Boxes So.	2 ea 100 2 ea 100 2 ea 100	AMP AMP AMP
Platform G	4 EA 100 AMP 120/208V 1 EA 200 AMP 120/208V 1 EA 100 AMP 480V	All platforms are I Bailroom (level 4)	ocated on catwall		

All power is three phase 208/120 volt or 480/277 volt.

Exhibit Hall Level 4E & F Electrical Power Specifications





Exhibit Hall Level 6 Electrical Power Specifications



Platform M	2 EA 100 AMP 120/208V
	1 EA 200 AMP 120/208V

1 EA 100 AMP 480V

Platform N 5 EA 100 AMP 120/208V or 1 EA 200 AMP 480V

4 EA 100 AMP 120/208V Platform R 2 EA 100 AMP 480V

All platforms are located on catwalks (level 7) above ballroom (level 6).

All power is three phase 120/208 volt. 480/277 volt.

Ballroom 6A (Wall Power)	4 EA 100 AMP
Ballroom 6B (Wall Power)	2 EA 100 AMP
Ballroom 6C (Wall Power)	5 EA 100 AMP
Ballroom 6E (Wall Power)	8 EA 100 AMP
Meeting Room 604 Meeting Room 606 & 607 Meeting Room 608 & 609 Meeting Room 611 & 613 Meeting Room 615 Meeting Room 616 Meeting Room 617	1 EA 60 AMP 2 EA 60 AMP 2 EA 60 AMP 1 EA 60 AMP 1 EA 60 AMP 1 EA 60 AMP 1 EA 60 AMP
Meeting Room 618 Meeting Room 619	1 EA 60 AMP 1 EA 60 AMP
Meeting Room 620	1 EA 60 AMP