SLA-C · DataCenter Monterrey, colocation

Infrastructure

Two 42U racks with redundant power A+B, UPS, and generator with 48 hours of diesel autonomy.

Physical Access

Physical access requires prior registration in the provider's portal with 24 hours advance notice; for emergencies, the on-call manager may authorize via phone.

Commitments

99.98 % energy availability. Cold aisle temperature between 18 and 27 degrees. On-site technician with 15 minute response time for remote hands.