

Offline settings

Online settings

General

Hardware type

I/O settings

I/O names

Program password

Power on

Message text

Additional info

Statistics

Comment

value range type

value in STOP mode

AQ1

0-20mA / 0-10V



0.00



AQ2

0-20mA / 0-10V



0.00



AQ3

0-20mA / 0-10V



0.00



AQ4

0-20mA / 0-10V



0.00



AQ5

0-20mA / 0-10V



0.00



AQ6

0-20mA / 0-10V



0.00



AQ7

0-20mA / 0-10V



0.00



AQ8

0-20mA / 0-10V



0.00



Onboard AI setting

If 4 AIs are supported on LOGO!, do you want to enable 2 AIs or 4 AIs?

To ensure compatibility with older devices, enable 2AIs.

☐ Enable 0 AIs

No AIs are available for your circuit program.

☐ Enable 2 AIs

Only AI1 and AI2 corresponding to input terminals I7 and I8 can be used in your circuit program.

☒ Enable 4 AIs

AI1 and AI2 corresponding to input terminals I7 and I8 are available for use in your circuit program.

Additionally, AI3 and AI4 corresponding to input terminals I1 and I2 are available for use.