Panel schedule — glass door sections

PROVISIONAL. Dimensions below are a representative medical-centre module set; they must be replaced by the measured door schedule and site photographs. Every panel is an independent print piece — the artwork engine is parametric, so changing a width or height re-flows type and crop automatically without distortion.

PANEL	DEPARTMENT	W X H (CM)	ORIENTATION / ASPECT	PHOTO ASSET	COVERAGE	HANDLE / STILE CLEARANCE	STATUS
P-01	RECEPTION	100 X 210	PORTRAIT SINGLE SWING DOOR	A-01	40% PHOTO	RIGHT-HAND LEVER/PULL HANDLE, 950–1120 MM	PROVISIONAL
P-02	RECEPTION	45 X 210	PORTRAIT FIXED SIDELIGHT	GRAPHIC	GRAPHIC ONLY	FRAME REBATE 18 MM ALL ROUND	PROVISIONAL
P-03	CONSULTATION	90 X 210	PORTRAIT SINGLE SWING DOOR	A-02	40% PHOTO	LEFT-HAND LEVER HANDLE, 980–1150 MM	PROVISIONAL
P-04	CONSULTATION	90 X 210	PORTRAIT SINGLE SWING DOOR	A-03	40% PHOTO	RIGHT-HAND LEVER HANDLE, 980–1150 MM	PROVISIONAL
P-05	LABORATORY	90 X 210	PORTRAIT SINGLE SWING DOOR	A-04	40% PHOTO	LEFT-HAND LEVER HANDLE, 980–1150 MM	PROVISIONAL
P-06	PHARMACY	100 X 210	PORTRAIT SINGLE SWING DOOR	A-05	40% PHOTO	RIGHT-HAND PULL HANDLE, 950–1120 MM	PROVISIONAL
P-07	IMAGING	120 X 210	PORTRAIT DOUBLE DOOR, 2 × 600 LEAVES	A-06	40% PHOTO	VERTICAL PULL HANDLES BOTH LEAVES, 900–1500 MM	PROVISIONAL
P-08	IMAGING	45 X 210	PORTRAIT FIXED SIDELIGHT	GRAPHIC	GRAPHIC ONLY	FRAME REBATE 18 MM ALL ROUND	PROVISIONAL

READING THE SCHEDULE

(1) Coverage = share of the panel given to photography. One-way vision film needs a substantial unprinted or dark field to preserve outward visibility; 36–46% photographic coverage is the working target for these doors. (2) Clearance figures assume the handle and meeting-stile positions noted per panel and must be verified on site. (3) All panels are portrait; no panel may be rotated or split to fit a stock sheet.

Panel detail — obstructions, crop logic and production notes

P-01 RECEPTION

100 X 210 CM · 1 : 2.10 · PHOTO BOTTOM 1250 MM

— Left-hand hinge set: 3 no. butt hinges
— Right-hand lever/pull handle, 950–1120 mm
— Overhead door closer, top 240 mm
— Floor clearance 8 mm

ASSET A-01 Cedric Fauntleroy

Photograph must knock out to navy at the bottom edge, not float.

P-02 RECEPTION

45 X 210 CM · 1 : 4.67 · PHOTO BOTTOM 1450 MM

— Fixed glazing; no hardware
— Frame rebate 18 mm all round
— Silicone joint at floor

ASSET No photography (graphic panel)

No joins through the vertical wordmark; single-piece plot required.

P-03 CONSULTATION

90 X 210 CM · 1 : 2.33 · PHOTO BOTTOM 1250 MM

— Right-hand hinge set
— Left-hand lever handle, 980–1150 mm
— Overhead closer

ASSET A-02 cottonbro studio

Doctor's face sits in the upper third; keep clear of the closer shadow.

P-04 CONSULTATION

90 X 210 CM · 1 : 2.33 · PHOTO BOTTOM 1250 MM

— Left-hand hinge set
— Right-hand lever handle, 980–1150 mm
— Overhead closer

ASSET A-03 Thirdman

Landscape source: crop keeps both figures inside the safe zone.

P-05 LABORATORY

90 X 210 CM · 1 : 2.33 · PHOTO BOTTOM 1250 MM

— Right-hand hinge set
— Left-hand lever handle, 980–1150 mm
— Overhead closer

ASSET A-04 Pavel Danilyuk

Lab-coat highlights must be held below 240 so they do not bloom under perforation.

P-06 PHARMACY

100 X 210 CM · 1 : 2.10 · PHOTO BOTTOM 1250 MM

— Left-hand hinge set
— Right-hand pull handle, 950–1120 mm
— Push plate to 1200 mm

ASSET A-05 cottonbro studio

Shelf repetition reads as texture through the perforation — crop keeps it soft.

P-07 IMAGING

120 X 210 CM · 1 : 1.75 · PHOTO BOTTOM 1250 MM

— Meeting stile at centre (600 mm)
— Vertical pull handles both leaves, 900–1500 mm
— Overhead closers both leaves
— Seam allowance ±3 mm per leaf

ASSET A-06 MART PRODUCTION

One artwork plotted, split at centreline. No text across the meeting stile.

P-08 IMAGING

45 X 210 CM · 1 : 4.67 · PHOTO BOTTOM 1450 MM

— Fixed glazing; no hardware
— Frame rebate 18 mm all round

ASSET No photography (graphic panel)

Pairs with P-07 and deliberately carries no photograph — the scanner image must not repeat across two adjacent panels.

Image source and licence log

Every photograph is a real, professionally shot stock image. No AI-generated imagery, synthetic people or composited medical scenes are used anywhere in this project. Licence status is recorded exactly as checked on the provider's page — see the terms note at the foot of this page and page 4 of the production specification.

ASSET	USED ON	PHOTOGRAPH	CREATOR / PROVIDER	LICENCE	ORIGINAL PX	CHECKED
A-01	P-01	A RECEPTIONIST SMILING AT A PERSON (RECEPTION DESK, TABLET)	CEDRIC FAUNTLEROY / PEXELS	PEXELS LICENCE	5474 X 8211	2026-10-28
A-02	P-03	DOCTOR SITTING BY TABLE WITH PATIENT	COTTONBRO STUDIO / PEXELS	PEXELS LICENCE	4189 X 6284	2026-10-28
A-03	P-04	MEDICAL PROFESSIONAL SITTING ON A CHAIR HOLDING A TABLET WHILE TALKING	THIRDMAN / PEXELS	PEXELS LICENCE	4231 X 6346	2026-10-28
A-04	P-05	WOMAN LAB TECHNICIAN EXAMINING SAMPLES WITH A TRINOCULAR MICROSCOPE	PAVEL DANILYUK / PEXELS	PEXELS LICENCE	5192 X 3466	2026-10-28
A-05	P-06	PHARMACISTS EXAMINING MEDICINE BOTTLES ON A PHARMACY SHELF	COTTONBRO STUDIO / PEXELS	PEXELS LICENCE	6403 X 4269	2026-10-28
A-06	P-07	MRI SCANNER IN A HOSPITAL IMAGING ROOM	MART PRODUCTION / PEXELS	PEXELS LICENCE	6000 X 4000	2026-10-28

LICENCE TERMS AS CHECKED (PEXELS, 2026-10-28)

Allowed: free use in commercial and non-commercial work, including print marketing material; modification and creative editing permitted; attribution not required (credited here as good practice).

Not allowed — and directly relevant here: selling unaltered copies; implying that the people or brands depicted endorse the client; using imagery as part of a trade mark. These panels are environmental wayfinding and must not caption any depicted person as named staff.

Resolution audit at final print size

Effective resolution is calculated from the ORIGINAL file dimensions of each stock asset against the final crop window — not from the 110 ppi web previews used to build these comps. Minimum accepted for large-format work at 1.2 m viewing distance is 120 ppi; 150 ppi is the preferred target. Files under the floor must be re-sourced or the crop tightened before output.

PANEL	ASSET	TRIM SIZE (MM)	CROP WINDOW PX	NEEDED @150 PPI	EFFECTIVE PPI	RESULT
P-01	A-01	1000 X 2100	5474 X 4653	5906 X 5020	139	PASS (ACCEPTABLE)
P-02	GRAPHIC	450 X 2100	VECTOR	VECTOR	—	PASS (VECTOR)
P-03	A-02	900 X 2100	4189 X 3956	5315 X 5020	118	PASS (ACCEPTABLE)
P-04	A-03	900 X 2100	4231 X 3996	5315 X 5020	119	PASS (ACCEPTABLE)
P-05	A-04	900 X 2100	3670 X 3466	5315 X 5020	104	FAIL — TIGHTEN CROP
P-06	A-05	1000 X 2100	5022 X 4269	5906 X 5020	128	PASS (ACCEPTABLE)
P-07	A-06	1200 X 2100	5647 X 4000	7087 X 5020	120	PASS (ACCEPTABLE)
P-08	GRAPHIC	450 X 2100	VECTOR	VECTOR	—	PASS (VECTOR)

Downloaded originals must be the full-resolution file from each asset page (the 'Free download' original, not the resized preview). Relink in the production document, replace the placed preview, and re-check the crop — the focus point is stored per panel so the framing reproduces exactly.