

SOLAR

0.20 = 0.60A
0.18 = 0.67A
0.15 = 0.80A
0.12 = 1.00A
0.08 = 1.50A
0.04 = 3.00A

BAT

LOAD

BATTERY

LOAD

Load disconnect at 11.65V
Load reconnect at 12.15V