

GOVERNMENT OF INDIA

Public Works Department - Electrical Division

NOTICE INVITING TENDER

SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF INTERNAL ELECTRIFICATION WORKS FOR THE ADMINISTRATIVE BLOCK

Tender Reference	EE/ELECT/2026-27/114
Issuing Authority	Office of the Executive Engineer (Electrical Division)
Mode of Tendering	Open e-Tender, two-bid system
Estimated Cost	Rs 1,42,50,000 (Rupees One Crore Forty Two Lakh Fifty Thousand)
Earnest Money Deposit	Rs 2,00,000
Bid Submission Closes	24 September 2026, 15:00 hrs
Technical Bid Opening	25 September 2026, 11:00 hrs

SECTION III - TECHNICAL SPECIFICATIONS

The following specifications are mandatory. Any deviation shall be explicitly listed in the deviation schedule of the technical bid.

3.1 GENERAL REQUIREMENTS

- 3.1.1 All electrical wiring installation work shall be carried out in accordance with the Code of Practice for Electrical Wiring Installations, IS 732, and the relevant statutory rules in force.
- 3.1.2 The entire installation shall be earthed in accordance with the Code of Practice for Earthing, IS 3043 - 1987.
- 3.1.3 Workmanship shall conform to the best modern practice. The contractor shall employ only licensed electricians for all terminations and jointing work.

3.2 CABLES AND CONDUCTORS

- 3.2.1 All internal wiring shall be carried out using PVC insulated copper conductor cables of 1100 V grade conforming to IS 694.
- 3.2.2 Heavy duty PVC insulated armoured cables for sub-mains distribution shall conform to IS 1554 (Part 1):1988 for working voltages up to and including 1100 V.
- 3.2.3 Cross-linked polyethylene insulated cables, where specified for outdoor feeder runs, shall conform to IS 7098 (Part 1).
- 3.2.4 The minimum cross sectional area of any conductor used for light points shall not be less than 1.5 sq mm copper.

3.3 CONDUITS AND ACCESSORIES

- 3.3.1 Rigid non-metallic conduits used for surface, recessed and concealed conduit wiring shall conform to IS 9537 (Part 3).

3.3.2 Fittings and accessories for rigid steel conduits shall conform to IS 3419.

3.4 SWITCHES, SOCKET OUTLETS AND PROTECTION

3.4.1 All switches for domestic and similar purposes shall conform to IS 3854.

3.4.2 Plugs and socket outlets of rated voltage up to and including 250 V shall conform to IS 1293.

3.4.3 Low voltage switchgear and controlgear assemblies (distribution boards) shall be factory built assemblies conforming to IS 8623 (Part 1).

3.4.4 Miniature circuit breakers shall provide overcurrent protection appropriate to the connected load and the conductor size.

3.5 LIGHTING

3.5.1 All luminaires shall be LED type. Self-ballasted LED lamps for general lighting services shall conform to IS 16102 (Part 1).

3.5.2 LED luminaires shall carry valid BIS registration under the applicable compulsory registration requirements.

3.5.3 Illumination levels for office areas shall comply with the national lighting code requirements for interior illumination.

3.6 TESTING AND COMMISSIONING

3.6.1 Insulation resistance of the completed installation shall be measured and recorded before energisation.

3.6.2 Earth resistance of each earth electrode shall be measured and shall not exceed the value stipulated in the relevant Indian Standard.

3.6.3 All high voltage switchboards shall be tested for dielectric strength in the manner recommended in the applicable Indian Standard.

SECTION IV - COMMERCIAL TERMS

4.1 Earnest Money Deposit of Rs 2,00,000 shall accompany the bid in the form of a demand draft drawn in favour of the Executive Engineer.

4.2 Payment shall be released within 45 days of certified completion of each milestone as defined in the payment schedule.

4.3 The defect liability period shall be 12 months from the date of handing over. Any dispute shall be referred to arbitration under the Arbitration and Conciliation Act, 1996.

4.4 Bidders must have completed at least two similar works of value not less than Rs 50,00,000 each in the last five years.

4.5 The successful bidder shall furnish a performance security equal to 5 percent of the accepted contract value.

DECLARATION BY THE BIDDER

I/We have read and understood the technical specifications above and agree to supply materials conforming in every respect to the Indian Standards cited herein, at their latest editions current on the date of supply.

Signature of Bidder

Date and Seal