


Building A · FIRST FLOOR (Light scene 1)

Calculation objects



Building A · FIRST FLOOR (Light scene 1)

Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (201 STARIS) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	184 lx (≥ 500 lx) ✗	123 lx	224 lx	0.67 (≥ 0.60) ✓	0.55	WP20
Working plane (202 CORRIDOR) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	140 lx (≥ 500 lx) ✗	65.0 lx	175 lx	0.46 (≥ 0.60) ✗	0.37	WP7
Working plane (203 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	331 lx (≥ 500 lx) ✗	281 lx	377 lx	0.85 (≥ 0.60) ✓	0.75	WP15
Working plane (204 MANAGER) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	470 lx (≥ 500 lx) ✗	248 lx	569 lx	0.53 (≥ 0.60) ✗	0.44	WP13
Working plane (204A DB) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	0.00 lx (≥ 500 lx) ✗	0.00 lx	0.00 lx	- (≥ 0.60)	-	WP21
Working plane (205 BALCONY) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	181 lx (≥ 500 lx) ✗	63.6 lx	341 lx	0.35 (≥ 0.60) ✗	0.19	WP16
Working plane (206 TOILET) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	269 lx (≥ 500 lx) ✗	248 lx	286 lx	0.92 (≥ 0.60) ✓	0.87	WP12
Working plane (207 OFFICE) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	516 lx (≥ 500 lx) ✓	317 lx	666 lx	0.61 (≥ 0.60) ✓	0.48	WP11
Working plane (208 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	458 lx (≥ 500 lx) ✗	374 lx	514 lx	0.82 (≥ 0.60) ✓	0.73	WP5
Working plane (209 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	422 lx (≥ 500 lx) ✗	340 lx	489 lx	0.81 (≥ 0.60) ✓	0.70	WP6
Working plane (210 CAD) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	455 lx (≥ 500 lx) ✗	309 lx	549 lx	0.68 (≥ 0.60) ✓	0.56	WP3

Building A · FIRST FLOOR (Light scene 1)

Calculation objects

Working plane (211 CORRIDOR) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	133 lx (≥ 500 lx) ✗	53.7 lx	220 lx	0.40 (≥ 0.60) ✗	0.24	WP1
Working plane (212 COMMON) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	435 lx (≥ 500 lx) ✗	290 lx	528 lx	0.67 (≥ 0.60) ✓	0.55	WP2
Working plane (213 BALCONY) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	118 lx (≥ 500 lx) ✗	22.1 lx	305 lx	0.19 (≥ 0.60) ✗	0.072	WP4
Working plane (214 OFFICE) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	416 lx (≥ 500 lx) ✗	302 lx	480 lx	0.73 (≥ 0.60) ✓	0.63	WP10
Working plane (215 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	419 lx (≥ 500 lx) ✗	304 lx	477 lx	0.73 (≥ 0.60) ✓	0.64	WP9
Working plane (216 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	400 lx (≥ 500 lx) ✗	285 lx	460 lx	0.71 (≥ 0.60) ✓	0.62	WP8
Working plane (217 TOILET) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	140 lx (≥ 500 lx) ✗	127 lx	150 lx	0.91 (≥ 0.60) ✓	0.85	WP14
Working plane (218 TOILET) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	140 lx (≥ 500 lx) ✗	101 lx	150 lx	0.72 (≥ 0.60) ✓	0.67	WP19
Working plane (219 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	405 lx (≥ 500 lx) ✗	325 lx	464 lx	0.80 (≥ 0.60) ✓	0.70	WP18
Working plane (220 OFFICE) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	392 lx (≥ 500 lx) ✗	300 lx	468 lx	0.77 (≥ 0.60) ✓	0.64	WP17