

Building A · GROUND FLOOR (Emergency light scene)

Room list



Building A · GROUND FLOOR (Emergency light scene)

Room list

101 STAIRS

P_{total}
2.5 W

A_{Room}
5.88 m²

Lighting power density
0.43 W/m² (Space)

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K9R243/1-AX1 (_LTRevAB)	2.5 W	80 lm (100 %)

102 CORRIDOR / LOBBY

P_{total}
12.5 W

A_{Room}
45.50 m²

Lighting power density
0.27 W/m² (Space)

pcs.	Manufacturer	Article No.	Article name	P	Φ
3	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)
5	ETAP	-	K9R243/1-AX1 (_LTRevAB)	2.5 W	80 lm (100 %)

105 TOILET DISABLE

P_{total}
0.0 W

A_{Room}
4.88 m²

Lighting power density
0.00 W/m² (Space)

E_{min} (Anti panic surface)
1.69 lx

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

Building A · GROUND FLOOR (Emergency light scene)

Room list

106 MEETING

P_{total} 0.0 W	A_{Room} 12.47 m ²	Lighting power density 0.00 W/m ² (Space)	E_{min} (Anti panic surface) 1.61 lx
-----------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

107 MEETING

P_{total} 0.0 W	A_{Room} 12.34 m ²	Lighting power density 0.00 W/m ² (Space)	E_{min} (Anti panic surface) 1.60 lx
-----------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

108 CORRIDOR

P_{total} 12.5 W	A_{Room} 52.09 m ²	Lighting power density 0.24 W/m ² (Space)
------------------------------------	---	--

pcs.	Manufacturer	Article No.	Article name	P	Φ
5	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)
5	ETAP	-	K9R243/1-AX1 (_LTRevAB)	2.5 W	80 lm (100 %)

Building A · GROUND FLOOR (Emergency light scene)

Room list

109 MAIL

P_{total} 0.0 W	A_{Room} 12.41 m ²	Lighting power density 0.00 W/m ² (Space)	E_{min} (Anti panic surface) 1.82 lx
-----------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

110 OFFICE

P_{total} 0.0 W	A_{Room} 21.42 m ²	Lighting power density 0.00 W/m ² (Space)	E_{min} (Anti panic surface) 1.15 lx
-----------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

111 CAD

P_{total} 0.0 W	A_{Room} 24.72 m ²	Lighting power density 0.00 W/m ² (Space)	E_{min} (Anti panic surface) 0.70 lx
-----------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

Building A · GROUND FLOOR (Emergency light scene)

Room list

112 CAD

P_{total}
0.0 W**A_{Room}**
25.80 m²**Lighting power density**
0.00 W/m² (Space)**E_{min} (Anti panic surface)**
0.39 lx

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

113 OFFICE

P_{total}
0.0 W**A_{Room}**
18.60 m²**Lighting power density**
0.00 W/m² (Space)**E_{min} (Anti panic surface)**
1.26 lx

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

114 VISITORS

P_{total}
0.0 W**A_{Room}**
12.61 m²**Lighting power density**
0.00 W/m² (Space)**E_{min} (Anti panic surface)**
1.76 lx

pcs.	Manufacturer	Article No.	Article name	P	Φ
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.0 W	93 lm (100 %)

Building A · GROUND FLOOR (Light scene 1)

Room list



Building A · GROUND FLOOR (Light scene 1)

Room list

101 STAIRS

P_{total}
29.5 W

A_{Room}
5.88 m²

Lighting power density
5.02 W/m² (Space)

pcs.	Manufacturer	Article No.	Article name	P	$\Phi_{\text{Luminaire}}$
1	ETAP	-	U2B-M110-MI-840-045D (_LTRevAD)	29.5 W	4490 lm

102 CORRIDOR / LOBBY

P_{total}
175.0 W

A_{Room}
45.50 m²

Lighting power density
3.85 W/m² = 1.26 W/m²/100 lx (Space)

$\bar{E}_{\text{perpendicular}}$ (Working plane)
305 lx

pcs.	Manufacturer	Article No.	Article name	P	$\Phi_{\text{Luminaire}}$
9	ETAP	-	U2B-M110-MI-840-025D (_LTRevAD)	17.0 W	2495 lm
2	Lena Lighting	284380	EXPO OPTIMA track 1700lm 60D biały mat struktura 935 11W	11.0 W	1700 lm

103 TOILET

P_{total}
16.5 W

A_{Room}
3.03 m²

Lighting power density
5.44 W/m² = 2.71 W/m²/100 lx (Space)

$\bar{E}_{\text{perpendicular}}$ (Working plane)
201 lx

pcs.	Manufacturer	Article No.	Article name	P	$\Phi_{\text{Luminaire}}$
1	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm

Building A · GROUND FLOOR (Light scene 1)

Room list

104 TOLIET

P_{total} 16.5 W	A_{Room} 2.93 m ²	Lighting power density 5.64 W/m ² = 2.96 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 190 lx
------------------------------------	--	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
1	ETAP	-	U2B-M210-MI-840-025D (_LTRRevAD)	16.5 W	2495 lm

105 TOILET DISABLE

P_{total} 16.5 W	A_{Room} 4.88 m ²	Lighting power density 3.38 W/m ² = 1.92 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 176 lx
------------------------------------	--	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
1	ETAP	-	U2B-M210-MI-840-025D (_LTRRevAD)	16.5 W	2495 lm

106 MEETING

P_{total} 66.0 W	A_{Room} 12.47 m ²	Lighting power density 5.29 W/m ² = 1.25 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 424 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
4	ETAP	-	U2B-M210-MI-840-025D (_LTRRevAD)	16.5 W	2495 lm

Building A · GROUND FLOOR (Light scene 1)

Room list

107 MEETING

P_{total} 66.0 W	A_{Room} 12.34 m ²	Lighting power density 5.35 W/m ² = 1.23 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 433 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm

108 CORRIDOR

P_{total} 217.5 W	A_{Room} 52.09 m ²	Lighting power density 4.18 W/m ² = 1.18 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 352 lx
-------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
2	ETAP	-	U2B-M110-MI-830-025D (_LTRevAD)	17.5 W	2495 lm
2	ETAP	-	U2B-M110-MI-840-025D (_LTRevAD)	17.0 W	2495 lm
9	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm

109 MAIL

P_{total} 66.0 W	A_{Room} 12.41 m ²	Lighting power density 5.32 W/m ² = 1.23 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 432 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm

Building A · GROUND FLOOR (Light scene 1)

Room list

110 OFFICE

P_{total} 66.0 W	A_{Room} 21.42 m ²	Lighting power density 3.08 W/m ² = 1.03 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 299 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
4	ETAP	-	U2B-M210-MI-840-025D (_LTRvAD)	16.5 W	2495 lm

111 CAD

P_{total} 99.0 W	A_{Room} 24.72 m ²	Lighting power density 4.00 W/m ² = 1.02 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 393 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
6	ETAP	-	U2B-M210-MI-840-025D (_LTRvAD)	16.5 W	2495 lm

112 CAD

P_{total} 99.0 W	A_{Room} 25.80 m ²	Lighting power density 3.84 W/m ² = 1.00 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 382 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
6	ETAP	-	U2B-M210-MI-840-025D (_LTRvAD)	16.5 W	2495 lm

Building A · GROUND FLOOR (Light scene 1)

Room list

113 OFFICE

P_{total} 66.0 W	A_{Room} 18.60 m ²	Lighting power density 3.55 W/m ² = 1.12 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 318 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm

114 VISITORS

P_{total} 61.0 W	A_{Room} 12.61 m ²	Lighting power density 4.84 W/m ² = 1.14 W/m ² /100 lx (Space)	E_{perpendicular} (Working plane) 425 lx
------------------------------------	---	--	--

pcs.	Manufacturer	Article No.	Article name	P	Φ _{Luminaire}
2	ETAP	-	U2B-M210-MI-830-045D (_LTRevAD)	30.5 W	4490 lm

Building A · GROUND FLOOR


Luminaire list

Φ_{total} 159723 lm	P_{total} 1067.3 W	Luminous efficacy 149.7 lm/W	$\Phi_{\text{Emergency lighting}}$ 2461 lm	$P_{\text{Emergency lighting}}$ 27.5 W
------------------------------------	--------------------------------	---------------------------------	---	---

pcs.	Manufacturer	Article No.	Article name		P	Φ	Luminous efficacy
17	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRvAA)		0.4 W	19 lm	43.2 lm/W
					0.0 W	93 lm (100 %)	-
11	ETAP	-	K9R243/1-AX1 (_LTRvAB)		2.5 W	80 lm (100 %)	-
2	ETAP	-	U2B-M110-MI-830-025D (_LTRvAD)		17.5 W	2495 lm	142.5 lm/W
11	ETAP	-	U2B-M110-MI-840-025D (_LTRvAD)		17.0 W	2495 lm	146.7 lm/W
1	ETAP	-	U2B-M110-MI-840-045D (_LTRvAD)		29.5 W	4490 lm	152.2 lm/W
2	ETAP	-	U2B-M210-MI-830-045D (_LTRvAD)		30.5 W	4490 lm	147.2 lm/W
44	ETAP	-	U2B-M210-MI-840-025D (_LTRvAD)		16.5 W	2495 lm	151.2 lm/W
2	Lena Lighting	284380	EXPO OPTIMA track 1700lm 60D bia ³ y mat struktura 935 11W		11.0 W	1700 lm	154.5 lm/W

Building A · GROUND FLOOR (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR (Emergency light scene)

Calculation objects

Anti panic surfaces

Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.69 lx (≥ 0.50 lx) ✓	3.45 lx	0.49 (≥ 0.025) ✓	AP9
Anti panic surface (106 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.61 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP7
Anti panic surface (107 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.60 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP8
Anti panic surface (109 MAIL) Perpendicular illuminance (adaptive) Height: 0.000 m	1.82 lx (≥ 0.50 lx) ✓	3.44 lx	0.53 (≥ 0.025) ✓	AP4
Anti panic surface (110 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.15 lx (≥ 0.50 lx) ✓	3.45 lx	0.33 (≥ 0.025) ✓	AP3
Anti panic surface (111 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.70 lx (≥ 0.50 lx) ✓	3.45 lx	0.20 (≥ 0.025) ✓	AP2
Anti panic surface (112 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.39 lx (≥ 0.50 lx) ✗	3.45 lx	0.11 (≥ 0.025) ✓	AP1
Anti panic surface (113 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.26 lx (≥ 0.50 lx) ✓	3.45 lx	0.37 (≥ 0.025) ✓	AP5
Anti panic surface (114 VISITORS) Perpendicular illuminance (adaptive) Height: 0.000 m	1.76 lx (≥ 0.50 lx) ✓	3.44 lx	0.51 (≥ 0.025) ✓	AP6

Building A · GROUND FLOOR (Emergency light scene)

Calculation objects

Escape routes


Properties	E_{min} Middle area (Target)	E_{max} Middle area	E_{min} Centerline (Target)	E_{max} Centerline	U_d (Target)	Index
102 Corridor/Lobby Emergency route Perpendicular illuminance (adaptive) Height: 0.000 m	1.86 lx (≥ 0.50 lx) ✓	11.3 lx	2.23 lx (≥ 1.00 lx) ✓	11.2 lx	0.20 (≥ 0.025) ✓	ER1
108 Corridor Emergency route Perpendicular illuminance (adaptive) Height: 0.000 m	2.57 lx (≥ 0.50 lx) ✓	12.1 lx	3.00 lx (≥ 1.00 lx) ✓	12.1 lx	0.25 (≥ 0.025) ✓	ER2

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR (Light scene 1)

Calculation objects



Building A · GROUND FLOOR (Light scene 1)

Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (102 CORRIDOR / LOBBY) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	305 lx (≥ 500 lx) ✗	128 lx	404 lx	0.42 (≥ 0.60) ✗	0.32	WP24
Working plane (103 TOILET) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	201 lx (≥ 500 lx) ✗	163 lx	222 lx	0.81 (≥ 0.60) ✓	0.73	WP32
Working plane (104 TOILET) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	190 lx (≥ 500 lx) ✗	143 lx	214 lx	0.75 (≥ 0.60) ✓	0.67	WP29
Working plane (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	176 lx (≥ 500 lx) ✗	124 lx	208 lx	0.70 (≥ 0.60) ✓	0.60	WP27
Working plane (106 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	424 lx (≥ 500 lx) ✗	290 lx	494 lx	0.68 (≥ 0.60) ✓	0.59	WP28
Working plane (107 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	433 lx (≥ 500 lx) ✗	297 lx	495 lx	0.69 (≥ 0.60) ✓	0.60	WP26
Working plane (108 CORRIDOR) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	352 lx (≥ 500 lx) ✗	127 lx	466 lx	0.36 (≥ 0.60) ✗	0.27	WP33
Working plane (109 MAIL) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	432 lx (≥ 500 lx) ✗	223 lx	581 lx	0.52 (≥ 0.60) ✗	0.38	WP23
Working plane (110 OFFICE) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	299 lx (≥ 500 lx) ✗	169 lx	380 lx	0.57 (≥ 0.60) ✗	0.44	WP22
Working plane (111 CAD) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	393 lx (≥ 500 lx) ✗	221 lx	492 lx	0.56 (≥ 0.60) ✗	0.45	WP21
Working plane (112 CAD) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	382 lx (≥ 500 lx) ✗	204 lx	494 lx	0.53 (≥ 0.60) ✗	0.41	WP25

Building A · GROUND FLOOR (Light scene 1)

Calculation objects

Working plane (113 OFFICE) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	318 lx (≥ 500 lx) ✗	221 lx	385 lx	0.69 (≥ 0.60) ✓	0.57	WP31
Working plane (114 VISITORS) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	425 lx (≥ 500 lx) ✗	235 lx	600 lx	0.55 (≥ 0.60) ✗	0.39	WP30

Calculation surfaces

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
101 Stairs Perpendicular illuminance Height: 1.700 m	311 lx	98.1 lx	589 lx	0.32	0.17	CG1
101 Stairs Lower Perpendicular illuminance Height: 0.000 m	366 lx	319 lx	397 lx	0.87	0.80	CG2
Art Wall Perpendicular illuminance Height: 1.350 m	199 lx	54.1 lx	280 lx	0.27	0.19	CG6
Art Wall Horizontal illuminance Height: 1.350 m	90.3 lx	16.2 lx	166 lx	0.18	0.098	CG6

Building A · GROUND FLOOR (Light scene 1)

Calculation objects

111 CAD Glare Surface (RUG)

Strongest glare at	135°
max	15.3
Target	≤ 19.0
Viewing sector	0° - 360°
Step width	15°
Height	1.200 m
Index	CG4

Building A · GROUND FLOOR (Light scene 1)

Calculation objects

111 CAD Glare Surface (RUG)



Building A · GROUND FLOOR (Light scene 1)

Calculation objects

112 CAD Glare Surface (RUG)

Strongest glare at	120°
max	16.0
Target	≤ 19.0
Viewing sector	0° - 360°
Step width	15°
Height	1.200 m
Index	CG5

Building A · GROUND FLOOR (Light scene 1)

Calculation objects

112 CAD Glare Surface (RUG)




Building A · GROUND FLOOR (Light scene 1)

Calculation objects


112 CAD Glare Surface (R_G)

Strongest glare at	135°
max	> 90
Target	-
Viewing sector	0° - 360°
Step width	15°
Angle of inclination	-2°
Height	1.200 m
Index	CG5
Method	Simplified calculation according to EN 12464

Building A · GROUND FLOOR (Light scene 1)

Calculation objects112 CAD Glare Surface (R_G)


Building A · GROUND FLOOR (Emergency light scene)
102 Corridor/Lobby Emergency route



Properties	E_{min} Middle area (Target)	E_{max} Middle area	E_{min} Centerline (Target)	E_{max} Centerline	U_d (Target)	Index
102 Corridor/Lobby Emergency route Perpendicular illuminance (adaptive) Height: 0.000 m	1.86 lx (≥ 0.50 lx) ✓	11.3 lx	2.23 lx (≥ 1.00 lx) ✓	11.2 lx	0.20 (≥ 0.025) ✓	ER1

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR (Emergency light scene)

108 Corridor Emergency route


Properties	E_{min} Middle area (Target)	E_{max} Middle area	E_{min} Centerline (Target)	E_{max} Centerline	U_d (Target)	Index
108 Corridor Emergency route Perpendicular illuminance (adaptive) Height: 0.000 m	2.57 lx (≥ 0.50 lx) ✓	12.1 lx	3.00 lx (≥ 1.00 lx) ✓	12.1 lx	0.25 (≥ 0.025) ✓	ER2

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 101 STAIRS (Emergency light scene)

Summary



Ground area	5.88 m²		
Reflection factors	Ceiling: 55.8 %, Walls: 50.0 %, Floor: 20.0 %	Clearance height	2.700 m
Maintenance factor	0.76 (fixed)	Mounting height	2.758 m

Building A · GROUND FLOOR · 101 STAIRS (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.43 W/m ²	–		

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name		P	Φ	Luminous efficacy
1	ETAP	-	K9R243/1-AX1 (_LTRevAB)		2.5 W	80 lm (100 %)	–

Building A · GROUND FLOOR · 101 STAIRS (Light scene 1)

Summary



Ground area	5.88 m ²		
Reflection factors	Ceiling: 55.8 %, Walls: 50.0 %, Floor: 20.0 %	Clearance height	2.700 m
Maintenance factor	0.76 (fixed)	Mounting height	2.776 m

Building A · GROUND FLOOR · 101 STAIRS (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Glare valuation ⁽¹⁾	R _{UG, max}	17	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	73.0 kWh/a	max. 250 kWh/a	✓	
Space	Lighting power density	5.02 W/m ²	–		

(1) Based on a rectangular space of 4.590 m x 1.280 m and SHR of 0.25.

(2) Calculated using DIN:18599-4.


Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Luminaire list


pcs.	Manufacturer	Article No.	Article name	R _{UG}	P	Φ	Luminous efficacy
1	ETAP	-	U2B-M110-MI-840-045D (LTRRevAD)	17	29.5 W	4490 lm	152.2 lm/W

Building A · GROUND FLOOR · 101 STAIRS

Luminaire layout plan



Building A · GROUND FLOOR · 101 STAIRS


Luminaire layout plan

Manufacturer	ETAP	P	0.0 W
Article No.	-	P _{Emergency lighting}	2.5 W
Article name	K9R243/1-AX1 (_LTRevAB)	Φ _{Luminaire}	0 lm
Fitting	1x sign with picto	Φ _{Emergency lighting}	80 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
0.638 m	4.493 m	2.758 m	1

Building A · GROUND FLOOR · 101 STAIRS

Luminaire layout plan

Manufacturer	ETAP	P	29.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	4490 lm
Article name	U2B-M110-MI-840-045D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.630 m	3.819 m	2.776 m	2

Building A · GROUND FLOOR · 101 STAIRS


Luminaire list

Φ_{total} 4500 lm	P_{total} 29.5 W	Luminous efficacy 152.5 lm/W	$\Phi_{\text{Emergency lighting}}$ 80 lm	$P_{\text{Emergency lighting}}$ 2.5 W
----------------------------------	------------------------------	---------------------------------	---	--

pcs.	Manufacturer	Article No.	Article name		P	Φ	Luminous efficacy
1	ETAP	-	K9R243/1-AX1 (_LTRevAB)		2.5 W	80 lm (100 %)	-
1	ETAP	-	U2B-M110-MI-840-045D (_LTRevAD)		29.5 W	4490 lm	152.2 lm/W

Building A · GROUND FLOOR · 101 STAIRS (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 101 STAIRS (Emergency light scene)


Calculation objects

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 101 STAIRS (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 101 STAIRS (Light scene 1)

Calculation objects


Calculation surfaces

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
101 Stairs Perpendicular illuminance Height: 1.700 m	311 lx	98.1 lx	589 lx	0.32	0.17	CG1
101 Stairs Lower Perpendicular illuminance Height: 0.000 m	366 lx	319 lx	397 lx	0.87	0.80	CG2

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 101 STAIRS (Emergency light scene)

101 Stairs




Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
101 Stairs Perpendicular illuminance Height: 1.700 m	0.96 lx	0.00 lx	1.79 lx	0.00	0.00	CG1

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 101 STAIRS (Emergency light scene)


101 Stairs Lower



Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
101 Stairs Lower Perpendicular illuminance Height: 0.000 m	4.27 lx	2.36 lx	6.09 lx	0.55	0.39	CG2

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 101 STAIRS (Light scene 1)


101 Stairs

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
101 Stairs Perpendicular illuminance Height: 1.700 m	311 lx	98.1 lx	589 lx	0.32	0.17	CG1

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 101 STAIRS (Light scene 1)

101 Stairs Lower




Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
101 Stairs Lower Perpendicular illuminance Height: 0.000 m	366 lx	319 lx	397 lx	0.87	0.80	CG2

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY (Light scene 1)

Summary



Ground area	45.50 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.600 m – 2.776 m
Height _{Working plane}	0.000 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	305 lx	$\geq 500 \text{ lx}$	✗	WP24
	$U_o (g_1)$	0.42	≥ 0.60	✗	WP24
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	21	≤ 19	✗	
Energy estimation ⁽²⁾	Consumption	433 kWh/a	max. 1600 kWh/a	✓	
Space	Lighting power density	3.85 W/m ²	–		
		1.26 W/m ² /100 lx	–		

(1) Based on a rectangular space of 6.900 m x 12.350 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
9	ETAP	-	U2B-M110-MI-840-025D (_LTRevAD)	16	17.0 W	2495 lm	146.7 lm/W
2	Lena Lighting	284380	EXPO OPTIMA track 1700lm 60D bia³y mat struktura 935 11W	21	11.0 W	1700 lm	154.5 lm/W

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY

Luminaire layout plan

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
10.443 m	4.060 m	2.700 m	4
3.243 m	2.860 m	2.700 m	16
7.443 m	1.660 m	2.700 m	17

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY


Luminaire layout plan

Manufacturer	ETAP	P	0.0 W
Article No.	-	P _{Emergency lighting}	2.5 W
Article name	K9R243/1-AX1 (_LTRevAB)	Φ _{Luminaire}	0 lm
Fitting	1x sign with picto	Φ _{Emergency lighting}	80 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
10.562 m	6.277 m	2.758 m	1
2.105 m	2.947 m	2.758 m	6
6.883 m	2.900 m	2.758 m	11
7.450 m	0.570 m	2.758 m	18
10.528 m	0.547 m	2.758 m	19

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY


Luminaire layout plan

Manufacturer	ETAP	P	17.0 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M110-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
9.883 m	5.300 m	2.776 m	2
11.683 m	5.300 m	2.776 m	3
0.883 m	2.900 m	2.776 m	7
2.683 m	2.900 m	2.776 m	8
4.483 m	2.900 m	2.776 m	9
6.283 m	2.900 m	2.776 m	10
8.083 m	2.900 m	2.776 m	12
9.883 m	2.900 m	2.776 m	13
11.683 m	2.900 m	2.776 m	14

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY

Luminaire layout plan

Manufacturer	Lena Lighting	P	11.0 W
Article No.	284380	Φ _{Luminaire}	1700 lm
Article name	EXPO OPTIMA track 1700lm 60D bia ³ y mat struktura 935 11W		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
10.441 m	2.955 m	2.600 m	5
7.457 m	2.873 m	2.600 m	15

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY


Luminaire list

Φ_{total} 25957 lm	P_{total} 176.2 W	Luminous efficacy 147.3 lm/W	$\Phi_{\text{Emergency lighting}}$ 679 lm	$P_{\text{Emergency lighting}}$ 12.5 W
-----------------------------------	-------------------------------	---------------------------------	--	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
3	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
5	ETAP	-	K9R243/1-AX1 (_LTRevAB)	 2.5 W	80 lm (100 %)	-
9	ETAP	-	U2B-M110-MI-840-025D (_LTRevAD)	17.0 W	2495 lm	146.7 lm/W
2	Lena Lighting	284380	EXPO OPTIMA track 1700lm 60D biały mat struktura 935 11W	11.0 W	1700 lm	154.5 lm/W

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY (Light scene 1)

Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (102 CORRIDOR / LOBBY) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	305 lx (≥ 500 lx) ✗	128 lx	404 lx	0.42 (≥ 0.60) ✗	0.32	WP24


Calculation surfaces

Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Art Wall Perpendicular illuminance Height: 1.350 m	199 lx	54.1 lx	280 lx	0.27	0.19	CG6
Art Wall Horizontal illuminance Height: 1.350 m	90.3 lx	16.2 lx	166 lx	0.18	0.098	CG6

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY (Light scene 1)

Working plane (102 CORRIDOR / LOBBY)





Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (102 CORRIDOR / LOBBY)	305 lx	128 lx	404 lx	0.42	0.32	WP24
Perpendicular illuminance (adaptive)	≥ 500 lx			≥ 0.60		
Height: 0.000 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 102 CORRIDOR / LOBBY (Light scene 1)



Art Wall



Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Art Wall Perpendicular illuminance Height: 1.350 m	199 lx	54.1 lx	280 lx	0.27	0.19	CG6

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Art Wall




Properties	$\bar{E}$	E_{min}	E_{max}	$U_o (g_1)$	g_2	Index
Art Wall Horizontal illuminance Height: 1.350 m	90.3 lx	16.2 lx	166 lx	0.18	0.098	CG6

55

Building A · GROUND FLOOR · 103 TOILET (Light scene 1)

Summary



Ground area	3.03 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.000 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 103 TOILET (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	201 lx	$\geq 500 \text{ lx}$	✗	WP32
	$U_o (g_1)$	0.81	≥ 0.60	✓	WP32
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	14	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	40.8 kWh/a	max. 150 kWh/a	✓	
Space	Lighting power density	5.44 W/m ²	–		
		2.71 W/m ² /100 lx	–		

(1) Based on a rectangular space of 2.100 m x 1.445 m and SHR of 0.25.

(2) Calculated using DIN:18599-4.


Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Luminaire list


pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
1	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	14	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 103 TOILET

Luminaire layout plan



Building A · GROUND FLOOR · 103 TOILET

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.802 m	0.833 m	2.776 m	1

Building A · GROUND FLOOR · 103 TOILET


Luminaire list

Φ_{total} 2500 lm	P_{total} 16.5 W	Luminous efficacy 151.5 lm/W
----------------------------------	------------------------------	---------------------------------

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	U2B-M210-MI-840-025D (LTRRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 103 TOILET (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 103 TOILET (Light scene 1)

Calculation objects


Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (103 TOILET)	201 lx	163 lx	222 lx	0.81	0.73	WP32
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.000 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 103 TOILET (Light scene 1)

Working plane (103 TOILET)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_0 (g_1)$ (Target)	g_2	Index
Working plane (103 TOILET)	201 lx	163 lx	222 lx	0.81	0.73	WP32
Perpendicular illuminance (adaptive)	≥ 500 lx			≥ 0.60		
Height: 0.000 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 104 TOLIET (Light scene 1)

Summary



Ground area	2.93 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.000 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 104 TOLIET (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	190 lx	$\geq 500 \text{ lx}$	✗	WP29
	$U_o (g_1)$	0.75	≥ 0.60	✓	WP29
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	14	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	40.8 kWh/a	max. 150 kWh/a	✓	
Space	Lighting power density	5.64 W/m ²	–		
		2.96 W/m ² /100 lx	–		

(1) Based on a rectangular space of 1.400 m x 2.090 m and SHR of 0.25.

(2) Calculated using DIN:18599-4.


Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Luminaire list


pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
1	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	14	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 104 TOLIET

Luminaire layout plan



Building A · GROUND FLOOR · 104 TOLIET

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
1.101 m	0.817 m	2.776 m	1

Building A · GROUND FLOOR · 104 TOLIET


Luminaire list

Φ_{total} 2500 lm	P_{total} 16.5 W	Luminous efficacy 151.5 lm/W
---------------------------	-----------------------	---------------------------------

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	U2B-M210-MI-840-025D (LTRRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 104 TOLIET (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 104 TOLIET (Light scene 1)



Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (104 TOLIET)	190 lx	143 lx	214 lx	0.75	0.67	WP29
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.000 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 104 TOLIET (Light scene 1)


Working plane (104 TOLIET)

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (104 TOLIET)	190 lx	143 lx	214 lx	0.75	0.67	WP29
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.000 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 105 TOILET DISABLE (Emergency light scene)

Summary



Ground area	4.88 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.000 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 105 TOILET DISABLE (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.69 lx (≥ 0.50 lx) ✓	3.45 lx	0.49 (≥ 0.025) ✓	AP9

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 105 TOILET DISABLE (Light scene 1)

Summary



Ground area	4.88 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.000 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 105 TOILET DISABLE (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	176 lx	$\geq 500 \text{ lx}$	✗	WP27
	$U_o (g_1)$	0.70	≥ 0.60	✓	WP27
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	14	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	40.8 kWh/a	max. 200 kWh/a	✓	
Space	Lighting power density	3.38 W/m ²	–		
		1.92 W/m ² /100 lx	–		

(1) Based on a rectangular space of 2.320 m x 2.104 m and SHR of 0.25.

(2) Calculated using DIN:18599-4.


Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Luminaire list



pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
1	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	14	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 105 TOILET DISABLE

Luminaire layout plan



Building A · GROUND FLOOR · 105 TOILET DISABLE


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
1.281 m	1.562 m	2.700 m	1

Building A · GROUND FLOOR · 105 TOILET DISABLE

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
1.307 m	0.804 m	2.776 m	2

Building A · GROUND FLOOR · 105 TOILET DISABLE


Luminaire list

Φ_{total} 2519 lm	P_{total} 16.9 W	Luminous efficacy 149.1 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
1	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 105 TOILET DISABLE (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 105 TOILET DISABLE (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.69 lx (≥ 0.50 lx) ✓	3.45 lx	0.49 (≥ 0.025) ✓	AP9

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 105 TOILET DISABLE (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 105 TOILET DISABLE (Light scene 1)

Calculation objects



Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	176 lx (≥ 500 lx) ✗	124 lx	208 lx	0.70 (≥ 0.60) ✓	0.60	WP27

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 105 TOILET DISABLE (Emergency light scene)

Anti panic surface (105 TOILET DISABLE)





Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.69 lx (≥ 0.50 lx) ✓	3.45 lx	0.49 (≥ 0.025) ✓	AP9

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 105 TOILET DISABLE (Light scene 1)

Working plane (105 TOILET DISABLE)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (105 TOILET DISABLE) Perpendicular illuminance (adaptive) Height: 0.000 m, Wall zone: 0.000 m	176 lx (≥ 500 lx) ✗	124 lx	208 lx	0.70 (≥ 0.60) ✓	0.60	WP27

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 106 MEETING (Emergency light scene)

Summary



Ground area	12.47 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 106 MEETING (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (106 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.61 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP7

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 106 MEETING (Light scene 1)

Summary



Ground area	12.47 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 106 MEETING (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	424 lx	$\geq 500 \text{ lx}$	✗	WP28
	$U_o (g_1)$	0.68	≥ 0.60	✓	WP28
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[103 - 163] kWh/a	max. 450 kWh/a	✓	
Space	Lighting power density	5.29 W/m ²	–		
		1.25 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.130 m x 3.020 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 106 MEETING

Luminaire layout plan

Building A · GROUND FLOOR · 106 MEETING


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
2.025 m	1.374 m	2.700 m	3

Building A · GROUND FLOOR · 106 MEETING

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.863 m	2.312 m	2.776 m	1
3.263 m	2.312 m	2.776 m	2
0.868 m	0.512 m	2.776 m	4
3.268 m	0.512 m	2.776 m	5

Building A · GROUND FLOOR · 106 MEETING


Luminaire list

Φ_{total} 10019 lm	P_{total} 66.4 W	Luminous efficacy 150.9 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 106 MEETING (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 106 MEETING (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (106 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.61 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP7

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 106 MEETING (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 106 MEETING (Light scene 1)

Calculation objects



Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (106 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	424 lx (≥ 500 lx) ✗	290 lx	494 lx	0.68 (≥ 0.60) ✓	0.59	WP28

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 106 MEETING (Emergency light scene)



Anti panic surface (106 MEETING)



Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (106 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.61 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP7

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 106 MEETING (Light scene 1)


Working plane (106 MEETING)

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (106 MEETING)	424 lx	290 lx	494 lx	0.68	0.59	WP28
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 107 MEETING (Emergency light scene)

Summary



Ground area	12.34 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 107 MEETING (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (107 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.60 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP8

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 107 MEETING (Light scene 1)

Summary



Ground area	12.34 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 107 MEETING (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	433 lx	$\geq 500 \text{ lx}$	✗	WP26
	$U_o (g_1)$	0.69	≥ 0.60	✓	WP26
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[103 - 163] kWh/a	max. 450 kWh/a	✓	
Space	Lighting power density	5.35 W/m ²	–		
		1.23 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.100 m x 3.010 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 107 MEETING

Luminaire layout plan

Building A · GROUND FLOOR · 107 MEETING


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRvAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
1.945 m	1.371 m	2.700 m	3

Building A · GROUND FLOOR · 107 MEETING

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.783 m	2.311 m	2.776 m	1
3.183 m	2.311 m	2.776 m	2
0.788 m	0.511 m	2.776 m	4
3.188 m	0.511 m	2.776 m	5

Building A · GROUND FLOOR · 107 MEETING


Luminaire list

Φ_{total} 10019 lm	P_{total} 66.4 W	Luminous efficacy 150.9 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 107 MEETING (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 107 MEETING (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (107 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.60 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP8

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 107 MEETING (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 107 MEETING (Light scene 1)

Calculation objects



Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (107 MEETING) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	433 lx (≥ 500 lx) ✗	297 lx	495 lx	0.69 (≥ 0.60) ✓	0.60	WP26

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 107 MEETING (Emergency light scene)


Anti panic surface (107 MEETING)



Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (107 MEETING) Perpendicular illuminance (adaptive) Height: 0.000 m	1.60 lx (≥ 0.50 lx) ✓	3.44 lx	0.47 (≥ 0.025) ✓	AP8

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 107 MEETING (Light scene 1)


Working plane (107 MEETING)

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (107 MEETING)	433 lx	297 lx	495 lx	0.69	0.60	WP26
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 108 CORRIDOR (Light scene 1)

Summary



Ground area	52.09 m²	Clearance height	2.700 m
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %	Mounting height	2.776 m
Maintenance factor	0.76 (fixed)	Height _{Working plane}	0.700 m
		Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 108 CORRIDOR (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	352 lx	$\geq 500 \text{ lx}$	✗	WP33
	$U_o (g_1)$	0.36	≥ 0.60	✗	WP33
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	16	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[445 - 538] kWh/a	max. 1850 kWh/a	✓	
Space	Lighting power density	4.18 W/m ²	–		
		1.18 W/m ² /100 lx	–		

(1) Based on a rectangular space of 6.840 m x 21.000 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))



Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
2	ETAP	-	U2B-M110-MI-830-025D (_LTRevAD)	16	17.5 W	2495 lm	142.5 lm/W
2	ETAP	-	U2B-M110-MI-840-025D (_LTRevAD)	16	17.0 W	2495 lm	146.7 lm/W
9	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 108 CORRIDOR

Luminaire layout plan

Building A · GROUND FLOOR · 108 CORRIDOR


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRvAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
19.123 m	5.422 m	2.700 m	1
17.543 m	4.126 m	2.700 m	4
19.043 m	3.348 m	2.700 m	5
19.043 m	0.730 m	2.700 m	18
7.123 m	0.676 m	2.700 m	19

Building A · GROUND FLOOR · 108 CORRIDOR


Luminaire layout plan

Manufacturer	ETAP	P	0.0 W
Article No.	-	P _{Emergency lighting}	2.5 W
Article name	K9R243/1-AX1 (_LTRevAB)	Φ _{Luminaire}	0 lm
Fitting	1x sign with picto	Φ _{Emergency lighting}	80 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
19.677 m	0.752 m	2.758 m	17
0.502 m	0.537 m	2.758 m	20
7.681 m	0.531 m	2.758 m	21
2.310 m	0.529 m	2.758 m	22
17.288 m	0.496 m	2.758 m	23

Building A · GROUND FLOOR · 108 CORRIDOR


Luminaire layout plan

Manufacturer	ETAP	P	17.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M110-MI-830-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
17.883 m	5.290 m	2.776 m	2
20.283 m	5.290 m	2.776 m	3

Building A · GROUND FLOOR · 108 CORRIDOR


Luminaire layout plan

Manufacturer	ETAP	P	17.0 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M110-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
17.883 m	2.890 m	2.776 m	6
20.283 m	2.890 m	2.776 m	7

Building A · GROUND FLOOR · 108 CORRIDOR

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
1.081 m	0.792 m	2.776 m	8
3.486 m	0.792 m	2.776 m	9
8.286 m	0.792 m	2.776 m	10
13.081 m	0.792 m	2.776 m	11
17.881 m	0.792 m	2.776 m	12
5.886 m	0.788 m	2.776 m	13
10.686 m	0.788 m	2.776 m	14
15.486 m	0.788 m	2.776 m	15
20.286 m	0.788 m	2.776 m	16

Building A · GROUND FLOOR · 108 CORRIDOR

Luminaire list

Φ_{total} 32595 lm	P_{total} 219.5 W	Luminous efficacy 148.5 lm/W	$\Phi_{\text{Emergency lighting}}$ 865 lm	$P_{\text{Emergency lighting}}$ 12.5 W
-----------------------------------	-------------------------------	---------------------------------	--	---

pcs.	Manufacturer	Article No.	Article name		P	Φ	Luminous efficacy
5	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)		0.4 W	19 lm	43.2 lm/W
					0.0 W	93 lm (100 %)	-
5	ETAP	-	K9R243/1-AX1 (_LTRevAB)		2.5 W	80 lm (100 %)	-
2	ETAP	-	U2B-M110-MI-830-025D (_LTRevAD)		17.5 W	2495 lm	142.5 lm/W
2	ETAP	-	U2B-M110-MI-840-025D (_LTRevAD)		17.0 W	2495 lm	146.7 lm/W
9	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)		16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 108 CORRIDOR (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 108 CORRIDOR (Light scene 1)

Calculation objects


Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (108 CORRIDOR)	352 lx	127 lx	466 lx	0.36	0.27	WP33
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 108 CORRIDOR (Light scene 1)

Working plane (108 CORRIDOR)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (108 CORRIDOR) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	352 lx (≥ 500 lx) 	127 lx	466 lx	0.36 (≥ 0.60) 	0.27	WP33

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 109 MAIL (Emergency light scene)

Summary



Ground area	12.41 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 109 MAIL (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (109 MAIL) Perpendicular illuminance (adaptive) Height: 0.000 m	1.82 lx (≥ 0.50 lx) ✓	3.44 lx	0.53 (≥ 0.025) ✓	AP4


Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 109 MAIL (Light scene 1)

Summary



Ground area	12.41 m ²	Clearance height	2.700 m
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %	Mounting height	2.776 m
Maintenance factor	0.76 (fixed)	Height _{Working plane}	0.700 m
		Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 109 MAIL (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	432 lx	$\geq 500 \text{ lx}$	✗	WP23
	$U_o (g_1)$	0.52	≥ 0.60	✗	WP23
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[103 - 163] kWh/a	max. 450 kWh/a	✓	
Space	Lighting power density	5.32 W/m ²	–		
		1.23 W/m ² /100 lx	–		

(1) Based on a rectangular space of 5.304 m x 2.340 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 109 MAIL

Luminaire layout plan

Building A · GROUND FLOOR · 109 MAIL


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
1.050 m	2.840 m	2.700 m	3

Building A · GROUND FLOOR · 109 MAIL

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
1.576 m	4.082 m	2.776 m	1
0.376 m	4.078 m	2.776 m	2
1.576 m	1.082 m	2.776 m	4
0.376 m	1.078 m	2.776 m	5

Building A · GROUND FLOOR · 109 MAIL


Luminaire list

Φ_{total} 10019 lm	P_{total} 66.4 W	Luminous efficacy 150.9 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 109 MAIL (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 109 MAIL (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (109 MAIL) Perpendicular illuminance (adaptive) Height: 0.000 m	1.82 lx (≥ 0.50 lx) ✓	3.44 lx	0.53 (≥ 0.025) ✓	AP4

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 109 MAIL (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 109 MAIL (Light scene 1)

Calculation objects



Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (109 MAIL)	432 lx	223 lx	581 lx	0.52	0.38	WP23
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 109 MAIL (Emergency light scene)

Anti panic surface (109 MAIL)




Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (109 MAIL) Perpendicular illuminance (adaptive) Height: 0.000 m	1.82 lx (≥ 0.50 lx) ✓	3.44 lx	0.53 (≥ 0.025) ✓	AP4

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 109 MAIL (Light scene 1)

Working plane (109 MAIL)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (109 MAIL)	432 lx	223 lx	581 lx	0.52	0.38	WP23
Perpendicular illuminance (adaptive)	≥ 500 lx			≥ 0.60		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 110 OFFICE (Emergency light scene)

Summary



Ground area	21.42 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 110 OFFICE (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (110 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.15 lx (≥ 0.50 lx) ✓	3.45 lx	0.33 (≥ 0.025) ✓	AP3

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 110 OFFICE (Light scene 1)

Summary



Ground area	21.42 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 110 OFFICE (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	299 lx	$\geq 500 \text{ lx}$	✗	WP22
	$U_o (g_1)$	0.57	≥ 0.60	✗	WP22
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[103 - 163] kWh/a	max. 800 kWh/a	✓	
Space	Lighting power density	3.08 W/m ²	–		
		1.03 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.050 m x 5.290 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 110 OFFICE

Luminaire layout plan

Building A · GROUND FLOOR · 110 OFFICE


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
2.027 m	2.770 m	2.700 m	3

Building A · GROUND FLOOR · 110 OFFICE

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
3.253 m	4.012 m	2.776 m	1
0.848 m	4.008 m	2.776 m	2
3.253 m	1.012 m	2.776 m	4
0.848 m	1.008 m	2.776 m	5

Building A · GROUND FLOOR · 110 OFFICE


Luminaire list

Φ_{total} 10019 lm	P_{total} 66.4 W	Luminous efficacy 150.9 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 110 OFFICE (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 110 OFFICE (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (110 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.15 lx (≥ 0.50 lx) ✓	3.45 lx	0.33 (≥ 0.025) ✓	AP3

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 110 OFFICE (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 110 OFFICE (Light scene 1)

Calculation objects



Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (110 OFFICE)	299 lx	169 lx	380 lx	0.57	0.44	WP22
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 110 OFFICE (Emergency light scene)

Anti panic surface (110 OFFICE)




Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (110 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.15 lx (≥ 0.50 lx) ✓	3.45 lx	0.33 (≥ 0.025) ✓	AP3

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 110 OFFICE (Light scene 1)

Working plane (110 OFFICE)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (110 OFFICE)	299 lx	169 lx	380 lx	0.57	0.44	WP22
Perpendicular illuminance (adaptive)	≥ 500 lx			≥ 0.60		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 111 CAD (Emergency light scene)

Summary



Ground area	24.72 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 111 CAD (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (111 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.70 lx (≥ 0.50 lx) ✓	3.45 lx	0.20 (≥ 0.025) ✓	AP2

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 111 CAD (Light scene 1)

Summary



Ground area	24.72 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 111 CAD (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	393 lx	$\geq 500 \text{ lx}$	✗	WP21
	$U_o (g_1)$	0.56	≥ 0.60	✗	WP21
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[154 - 245] kWh/a	max. 900 kWh/a	✓	
Space	Lighting power density	4.00 W/m ²	–		
		1.02 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.700 m x 5.260 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
6	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 111 CAD

Luminaire layout plan

Building A · GROUND FLOOR · 111 CAD


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
2.260 m	2.660 m	2.700 m	5

Building A · GROUND FLOOR · 111 CAD

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.831 m	4.581 m	2.776 m	1
3.831 m	4.581 m	2.776 m	2
0.831 m	2.786 m	2.776 m	3
3.831 m	2.786 m	2.776 m	4
0.826 m	0.986 m	2.776 m	6
3.826 m	0.986 m	2.776 m	7

Building A · GROUND FLOOR · 111 CAD


Luminaire list

Φ_{total} 15019 lm	P_{total} 99.4 W	Luminous efficacy 151.1 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
6	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 111 CAD (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 111 CAD (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (111 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.70 lx (≥ 0.50 lx) ✓	3.45 lx	0.20 (≥ 0.025) ✓	AP2

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 111 CAD (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 111 CAD (Light scene 1)

Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (111 CAD) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	393 lx (≥ 500 lx) ✗	221 lx	492 lx	0.56 (≥ 0.60) ✗	0.45	WP21

Building A · GROUND FLOOR · 111 CAD (Light scene 1)

Calculation objects

111 CAD Glare Surface (RUG)

Strongest glare at	135°
max	15.3
Target	≤ 19.0
Viewing sector	0° - 360°
Step width	15°
Height	1.200 m
Index	CG4

Building A · GROUND FLOOR · 111 CAD (Light scene 1)



Calculation objects

111 CAD Glare Surface (RUG)



Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 111 CAD (Emergency light scene)
Anti panic surface (111 CAD)




Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (111 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.70 lx (≥ 0.50 lx) ✓	3.45 lx	0.20 (≥ 0.025) ✓	AP2

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 111 CAD (Light scene 1)

Working plane (111 CAD)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (111 CAD)	393 lx	221 lx	492 lx	0.56	0.45	WP21
Perpendicular illuminance (adaptive)	$\geq 500 \text{ lx}$			≥ 0.60		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 112 CAD (Emergency light scene)

Summary



Ground area	25.80 m²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 112 CAD (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (112 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.39 lx (≥ 0.50 lx) ✗	3.45 lx	0.11 (≥ 0.025) ✓	AP1

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Summary



Ground area	25.80 m ²	Clearance height	2.700 m
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %	Mounting height	2.776 m
Maintenance factor	0.76 (fixed)	Height _{Working plane}	0.700 m
		Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	382 lx	$\geq 500 \text{ lx}$	✗	WP25
	$U_o (g_1)$	0.53	≥ 0.60	✗	WP25
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[154 - 245] kWh/a	max. 950 kWh/a	✓	
Space	Lighting power density	3.84 W/m ²	–		
		1.00 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.910 m x 5.254 m and SHR of 0.25.

(2) Calculated using DIN:18599-4.


Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Luminaire list




pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
6	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 112 CAD

Luminaire layout plan



Building A · GROUND FLOOR · 112 CAD


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
2.326 m	2.640 m	2.700 m	5

Building A · GROUND FLOOR · 112 CAD

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.751 m	4.537 m	2.776 m	1
3.751 m	4.537 m	2.776 m	2
0.751 m	2.742 m	2.776 m	3
3.751 m	2.742 m	2.776 m	4
0.746 m	0.942 m	2.776 m	6
3.746 m	0.942 m	2.776 m	7

Building A · GROUND FLOOR · 112 CAD


Luminaire list

Φ_{total} 15019 lm	P_{total} 99.4 W	Luminous efficacy 151.1 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
6	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 112 CAD (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 112 CAD (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (112 CAD) Perpendicular illuminance (adaptive) Height: 0.000 m	0.39 lx (≥ 0.50 lx) ✗	3.45 lx	0.11 (≥ 0.025) ✓	AP1

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Calculation objects

Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (112 CAD) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	382 lx (≥ 500 lx) ✗	204 lx	494 lx	0.53 (≥ 0.60) ✗	0.41	WP25

Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Calculation objects

112 CAD Glare Surface (RUG)

Strongest glare at	120°
max	16.0
Target	≤ 19.0
Viewing sector	0° - 360°
Step width	15°
Height	1.200 m
Index	CG5

Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Calculation objects

112 CAD Glare Surface (RUG)




Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Calculation objects

112 CAD Glare Surface (R_G)

Strongest glare at	135°
max	> 90
Target	-
Viewing sector	0° - 360°
Step width	15°
Angle of inclination	-2°
Height	1.200 m
Index	CG5
Method	Simplified calculation according to EN 12464



Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Calculation objects112 CAD Glare Surface (R_G)

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 112 CAD (Emergency light scene)

Anti panic surface (112 CAD)





Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (112 CAD)	0.39 lx	3.45 lx	0.11	AP1
Perpendicular illuminance (adaptive)	(≥ 0.50 lx)		(≥ 0.025)	
Height: 0.000 m	✗		✓	

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 112 CAD (Light scene 1)

Working plane (112 CAD)




Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (112 CAD)	382 lx	204 lx	494 lx	0.53	0.41	WP25
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 113 OFFICE (Emergency light scene)

Summary



Ground area	18.60 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 113 OFFICE (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (113 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.26 lx (≥ 0.50 lx) ✓	3.45 lx	0.37 (≥ 0.025) ✓	AP5

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 113 OFFICE (Light scene 1)

Summary



Ground area	18.60 m²	Clearance height	2.700 m
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %	Mounting height	2.776 m
Maintenance factor	0.76 (fixed)	Height _{Working plane}	0.700 m
		Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 113 OFFICE (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	318 lx	$\geq 500 \text{ lx}$	✗	WP31
	$U_o (g_1)$	0.69	≥ 0.60	✓	WP31
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	15	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	[103 - 163] kWh/a	max. 700 kWh/a	✓	
Space	Lighting power density	3.55 W/m ²	–		
		1.12 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.760 m x 3.907 m and SHR of 0.25.


(2) Calculated using DIN:18599-4.

Utilisation profile: DIALux presetting (5.26.2 Standard (office))




Luminaire list

pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	15	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 113 OFFICE

Luminaire layout plan

Building A · GROUND FLOOR · 113 OFFICE


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
2.602 m	1.930 m	2.700 m	3

Building A · GROUND FLOOR · 113 OFFICE

Luminaire layout plan

Manufacturer	ETAP	P	16.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	2495 lm
Article name	U2B-M210-MI-840-025D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.928 m	3.268 m	2.776 m	1
3.923 m	3.268 m	2.776 m	2
0.928 m	0.868 m	2.776 m	4
3.928 m	0.868 m	2.776 m	5

Building A · GROUND FLOOR · 113 OFFICE


Luminaire list

Φ_{total} 10019 lm	P_{total} 66.4 W	Luminous efficacy 150.9 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
-----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
4	ETAP	-	U2B-M210-MI-840-025D (_LTRevAD)	16.5 W	2495 lm	151.2 lm/W

Building A · GROUND FLOOR · 113 OFFICE (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 113 OFFICE (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (113 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.26 lx (≥ 0.50 lx) ✓	3.45 lx	0.37 (≥ 0.025) ✓	AP5

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 113 OFFICE (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 113 OFFICE (Light scene 1)

Calculation objects



Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (113 OFFICE) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	318 lx (≥ 500 lx) ✗	221 lx	385 lx	0.69 (≥ 0.60) ✓	0.57	WP31

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 113 OFFICE (Emergency light scene)


Anti panic surface (113 OFFICE)



Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (113 OFFICE) Perpendicular illuminance (adaptive) Height: 0.000 m	1.26 lx (≥ 0.50 lx) ✓	3.45 lx	0.37 (≥ 0.025) ✓	AP5

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 113 OFFICE (Light scene 1)


Working plane (113 OFFICE)

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (113 OFFICE)	318 lx	221 lx	385 lx	0.69	0.57	WP31
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✓		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 114 VISITORS (Emergency light scene)

Summary



Ground area	12.61 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.700 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 114 VISITORS (Emergency light scene)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Space	Lighting power density	0.00 W/m ²	–		

Anti panic surface

Properties	E _{min} (Target)	E _{max}	U _d (Target)	Index
Anti panic surface (114 VISITORS) Perpendicular illuminance (adaptive) Height: 0.000 m	1.76 lx (≥ 0.50 lx) ✓	3.44 lx	0.51 (≥ 0.025) ✓	AP6

Notes on planning:


The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Luminaire list

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	–

Building A · GROUND FLOOR · 114 VISITORS (Light scene 1)

Summary



Ground area	12.61 m ²
Reflection factors	Ceiling: 70.0 %, Walls: 50.0 %, Floor: 20.0 %
Maintenance factor	0.76 (fixed)

Clearance height	2.700 m
Mounting height	2.776 m
Height _{Working plane}	0.700 m
Wall zone _{Working plane}	0.000 m

Building A · GROUND FLOOR · 114 VISITORS (Light scene 1)

Summary

Results

	Symbol	Calculated	Target	Check	Index
Working plane	$\bar{E}_{\text{perpendicular}}$	425 lx	$\geq 500 \text{ lx}$	✗	WP30
	$U_o (g_1)$	0.55	≥ 0.60	✗	WP30
Glare valuation ⁽¹⁾	$R_{UG, \text{max}}$	17	≤ 19	✓	
Energy estimation ⁽²⁾	Consumption	151 kWh/a	max. 450 kWh/a	✓	
Space	Lighting power density	4.84 W/m ²	–		
		1.14 W/m ² /100 lx	–		

(1) Based on a rectangular space of 4.760 m x 2.650 m and SHR of 0.25.

(2) Calculated using DIN:18599-4.


Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Luminaire list




pcs.	Manufacturer	Article No.	Article name	R_{UG}	P	Φ	Luminous efficacy
2	ETAP	-	U2B-M210-MI-830-045D (_LTRevAD)	17	30.5 W	4490 lm	147.2 lm/W

Building A · GROUND FLOOR · 114 VISITORS

Luminaire layout plan



Building A · GROUND FLOOR · 114 VISITORS


Luminaire layout plan

Manufacturer	ETAP	P	0.4 W
Article No.	-	P _{Emergency lighting}	0.0 W
Article name	K4A-R30-1M0-30-3L0 (_LTRRevAA)	Φ _{Luminaire}	19 lm
Fitting	1x K1RP03_3, 1x K1RP03_3	Φ _{Emergency lighting}	93 lm
		ELF	100 %

Individual luminaires

X	Y	Mounting height	Luminaire
2.641 m	1.337 m	2.700 m	3

Building A · GROUND FLOOR · 114 VISITORS

Luminaire layout plan

Manufacturer	ETAP	P	30.5 W
Article No.	-	$\Phi_{\text{Luminaire}}$	4490 lm
Article name	U2B-M210-MI-830-045D (_LTRevAD)		
Fitting	1x LED		

Individual luminaires

X	Y	Mounting height	Luminaire
0.867 m	1.379 m	2.776 m	1
3.867 m	1.375 m	2.776 m	2

Building A · GROUND FLOOR · 114 VISITORS


Luminaire list

Φ_{total} 9019 lm	P_{total} 61.4 W	Luminous efficacy 146.9 lm/W	$\Phi_{\text{Emergency lighting}}$ 93 lm
----------------------------------	------------------------------	---------------------------------	---

pcs.	Manufacturer	Article No.	Article name	P	Φ	Luminous efficacy
1	ETAP	-	K4A-R30-1M0-30-3L0 (_LTRevAA)	0.4 W	19 lm	43.2 lm/W
				 0.0 W	93 lm (100 %)	-
2	ETAP	-	U2B-M210-MI-830-045D (_LTRevAD)	30.5 W	4490 lm	147.2 lm/W

Building A · GROUND FLOOR · 114 VISITORS (Emergency light scene)

Calculation objects



Building A · GROUND FLOOR · 114 VISITORS (Emergency light scene)

Calculation objects

Anti panic surfaces


Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (114 VISITORS) Perpendicular illuminance (adaptive) Height: 0.000 m	1.76 lx (≥ 0.50 lx) ✓	3.44 lx	0.51 (≥ 0.025) ✓	AP6

Notes on planning:

The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 114 VISITORS (Light scene 1)

Calculation objects



Building A · GROUND FLOOR · 114 VISITORS (Light scene 1)

Calculation objects


Working planes

Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (114 VISITORS)	425 lx	235 lx	600 lx	0.55	0.39	WP30
Perpendicular illuminance (adaptive)	(≥ 500 lx)			(≥ 0.60)		
Height: 0.700 m, Wall zone: 0.000 m	✗			✗		

Utilisation profile: DIALux presetting (5.26.2 Standard (office))

Building A · GROUND FLOOR · 114 VISITORS (Emergency light scene)

Anti panic surface (114 VISITORS)





Properties	E_{min} (Target)	E_{max}	U_d (Target)	Index
Anti panic surface (114 VISITORS) Perpendicular illuminance (adaptive) Height: 0.000 m	1.76 lx (≥ 0.50 lx) ✓	3.44 lx	0.51 (≥ 0.025) ✓	AP6

Notes on planning:
The emergency lighting scene was calculated without reflection and taking into account the placed furniture.

Building A · GROUND FLOOR · 114 VISITORS (Light scene 1)

Working plane (114 VISITORS)



Properties	$\bar{E}$ (Target)	E_{min}	E_{max}	$U_o (g_1)$ (Target)	g_2	Index
Working plane (114 VISITORS) Perpendicular illuminance (adaptive) Height: 0.700 m, Wall zone: 0.000 m	425 lx (≥ 500 lx) 	235 lx	600 lx	0.55 (≥ 0.60) 	0.39	WP30

Utilisation profile: DIALux presetting (5.26.2 Standard (office))