GUARDIAN GAS SOLUTIONS LLC

Your propane runtime worksheet

Fill in digitally or print and write. Calculations are completed by you; fields do not auto-calculate.

Generator brand + complete model number

Model year / serial range (verify privately)

Manufacturer manual / spec sheet + revision

Fuel-consumption table page / source

01 Confirm the units before calculating

Use your exact model's official manual or specification sheet. Find the LP row, liquid gal/h units and 100% (full-load) column. Model year and product generation can change fuel use.

POUNDS = fuel weight. GALLONS = liquid volume. A 100 lb propane payload is about 23.6 gal at 4.24 lb/gal; density varies. Do not multiply an already-rated propane payload by 80% again. Tank tare weight is excluded.

A. Total water capacity (gal)

B. Current gauge level (%)

C. Planned reserve level (%)

Use water-capacity GALLONS for A, not pounds stamped W-C. Ask your supplier to verify. The 80% fill example leaves expansion space; the reserve is a separate refill-planning assumption.

D. Generator full-load LP use (gal/h)

E. Other appliances, average LP use (gal/h)

Fuel above your chosen reserve

A x (B - C) / 100 = liquid gallons available

Your result

Combined fuel demand

D + E = combined gallons per hour

Your result

Estimated hours to the reserve

Available gallons / combined gal/h = hours

Your result

If B is at or below C, no fuel remains above that reserve: contact your supplier. Estimates use a roughly indicated gauge level and constant assumed demand. Include all tanks only when the installer confirms the system configuration.

Fuel use and operating cost

Use actual manufacturer flow data and actual supplier or utility rates.

02 Propane: gallons and fuel cost

F. LP price ($ per liquid gallon)

G. Planned operating hours

Generator fuel for your planned period

D x G = liquid gallons

Your result

Generator fuel over 24 running hours

D x 24 = liquid gallons per day

Your result

Generator fuel cost per hour

D x F = dollars per hour

Your result

Generator fuel cost for your planned period

D x G x F = dollars

Your result

These cost rows cover the generator only. Add other appliances separately. Include applicable variable fuel/delivery charges in your unit rate. Fixed charges, service, maintenance and costs outside that rate are separate.

03 Natural gas: pipeline usage and fuel cost

H. Full-load NG use (ft3/h)

I. Utility heat value (BTU/ft3)

J. Rate ($/therm OR $/CCF)

Circle or type the rate unit: THERM / CCF

Rate unit used

Volume: H x G = ft3; divide ft3 by 100 = CCF.

Energy: ft3 x I / 100,000 = therms. 1 therm = 100,000 BTU.

Cost: therms x $/therm OR CCF x $/CCF. Match your bill.

Period volume (ft3 or CCF)

Period therms (if needed)

Period NG fuel cost ($)

Normal adequate pipeline service avoids onsite refills. Utility interruptions, meter capacity, piping, pressure and generator maintenance still matter. CCF and therms are different units.

Worked example + ready checklist

Keep this with your generator documents and confirm the refill plan with your propane supplier.

04 Try the math, then compare your answer

EXAMPLE ONLY: 500 gal water capacity; start at 80%; plan to stop at a 20% reserve; generator uses 3.95 gal/h at full load; no other appliances included.

500 x (80 - 20) / 100 = 300 liquid gallons above reserve

300 / 3.95 = 75.9 hours, or about 3.2 days

The theoretical fill-to-zero inventory is 400 / 3.95 = 101.3 hours. That is not a recommended operating target or a guarantee of deliverable runtime.

Now start at 40%: 500 x (40 - 20) / 100 = 100 gal

100 / 3.95 = 25.3 hours to the same example reserve.

COST EXAMPLES: At $3/gal, 3.95 gal/h costs $11.85/h or $284.40 per 24 running hours. At 316 ft3/h NG, 1,000 BTU/ft3 and $1.50/therm: 75.84 therms/day and $113.76/day. These are hypothetical rates; LP and NG electrical ratings can differ.

05 Before an outage

- [ ] I verified the exact generator model/year and full-load fuel use in its official document.
- [ ] I confirmed tank capacity units and current level; I kept fill limit and reserve separate.
- [ ] I included shared appliances and asked the installer about vapor delivery at low levels.
- [ ] I confirmed refill trigger, delivery lead time and outage demand with my supplier.

Propane supplier / phone

Refill trigger / delivery lead time

Avoid running out: the generator and shared appliances can stop; standing pilots may go out. After a run-out, call your propane supplier. A qualified professional must check for leaks and safely restore service. Do not turn tank gas back on or relight appliances yourself.

Planning worksheet only. Gauge accuracy, weather, vaporization, fuel pressure, piping, regulators, maintenance and changing loads affect operation. The 20% reserve is an example, not a rule requirement. This sheet does not replace the installer's signed maximum-load disclosure required by Florida Rule 5J-20.052, effective November 17, 2026.

References: manufacturer model manual; propane.com/safety; flrules.org (5J-20.052).

Prepared November 11, 2026. Suggested form review when equipment or fuel storage changes.