

prevention device. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

Please call this office at 508-362-6498 should you have any questions regarding cross connections and backflow.

For additional information please see the following web sites:

<https://www.epa.gov/laws-regulations/summary-safe-drinking-water-act>

Massachusetts Department of Environmental Protection Cross Connection Regulations:

<http://www.mass.gov/eea/agencies/massdep/water/drinking/water-systems-ops.html#8>

OWNERS' RESPONSIBILITY

CROSS CONNECTION CONTROL

REDUCED PRESSURE BACKFLOWPREVENTERS AND DOUBLE CHECK VALVE

ASSEMBLIES

TESTING AND REPAIR POLICY

In accordance with Drinking Water Regulations of MASS 310 CMR 22.22 Sec. 13 (D), all installations of reduced pressure backflow preventer assemblies shall be tested semi-annually by the supplier of water. In addition, double check valve assemblies shall be tested annually by the supplier of water. All tests must be conducted by a certified Backflow Prevention Device tester in accordance with the regulated test procedures. The result of these tests must be recorded on the Standard Inspection and Maintenance Report Form. This form must be completely filled out (including the cross connection ID# from the DEP permit), signed and dated by the owner and the certified tester. All copies of the Inspection and Maintenance Report Forms shall be maintained by the owner. The owner or owner's agent must maintain on the premises a spare parts kit and any special tools required for removal and reassembling of devices which are to be tested. The presence of these materials must be recorded on the Inspection and Maintenance Report Form. Devices failing a test or found defective shall be overhauled, repaired or replaced by a plumber or a mechanical fire sprinkler contractor. They must be licensed by the Commonwealth of Massachusetts and re-inspected within two weeks of the initial inspection date.

Thank you for your cooperation in protecting the The Barnstable Fire District water supply. If you desire any additional information, please call us at 508-362-6498.