




ELEVATION, SIDE 6



SECTION A-A, SIDE 4



SECTION B-B, SIDE 5



SECTION C-C  
1:25

A				LK			
FIRST ISSUE				2026.01.08			
REV.:				INIT.:			
DESCRIPTION:				DATE:			
CAST IN PARTS				CONCRETE DETAILS:			
MARK	SIDE	NO.	DESCRIPTION, DETAILS	CONCRETE:	C40/50	SIDE	SURFACE
A	-	-	-	EXPOSURE CLASS:	XC4, XF2, DC-42	①	Steel Form
B	6	4	STARCON LIFTING EYES 5T-95	RECEIPT:	-	②	Steel Form
C	6	1	SSRCP1675 (CERTEX)	KONTROLKLASSE(DK):	-	③	Steel Form
D	3	3	NAILING BLOCK Ø21/25x25mm	WALL PANEL WEIGHT:	3352 Kg	④	Steel Form
E	3-4	10	PVC-DUCT Ø23/25mm	TOLERANCES:	According to A-Consult Quality Manual	⑤	Steel Form
F	-	-	-	DETAIL DRAWING:	-	⑥	Steel Float Form
G	-	-	-	GENERAL NOTES:	-	HOLE	Steel Form
H	1-6	1	DN 900 FLANGE	RECESS	Steel Form	RECESS	Steel Form
I	-	-	-	ALL DIMENSIONS IN MILLIMETRES. NO DIMENSIONS ARE TO BE SCALED FROM THE DRAWING. THE POST DRILLING OF PRECAST PANELS FOR PIPE CONNECTIONS OR BOLT FIXING IS PERMITTED, HOWEVER THIS WORK MUST BE CARRIED OUT WITH SPECIAL ATTENTION BEING PAID TO THE LOCATION OF THE POST TENSIONING TENDONS WITHIN THE STRUCTURE. ENSURING THAT THE OUTER DIAMETER OF ANY HOLE/APERTURE IS NO LESS 75 MM AWAY FROM THE OUTER DIAMETER OF ANY HOLE/APERTURE IS NO LESS 75 MM AWAY FROM THE OUTER DIAMETER OF ANY POST TENSIONING TENDONS. TENDON LOCATION TO BE MEASURED FROM TOP OF WALL DRAWING FOR LOCATION PLEASE REFER TO 'AS BUILT' DRAWINGS AND ANCHOR LOCATION IN BUTTRESS(ES) FURTHER GUIDANCE CAN BE SOUGHT FROM A-CONSULT.			
J	-	-	-				
K	-	-	-				
L	-	-	-				
M	-	-	-				
REMARKS:							

Client info:

MWHT

Date Plotted: 2026.01.08 Made by: LK Check by: SGK Scale: NTS

Project no.: 430773 Knapp Mill  
Constuction place address:

STATUS  
FOR APPROVAL

Description:  
CONCRETE LAYOUT  
WALL PANEL - TYPE 04  
TANK TYPE: N4500-32-2B/2

Drg.no.: AQ430773-00-45-32-1105 A  
Issue:

A-CONSULT Ltd.  
The Barn  
Manor Business Park  
East Drayton  
Retford DN22 0LG  
Tel.: +44(0)1777249444  
Fax: +44(0)1777248452  
e-mail: info@aconsult.co.uk  
http:// www.aconsult.co.uk

