


ANSWERS

2023 JOURNEYMAN OPEN BOOK EXAM #4 - ANSWERS

1. (c) qualified	Definitions 100
2. (a) 50 amps	210.8(F)
3. (d) in a damp or wet location	334.12(B)(4)
4. (c) 18"	Table 300.5(A) Column 1
5. (d) listed tamper-resistant	406.12(1)
6. (c) 36"	422.16(B)(1)(1)
7. (d) orange triangle	406.3(E)
8. (d) neutral	210.4(C)
9. (a) ground fault	Definition 100
10. (c) be required	590.4(G)
11. (d) 12 feet	680.43(B)(1)(a)
12. (b) branch circuit	210.12(A)(1)
13. (a) labeled	DEF 100
14. (d) weather resistant	406.9(B)
15. (d) 85%	Table 220.54
16. (d) suitable	430.8
17. (d) wet, dry, or corrosive	340.10(3)
18. (c) 18"	312.5(C) ex.1
19. (a) #6 or larger screw	314.27(D) ex.
20. (d) flame-retardant	392.100(F)
21. (d) readily accessible	210.8(A) ex.1
22. (a) 83%	310.12(A)
23. (a) residential garages	210.12(B)(C)
24. (c) 10 feet	250.52(A)(2)
25. (b) STOOW	Table 400.4 and Note 9



**Hi Lite each answer
in your Code Book**



After completing the exam, grade yourself by counting the correct number of questions and divide by the number of questions answered.

Example: 19 correct answers ÷ 25 questions = 76%.



Time limit 60 minutes ÷ 25 questions = 2.4 minutes per question!