

2023

JOURNEYMAN

OPEN

BOOK

EXAM #7



25 QUESTIONS

TIME LIMIT - 1 HOUR

TIME SPENT **MINUTES**

SCORE **%**

JOURNEYMAN OPEN BOOK EXAM #7 25 Questions One Hour Time Limit

1. Premises wiring shall not be ____ connected to a supply system unless the latter contains, for any grounded conductor of the interior system, a corresponding conductor that is grounded.

(a) directly (b) permanently (c) electrically (d) magnetically

2. ____ lists the direct-current resistance of conductors per kFT.

(a) Table 8, Chapter 9 (b) Table 9, Chapter 9 (c) Table 5, Chapter 9 (d) Table 4, Chapter 9

3. Electrical equipment, such as switchboards, switch gear, panel boards, industrial control panels, meter socket enclosures, and motor control centers, that is in other than ____, and is likely to require examination, adjustment, servicing, or maintenance while energized, shall be field or factory marked to warn qualified persons of potential electric arc flash hazards.

(a) locked rooms (b) schools (c) testing areas (d) dwelling units

4. Where simultaneous biplane examinations are undertaken with the X-ray units, the supply conductors and overcurrent protection devices shall be 100% of the ____ demand rating of each X-ray unit.

(a) continuous (b) non-continuous (c) instantaneous (d) momentary

5. _____. The highest level that water can reach before it spills out.

(a) Over Flow (b) Escape Limit (c) Datum Level (d) Maximum Water Level

6. Flexible cord used in extension cords made with separately listed and installed components shall be permitted to be supplied by a branch circuit in accordance with the following: 20 ampere circuits ____ and larger.

(a) #24 (b) #16 (c) #14 (d) #12

7. Selective coordination shall not be required between two overcurrent devices located in series if no ____ are connected in parallel with the downstream device.

(a) fuses (b) disconnects (c) devices (d) loads

8. Electrical equipment provided with ____ openings shall be installed so that walls or other obstructions do not prevent the free circulation of air through the equipment.

(a) ventilating (b) vented (c) filtered (d) gated

9. The feeder or branch circuit disconnecting means shall have a rating not less than the ____ load to be served.

(a) actual (b) minimum (c) calculated (d) maximum

10. Wiring located above heated ceilings shall be spaced not less than ____ above the heated ceiling.

(a) 2" (b) 3" (c) 4" (d) 6"

11. Conductors of branch circuits supplying more than one receptacle for cord-and-plug connected portable tools shall have an ampacity ____ the rating of the branch circuit.

(a) equal to (b) of not less than (c) greater than (d) 125%

12. Ferrous raceways and fittings protected from corrosion solely by ____ shall be permitted only indoors and in occupancies not subject to severe corrosive influences.

(a) enamel (b) silicone (c) galvanize (d) rubber

13. Table ____ lists the minimum cover requirements for underground wiring methods 1000 volts or less.

(a) 312.6(A) (b) 310.104 (c) 300.19(A) (d) 300.5(A)

14. Table ____ lists metric designators and trade sizes for conduit, tubing, etc.

(a) 314.16(A) (b) 355.44 (c) 384.22 (d) 300.1(C)

15. The temperature correction and adjustment factors shall be permitted to be applied to the ampacity for the temperature rating of the conductor, if the corrected and adjusted ampacity does not exceed the ampacity for the temperature rating of the ____ in accordance with the provisions of 110.14(C).

(a) termination (b) connector (c) enclosure (d) device

16. A sign shall be placed at the service entrance equipment, indicating type and ____ of each onsite emergency power source.

(a) voltage (b) kW (c) hours of fuel (d) location

17. Separately installed pressure connectors shall be used with conductors at the ampacities not exceeding the ampacity at the listed and ____ temperature rating of the conductor.

(a) marked (b) tested (c) identified (d) certified

18. The ____ number of branch circuits shall be determined from the total calculated load and the size or rating of the circuits used.

(a) minimum (b) maximum (c) total (d) largest

19. Internal parts of electrical equipment, including busbars, wiring terminals, insulators, and other surfaces, shall not be damaged or contaminated by foreign materials such as paint, plaster, cleaners, abrasives, or ____

(a) moisture (b) organic residues (c) corrosive residues (d) dust and dirt

20. A ____ is a portion of a sign that may provide protection from the weather but is not an electrical enclosure.

(a) Section Sign (b) Sign Body (c) Sign Gutter (d) Sign Enclosure

21. Where a panelboard is supplied through a transformer, the overcurrent protection required by 408.36 shall be located on the ____ side of the transformer.

(a) supply (b) primary (c) secondary (d) high leg

22. Open equipment doors must not impede access to or from working space required in 110.26. If the door(s) reduce(s) the access to less than ____ inches wide and 6 ¹/₂ feet high, access is considered impeded.

(a) 18 (b) 24 (c) 30 (d) 36

23. Terminations on ____ cables rated over 600 volts, nominal, shall be accessible only to authorized and qualified personnel.

(a) portable (b) fixed (c) flexible (d) nonmetallic

24. A switchboard, switchgear, or panelboard containing a 4-wire, ____ - connected system where the midpoint of one phase winding is grounded shall be legibly and permanently marked as follows: "Caution ____ Phase Has ____ Volts to Ground."

(a) series (b) wye (c) delta (d) grounded

25. Where a building or structure has any combination of feeders, branch circuits, or services passing through it or supplying it, a permanent plaque or directory shall be installed at each feeder and branch circuit ____ location denoting all other services, feeders, or branch circuits supplying that building or structure or passing through that building or structure and the area served by each.

(a) disconnect (b) connection (c) termination (d) entrance

