

Journeyman Final Exam Answers

Journeyman Final Exam #5 - ANSWERS

1. (b) release-type adhesive
 2. (b) 194 degrees F
 3. (b) MC
 4. (a) transition assembly
 5. (b) 15 amps
 6. (b) 2'
 7. (c) bottom shield
 8. (a) #18
 9. (d) I, II and III
 10. (b) II only
 11. (b) 2 crossings
 12. (c) 86°F
 13. (a) 7 times
 14. (d) 20 pounds
 15. (a) white
 16. (b) 12"
 17. (a) it may be used in hazardous locations
 18. (d) 60°C
 19. (c) NMC
 20. (d) all of these
 21. (b) appliances
 22. (b) USE
 23. (b) twelve times
 24. (b) as service-entrance cable
 25. (d) interior wiring in wet, corrosive locations
 26. (c) 122°F
 27. (d) 12"
 28. (c) for the support of luminaires
 29. (b) in exposed indoor locations
 30. (c) 12 1/2"
 31. (d) 20'
 32. (d) #10
 33. (b) clearly and durably identified
 34. (d) steel electrical metallic tubing
 35. (c) manually
- 324.41 - FCC flat conductor cable
 - 320.80(A) - Armored cable-AC
 - DEF 100- Metal Clad Cable-MC
 - 324.40(D) - FCC flat conductor cable
 - 322.56(B) - Flat Cable Assemblies-FC
 - 320.30(D)(2) - Armored Cable-AC
 - DEF 100 - Bottom Shield
 - 330.104 - Metal Clad Cable-MC
 - 324.40(A) - FCC flat conductor cable
 - 322.10(1) - Flat Cable Assemblies-FC
 - 324.18 - FCC flat conductor cable
 - 324.10(F) - FCC flat conductor cable
 - 330.24(B) - Metal Clad Cable-MC
 - 326.112 - Integrated Gas Spacer cable-IGS
 - 322.120(B) - Flat Cable Assemblies-FC
 - 334.30 - Nonmetallic sheath cable-NM
 - 332.10(7) - Mineral-Insulated-MI cable
 - 340.80 - Underground Feeder-UF cable
 - 334.116(B) - Nonmetallic sheath cable-NM
 - 332.104 & .108 & .116 - MI cable
 - 338.10(B)(3) - Service-Entrance cable -SE
 - DEF 100 - USE cable
 - 336.24 - Power and Control Tray cable-TC
 - 334.12(A)(3) - Nonmetallic sheath cable-NM
 - 340.10(3) - Underground Feeder-UF cable
 - 362.12(3)-Electrical Nonmetallic Tubing-ENT
 - 350.30(A) - Liquidtight Flex Metal - LFMC
 - 352.12(B) - Rigid PVC conduit-PVC
 - 354.12(1) -Nonmetallic Underground Conduit
 - T. 360.24(A)- Flexible Metallic Tubing-FMT
 - T. 344.30(B) - Rigid Metal Conduit-RMC
 - T. 348.22 - Flexible Metal Conduit-FMC
 - 344.120 - Rigid Metal Conduit-RMC
 - 358.14 - Electrical Metallic Tubing-EMT
 - 362.24(A)Electrical Nonmetallic Tubing-ENT

Half way through the exam

(Answers continued next page)

Journeyman Final Exam Answers

Journeyman Final Exam #5 - ANSWERS

- | | |
|--|--|
| 36. (a) above ground in direct sunlight | 352.100 - Rigid PVC conduit-PVC |
| 37. (d) any of these | 358.100 - Electrical Metallic Tubing-EMT |
| 38. (b) where subject to physical damage | 350.12 - Liquidtight Flex Metal - LFMC |
| 39. (d) 2000 amps csa 4"x.5" = 2 x 1000a | 366.23(A) - Auxiliary Gutters |
| 40. (b) 8" | 382.30(A) - Nonmetallic Extensions |
| 41. (c) in dry locations | 380.10 - Multioutlet Assembly |
| 42. (b) a header | 372.18(A) - Cellular Concrete Floor Raceways |
| 43. (d) 75% | 376.56(A) - Metal Wireways |
| 44. (c) 50 feet | 368.17(B) ex. - Busways |
| 45. (d) 1/4" | 378.44 - Nonmetallic Wireways |
| 46. (d) combined csa cannot exceed 45% | 374.22 - Cellular Metal Floor Raceways |
| 47. (a) 3 feet | 370.30(B) - Cablebus |
| 48. (b) 1" | 366.100(E) - Auxiliary Gutters |
| 49. (d) 2" | 382.15(A) - Nonmetallic Extensions |
| 50. (a) vapor seal | 368.234(A) - Busways |
| 51. (a) exposed | 370.10(1) - Cablebus |
| 52. (d) at least 1/3 the amp rating of the larger bus. | 368.17(B) ex. - Busways |
| 53. (c) 10 feet | 384.30(A) - Strut-Type Channel Raceway |
| 54. (d) Article 395 | 395.30(A) - Outdoor Overhead over 1000v |
| 55. (a) 300 volts | 388.12(3) - Surface Nonmetallic Raceways |
| 56. (a) 75% | 386.56 - Surface Metal Raceways |
| 57. (d) 95% | 392.80(A)(1)(b) - Cable Trays |
| 58. (b) one-half | 398.30(D) - Open Wiring on Insulators |
| 59. (b) 1" | 390.15(B) - Underfloor Raceways |
| 60. (b) hoistways | 386.12(4) - Surface Metal Raceways |
| 61. (c) 7 times | 330.24(B) - Metal Clad Cable-MC |
| 62. (d) listed for wet locations | 344.42(A) - Rigid Metal Conduit-RMC |
| 63. (a) 6 feet | 368.10(C)(2)(a) - Busways |
| 64. (d) 12" | 470.11 - Resistors and Reactors |
| 65. (d) 15 feet | 376.30(B) - Metal Wireways |
| 66. (c) Table 1 | 356.22 - Liquidtight Flex Nonmetallic - LFNC |
| 67. (c) 20 feet | 342.30(B)(3)-Intermediate Metal Conduit-IMC |
| 68. (b) 2" | 344.10(C) - Rigid Metal Conduit-RMC |
| 69. (d) 54" | 334.30(B)(2) - Nonmetallic sheath cable-NM |
| 70. (a) 3 feet | Table 352.30(B) -Rigid PVC |
-