

2023

JOURNEYMAN

OPEN

BOOK

EXAM #5



25 QUESTIONS

TIME LIMIT - 1 HOUR

TIME SPENT **MINUTES**

SCORE **%**

JOURNEYMAN OPEN BOOK EXAM #5 25 Questions One Hour Time Limit

1. Portable structures for fairs, carnivals and similar events shall not be located under or within a space 15 feet horizontally of conductors operating in excess of ____ volts.

- (a) 1000 (b) 600 (c) 300 (d) 250

2. Which of the following is not required to be marked on the name plate of a transformer?

- (a) Frequency (b) Amount of insulating liquid
(c) AWG size (d) Clearance for ventilating openings

3. Temporary electric power and lighting installations shall be permitted for a period not to exceed ____ days for decorative holiday lighting and similar purposes.

- (a) 25 (b) 50 (c) 60 (d) 90

4. ____ is permitted in the dedicated electrical space above a panelboard.

- (a) Water piping (b) Leak protection (c) Sprinkler protection (d) Air-conditioning ducts

5. Grounded conductors of circuits with parallel conductors in a panelboard shall be permitted to terminate in a single terminal if the terminal is ____ for connection of more than one conductor.

- (a) identified (b) listed (c) recognized (d) suitable

6. A household electric range with a rating of 8 3/4 kW or more, the minimum branch circuit rating shall be ____ amps.

- (a) 35 (b) 40 (c) 45 (d) 50

7. The phase having the higher voltage to ground is ____, when an industrial control panel is supplied from a 3 ϕ , 4-wire, delta connected electrical system.

- (a) permitted to be any phase on a delta connection
(b) required to be the "C" phase on a delta connection
(c) required to be the "B" phase on a delta connection
(d) required to be the "A" phase on a delta connection

8. The maximum ampere rating permitted for a 125 volt, single-phase, receptacle outlet having a cord-and-plug connected motor load that does not have individual overload protection is ____.

- (a) 15 amps (b) 20 amps (c) 25 amps (d) 30 amps

9. Service equipment at carnivals and fairs, shall not be installed in a location that is accessible to unqualified persons, unless the equipment ____.

- (a) is installed at a height over 6 feet (b) is provided with GFCI protection
(c) is provided with AFCI protection (d) is lockable

10. Where an NM cable is installed parallel to framing members, the cable shall be installed so that the nearest edge of the cable is not less than ____ from the nearest edge of the framing member.

- (a) 1/2" (b) 1" (c) 1 1/4" (d) 1 1/2"

11. Flexible cords shall be used only in continuous lengths, without splices, other than splices for the repair of hard-service cord or ____ cord under certain conditions.

- (a) junior hard-service (b) lamp (c) tinsel (d) portable

12. Feeder and branch circuit conductors that are installed on piers shall be provided ground-fault protection not exceeding ____.

- (a) 30 mA (b) 25 mA (c) 20 mA (d) 18 mA

13. Cartridge fuses in circuits of any voltage, and all fuses in circuits over ____ volts to ground, shall be provided with a disconnecting means on their supply side so that each circuit containing fuses can be independently disconnected from the source of power.

- (a) 150 (b) 125 (c) 120 (d) 60

14. Overhead conductors not over 1,000 volts pass over a track rails of railroads, they shall have a minimum clearance of not less than ____ feet above finished grade.

- (a) 12 (b) 15 (c) 18 (d) 24 1/2

15. Outdoor mobile home disconnecting means shall be installed so the bottom of the enclosure containing the disconnecting means is not less than ____ above finished grade or working platform.

- (a) 24" (b) 36" (c) 48" (d) 60"

16. For dwelling units, GFCI protection shall be provided for personnel in ____.

I. bathrooms II. crawl spaces III. basements

- (a) I only (b) I and II only (c) I and III only (d) I, II, and III

17. Personnel doors where equipment rated 800 amperes or more that contains overcurrent devices, is installed and there is a personnel door(s) intended for entrance to and egress from the working space less than ____ feet from the nearest edge of the working space.

(a) 12 (b) 15 (c) 20 (d) 25

18. Communications wires and cables and CATV type coaxial cables shall have a vertical clearance of not less than ____ from all points of roofs which they pass.

(a) 18" (b) 36" (c) 6 feet (d) 8 feet

19. The installation and wiring of separately derived systems operating at 120 volts line-to-line and ____ volts to ground for sensitive electronic equipment.

(a) 30 (b) 50 (c) 60 (d) 85

20. Installation of direct buried cables in an area that is subject to movement by frost or settlement of the soil shall be ____.

(a) heated electrically (b) of XHHW only (c) on running boards (d) placed with "S" loops

21. Grounding electrodes of pipe or conduit shall not be smaller than trade size ____ and, where of steel, shall have the outer surface galvanized or otherwise metal-coated for corrosion protection.

(a) 1/2" (b) 3/4" (c) 1" (d) 1 1/4"

22. All switchboards, switchgear, and panelboards supplied by a ____ in other than one or two-family dwellings shall be permanently marked to indicate each device or equipment where the power originates.

(a) feeder (b) service (c) generator (d) alternator

23. Where exposed NM cable passes through a floor, the NM cable shall be protected from damage by an approved means extending at least ____ above the floor.

(a) 18" (b) 16" (c) 8" (d) 6"

24. PVC conduit shall be securely fastened within ____ of each outlet, junction device, conduit body, or other conduit termination box.

(a) 24" (b) 30" (c) 36" (d) 48"

25. Grounding conductors and bonding jumpers shall **not** be connected by ____.

(a) listed pressure connectors (b) exothermic welding process
(c) terminal bars (d) sheet metal screws

