

## GETTING STARTED GUIDE

# PXIe-4135

## Single-Channel Precision System Source Measure Unit (SMU)



**Note** Before you begin, install and configure your chassis and controller.

This document explains how to install, configure, and test the PXIe-4135. The PXIe-4135 is a single-channel precision system SMU.

To access PXIe-4135 documentation, navigate to **Start»All Programs»National Instruments»NI-DCPower»Documentation**.



**Caution** Do not operate the PXIe-4135 in a manner not specified in this document. Product misuse can result in a hazard. You can compromise the safety protection built into the product if the product is damaged in any way. If the product is damaged, return it to NI for repair.

## Contents

|   |    |
|---|----|
| Electromagnetic Compatibility Guidelines.....                 | 2  |
| Safety Guidelines for Hazardous Voltages.....                 | 2  |
| Verifying the System Requirements.....                        | 2  |
| Unpacking the Kit.....  | 3  |
| Kit Contents.....   | 4  |
| Other Equipment.....  | 4  |
| Preparing the Environment.....                                | 5  |
| Safety.....   | 5  |
| Installing the Software.....                                  | 5  |
| System Safety Guidelines.....                                 | 6  |
| Safety Guidelines for System Design and Implementation.....   | 6  |
| Safety Guidelines for System Operation.....                   | 7  |
| Installing the PXIe-4135.....                                 | 8  |
| Configuring the PXIe-4135 in MAX.....                         | 10 |
| Testing the Safety Interlock.....                             | 11 |
| Testing with an Application Development Environment.....      | 11 |
| Testing with the NI-DCPower Soft Front Panel.....             | 11 |
| Programming the PXIe-4135.....                                | 12 |
| Troubleshooting.....  | 13 |
| What Should I Do if the PXIe-4135 Doesn't Appear in MAX?..... | 13 |
| Why Is the ACCESS LED Off When the Chassis Is On?.....        | 13 |
| Where To Go Next.....   | 14 |
| Worldwide Support and Services.....                           | 14 |

# Electromagnetic Compatibility Guidelines

---

This product was tested and complies with the regulatory requirements and limits for electromagnetic compatibility (EMC) stated in the product specifications. These requirements and limits provide reasonable protection against harmful interference when the product is operated in the intended operational electromagnetic environment.

This product is intended for use in industrial locations. However, harmful interference may occur in some installations, when the product is connected to a peripheral device or test object, or if the product is used in residential or commercial areas. To minimize interference with radio and television reception and prevent unacceptable performance degradation, install and use this product in strict accordance with the instructions in the product documentation.

Furthermore, any changes or modifications to the product not expressly approved by National Instruments could void your authority to operate it under your local regulatory rules.



**Caution** To ensure the specified EMC performance, operate this product only with shielded cables and accessories connected to the LO/Sense LO, Output HI, and Sense HI connectors. Only twisted, shielded pair cable (i.e. Belden 83321E) should be used to connect the signals of the LO/Sense LO connector. Any compatible unshielded twisted-pair cable may be used for the safety interlock connector.



**Caution** To ensure the specified EMC performance, the length of all I/O cables must be no longer than 3 m (10 ft).

## Safety Guidelines for Hazardous Voltages

---

If hazardous voltages are connected to the device, take the following precautions. A hazardous voltage is a voltage greater than 42.4 Vpk voltage or 60 VDC to earth ground.



**Caution** This module is rated for Measurement Category I. It is intended to carry signal voltages no greater than 250 VDC. This module can withstand up to 500 VDC impulse voltage. Do not use this module for connection to signals or for measurements within Categories II, III, or IV. Do not connect to MAINS supply circuits (for example, wall outlets) of 115 VAC or 230 VAC.



**Caution** Isolation voltage ratings apply to the voltage measured between any channel pin and the chassis ground. When operating channels in series or floating on top of external voltage references, ensure that no terminal exceeds this rating.

## Verifying the System Requirements

---

To use the NI-DCPower instrument driver, your system must meet certain requirements.

Refer to the product readme, which is available on the driver software media or online at [ni.com/manuals](http://ni.com/manuals), for more information about minimum system requirements, recommended system, and supported application development environments (ADEs).

## Unpacking the Kit

---



**Caution** To prevent electrostatic discharge (ESD) from damaging the device, ground yourself using a grounding strap or by holding a grounded object, such as your computer chassis.

1. Touch the antistatic package to a metal part of the computer chassis.
2. Remove the device from the package and inspect the device for loose components or any other sign of damage.



**Caution** Never touch the exposed pins of connectors.




**Note** Do not install a device if it appears damaged in any way.

3. Unpack any other items and documentation from the kit.

Store the device in the antistatic package when the device is not in use.

# Kit Contents

**Figure 1. NI 4135 Kit Contents**



- |  |   |
|--|---|
| 1. PXIe-4135 Precision System SMU Device | 4. Driver Software DVD                                |
| 2. LO/Sense LO Output Connector Assembly | 5. NI PXIe-4135 Getting Started Guide (this document) |
| 3. Safety Interlock Input Connector      | 6. Maintain Forced-Air Cooling Note to Users          |

## Other Equipment

There are several required items not included in your device kit that you need to operate the PXIe-4135. Your application may require additional items not included in your kit to install or operate your device.

### Required Items

- A PXI Express chassis and chassis documentation. For more information about compatible chassis options, refer to [ni.com](http://ni.com).
- A PXI Express embedded controller or MXI controller system that meets the system requirements specified in this guide and chassis documentation.
- One or more triaxial cable assemblies.

### Optional Items

- NI screwdriver (part number 781015-01).

# Preparing the Environment

---

Ensure that the environment you are using the PXIe-4135 in meets the following specifications.

## Operating Environment

|                                   |  |
|-----------------------------------|--|
| Ambient temperature range         | 0 °C to 55 °C (Tested in accordance with IEC 60068-2-1 and IEC 60068-2-2. Meets MIL-PRF-28800F Class 3 low temperature limit and MIL-PRF-28800F Class 2 high temperature limit.) |
| Relative humidity range           | 10% to 90%, noncondensing (Tested in accordance with IEC 60068-2-56.)  |
| Storage ambient temperature range | -40 °C to 70 °C (Tested in accordance with IEC 60068-2-1 and IEC 60068-2-2.)   |
| Maximum altitude                  | 2,000 m (800 mbar) (at 25 °C ambient temperature)  |
| Pollution Degree                  | 2  |

Indoor use only.



**Note** Refer to the device specifications on [ni.com/manuals](https://ni.com/manuals) for complete specifications.

# Safety

---



**Caution** Always refer to the specifications document for your device before connecting signals. Failure to observe the specified maximum signal ratings can cause shock, a fire hazard, or damage to the devices connected to the PXIe-4135. NI is not liable for any damage or injuries resulting from incorrect signal connections.

# Installing the Software

---

You must be an Administrator to install NI software on your computer.

1. Install an ADE, such as LabVIEW or LabWindows™/CVI™.
2. Insert the driver software media into your computer. The installer should open automatically.

If the installation window does not appear, navigate to the drive, double-click it, and double-click `autorun.exe`.

3. Follow the instructions in the installation prompts.



**Note** Windows users may see access and security messages during installation. Accept the prompts to complete the installation.

4. When the installer completes, select **Restart** in the dialog box that prompts you to restart, shut down, or restart later.

## System Safety Guidelines

---

### Safety Guidelines for System Design and Implementation

The PXIe-4135 is capable of generating hazardous voltages and working within hazardous voltage systems. It is the responsibility of the system designer, integrator, installer, maintenance personnel, and service personnel to ensure the system is safe during use.


- Ensure operators cannot access the PXIe-4135, cables, the device under test (DUT), or any other instruments in the system while hazardous voltages are present.
- Operator access points can include, but are not limited to, guards, gates, sliding doors, hinge doors, lids, covers, and light curtains.
- If using a test fixture enclosure, ensure that it is properly connected to safety ground.
- Ensure that the PXIe-4135 is properly secured to the chassis using the two front panel mounting screws.
- Double insulate all electrical connections that are accessible by an operator. Double insulation ensures protection if one layer of insulation fails. Refer to IEC 61010-1 for specific insulation requirements.

### Safety Interlock System Integration

The PXIe-4135 includes a safety interlock circuit that places the outputs of the SMU device in a safe state, regardless of the programmed state of the device.

- Do not short the safety interlock pins directly at the connector under any circumstances.
- Confirm on a regular basis that the safety interlock is functioning by performing a safety interlock test.
- Install mechanical detection switches that open the safety interlock circuit when the operator attempts to access the test fixture, disabling the hazardous voltage ranges of the instrument.
- Ensure the mechanical detection switches close the safety interlock circuit only when the operator has properly closed all entry points to the test fixture enclosure, enabling hazardous voltage ranges on the instrument.

**Figure 2. System Level Connection, Typical**



## Related Information

*For more information about the Safety Interlock, refer to the [NI DC Power Supplies and SMUs Help](#).*

*[Testing the Safety Interlock](#) on page 11*

## Mechanical Detection Switch Recommendations

- Use high-reliability, fail-safe, normally open mechanical detection switches on all access points to the test fixture enclosure.
- Use two normally open switches wired in series so that a single switch failure does not compromise safety protections.
- Isolate switches so the operator cannot trigger or bypass the switches without the use of a tool.
- Ensure the switches' certifications meet your test application requirements. NI recommends UL-certified safety switches to ensure reliability.
- Install the switches in accordance with the switch manufacturer specifications.
- Test the switches periodically to ensure proper implementation and reliability.

## Safety Guidelines for System Operation



**Caution** Hazardous voltage of up to the maximum voltage of the device may appear at the output terminals if the safety interlock terminal is closed. Open the safety interlock terminal when the output connections are accessible. With the safety interlock terminal open the output voltage level/limit is limited to  $\pm 40$  VDC, and

protection will be triggered if the voltage measured between the device HI and LO terminals exceeds  $\pm(42 \text{ Vpk} \pm 0.4 \text{ V})$ .



**Caution** Do not apply voltage to the safety interlock connector inputs. The interlock connector is designed to accept passive normally open contact closure connections only.

To ensure a system containing the PXIe-4135 is safe for operators, components, or conductors, take the following safety precautions:

- Ensure proper warnings and signage exists for workers in the area of operation.
- Provide training to all system operators so that they understand the potential hazards and how to protect themselves.
- Inspect connectors, cables, switches, and any test probes for any wear or cracking before each use.
- Before touching any of the connections to the high terminal or high sense on the PXIe-4135, discharge all components connected to the measurement path. Verify with a DMM before interaction with connections.

## Installing the PXIe-4135




**Caution** To prevent damage to the device caused by ESD or contamination, handle the device using the edges or the metal bracket.

1. Ensure the AC power source is connected to the chassis before installing the modules.

The AC power cord grounds the chassis and protects it from electrical damage while you install the modules.

2. Power off the chassis.
3. Inspect the slot pins on the chassis backplane for any bends or damage prior to installation. Do not install a module if the backplane is damaged.
4. Remove the black plastic connectors from all the captive screws on the module front panel.
5. Identify a supported slot in the chassis. The following figure shows the symbols that indicate the slot types.

**Figure 3. Chassis Compatibility Symbols**




- |                                       |                                   |
|---------------------------------------|-----------------------------------|
| 1. PXI Express System Controller Slot | 4. PXI Express System Timing Slot |
| 2. PXI Peripheral Slot                | 5. PXI Express Peripheral Slot    |
| 3. PXI Express Hybrid Peripheral Slot |                                   |



PXIe-4135 modules can be placed in PXI Express peripheral slots, PXI Express hybrid peripheral slots, or PXI Express system timing slots.

6. Touch any metal part of the chassis to discharge static electricity.
7. Ensure that the ejector handle is in the unlatched (downward) position.
8. Place the module edges into the module guides at the top and bottom of the chassis. Slide the device into the slot until it is fully inserted.

**Figure 4. Module Installation**



1. Chassis
2. Hardware Module
3. Ejector Handle in Down (Unlatched) Position

9. Latch the module in place by pulling up on the ejector handle.
10. Secure the device front panel to the chassis using the front-panel mounting screws.



**Note** Tightening the top and bottom mounting screws increases mechanical stability and also electrically connects the front panel to the chassis, which can improve the signal quality and electromagnetic performance.

11. Cover all empty slots using filler panels or slot blockers to maximize cooling air flow.
12. Prepare the LO/Sense LO connector assembly.



**Caution** To ensure specified EMC performance, only use twisted, shielded pair cable (e.g., Belden 83321E).

- a) Open the LO/Sense LO connector assembly.
- b) Use an insulation strip tool to expose the LO, sense LO, and ground cable conductors. The maximum strip length for the LO and sense LO cable is 10 mm (0.394 in).
- c) Insert each cable into the appropriate connector terminal. The cable drain wire should be terminated to the connector ground terminal.
- d) Inspect the connection to the connector terminals to ensure no exposed metal is visible on the LO and sense LO cables beyond the body of the connector.

- e) Clamp down using the screw terminals on the connector.
  - f) Verify that no exposed shield foil or braid extends outside of the backshell.
  - g) Use the cable tie to provide strain relief for the cable to the backshell.
  - h) Close the LO/sense LO connector assembly and tighten the retention screw to hold it in place.
13. Attach output connections.
    - a) Connect the triaxial cables to the device.
    - b) Connect the LO/sense LO connector assembly to the device. Tighten the thumbscrew on the connector assembly to hold it in place.
  14. Ensure that the safety interlock connector is wired to a test fixture that ensures operator safety, and prepare the safety interlock cable for insertion into the safety interlock connector.
    - a) Measure and mark your strip length on the safety interlock cable.



**Note** Required wire strip length for the safety interlock cable is 7.5 mm (0.295 in.) minimum and 10 mm (0.394 in.) absolute maximum.  
Acceptable AWG Range for safety interlock cable is 16-24.

- b) Use an insulation strip tool to expose cable of the appropriate length.
  - c) The safety interlock connector accepts both solid and multi-strand conductor cabling. If you are using a multi-stranded cable, twist the strands together before insertion. For additional cabling reliability, strip and tin multi-stranded conductors before insertion.
  - d) Insert the cable.
  - e) Inspect for loose strands and tighten any retention screws on the safety interlock connector assembly to hold it in place.
  - f) Connect the safety interlock connector to the device.
15. Power on the chassis.
  16. Perform the safety interlock test.

## Related Information

[Testing the Safety Interlock](#) on page 11

# Configuring the PXIe-4135 in MAX

Use Measurement & Automation Explorer (MAX) to configure your NI hardware. MAX informs other programs about which devices reside in the system and how they are configured. MAX is automatically installed with NI-DCPower.

1. Launch MAX.
2. In the configuration tree, expand **Devices and Interfaces** to see the list of installed devices.

Installed devices appear under the name of their associated chassis.

3. Expand your **Chassis** tree item.

MAX lists all devices installed in the chassis. Your default device names may vary.



**Note** If you do not see your device listed, press <F5> to refresh the list of installed devices. If the device is still not listed, power off the system, ensure the device is correctly installed, and restart.

4. Record the device identifier MAX assigns to the hardware. Use this identifier when programming the PXIe-4135.
5. Self-test the device by selecting the device in the configuration tree and clicking **Self-Test** in the MAX toolbar.

The MAX self-test performs a basic verification of hardware resources.

## Testing the Safety Interlock

---

In order to ensure safe operation of the PXIe-4135, periodically test the safety interlock for proper functionality. The recommended test interval is at least once per day of continuous usage.

## Testing with an Application Development Environment

1. Disconnect the output connector from the PXIe-4135 front panel.
2. Ensure that the safety interlock input on the test fixture is closed.
3. Set the **niDCPower Output Function** property or `NIDCPOWER_OUTPUT_FUNCTION` attribute to DC Voltage for the PXIe-4135.
4. Set the voltage level range to 200 V, and set the voltage level to 42.4 V.
5. Set the current limit range to 1 mA, and set the current limit to 1 mA.
6. Initiate the session.
7. Verify that the Voltage Status Indicator is amber.
8. Open the safety interlock input using the test fixture.
9. Verify that the Voltage Status Indicator is red.
10. Reset the device using the niDCPower Reset VI or the `niDCPower Reset` function.
11. Verify that the Voltage Status Indicator is green.



**Caution** If the PXIe-4135 fails the safety interlock test, discontinue use of the device and contact an authorized NI service representative to request a Return Material Authorization (RMA).

## Testing with the NI-DCPower Soft Front Panel

1. Disconnect the output connector from the PXIe-4135 front panel.
2. Ensure that the safety interlock input on the test fixture is closed.
3. In the NI-DCPower SFP, set Output Function to DC Voltage.
4. Set Voltage Level Range to 200 V, and set Voltage Level to 42.4 V.
5. Set Current Limit to 1 mA, and set Current Limit Range to 1 mA.
6. Ensure that Local sense is selected.

7. Check the **Output Enabled** checkbox to enable the output.
8. Verify that the Voltage Status Indicator is amber.
9. Open the safety interlock input using the test fixture.
10. Verify that the Voltage Status Indicator is red and that a hazardous voltage error message appears.
11. On the error message dialog, click **OK** to prompt the PXIe-4135 to attempt to clear the error and re-initialize the session to default values.
12. Verify that the Voltage Status Indicator is green.



**Caution** If the PXIe-4135 fails the safety interlock test, discontinue use of the device and contact an authorized NI service representative to request a Return Material Authorization (RMA).

# Programming the PXIe-4135

You can generate signals interactively using the NI-DCPower Soft Front Panel (SFP) or you can use the NI-DCPower instrument driver to program your device in the supported ADE of your choice.

**Table 1.** PXIe-4135 Programming Options

| Application Programming Interface (API) | Location   | Description   |
|---|--|---|
| NI-DCPower SFP                          | Available from the start menu at <b>Start»All Programs»National Instruments»NI-DCPower»NI-DCPower Soft Front Panel</b> . | The NI-DCPower SFP acquires, controls, and presents data. The NI-DCPower SFP operates on the PC, to provide additional display capabilities.  |
| NI-DCPower Instrument Driver            | LabVIEW—Available on the LabVIEW Functions palette at <b>Measurement I/O»NI-DCPower</b> .                                | NI-DCPower configures and operates the device hardware and performs basic acquisition and measurement options using LabVIEW VIs or LabWindows/CVI functions.  |
|   | C or LabWindows/CVI—Available at <b>Program Files»IVI Foundation»IVI Drivers»NI-DCPower</b> .                            |   |
|   | Microsoft Visual C/C++—NI-DCPower does not ship with installed C/C++ examples.   | Refer to the <i>Creating an Application with Microsoft Visual C and C++</i> topic of the <a href="#">NI DC Power Supplies and SMUs Help</a> to manually add all required include and library files to your project. |

# Troubleshooting

If an issue persists after you complete a troubleshooting procedure, contact NI technical support or visit [ni.com/support](http://ni.com/support).

## What Should I Do if the PXIe-4135 Doesn't Appear in MAX?

1. In the MAX configuration tree, expand **Devices and Interfaces**.
2. Expand the **Chassis** tree to see the list of installed devices, and press <F5> to refresh the list.
3. If the module is still not listed, power off the system, ensure that all hardware is correctly installed, and restart the system.
4. Navigate to the Device Manager.

| Operating System | Description |
|------------------|-------------|
|------------------|-------------|

|           |  |
|-----------|--|
| Windows 8 | Right-click the Start screen, and select <b>All apps»Control Panel»Hardware and Sound»Device Manager</b> . |
|-----------|--|

|           |  |
|-----------|--|
| Windows 7 | Select <b>Start»Control Panel»Device Manager</b> . |
|-----------|--|

|               |   |
|---------------|---|
| Windows Vista | Select <b>Start»Control Panel»System and Maintenance»Device Manager</b> . |
|---------------|---|


|            |  |
|------------|--|
| Windows XP | Select <b>Start»Control Panel»System»Hardware»Device Manager</b> . |
|------------|--|

5. If you are using a PXI or PXI Express controller, verify that a **National Instruments** entry appears in the system device list. Reinstall NI-DCPower and the device if error conditions appear in the list. If you are using an MXI controller, right-click **PCI-to-PCI Bridge**, and select **Properties** from the shortcut menu to verify that the bridge is enabled.

## Why Is the ACCESS LED Off When the Chassis Is On?

The LEDs may not illuminate until the device has been configured in MAX. Before proceeding, verify that the PXIe-4135 appears in MAX.

If the ACCESS LED fails to illuminate after you power on the PXI Express chassis, a problem may exist with the PXI Express power rails, a hardware module, or the LED.

1.  **Caution** Apply external signals only while the PXIe-4135 is powered on. Applying external signals while the device is powered off may cause damage. Disconnect any signals from the PXI Express module front panels.
2. Remove any front panel connections from the PXIe-4135.
3. Power off the PXI Express chassis.
4. Remove the module from the PXI Express chassis and inspect it for damage. Do not reinstall a damaged device.


5. Install the module in a different PXI Express chassis slot from which you removed it.
6. Power on the PXI Express chassis.
7. Verify that the device appears in MAX.
8. Reset the device in MAX and perform a self-test.

If the ACCESS LED still fails to illuminate and failures continue, contact NI technical support or visit [ni.com/support](http://ni.com/support).

## Related Information

*For more information about LED status indicator behavior, see the front panel topic for your device in the [NI DC Power Supplies and SMUs Help](#).*

## Where To Go Next



## Worldwide Support and Services

The NI website is your complete resource for technical support. At [ni.com/support](http://ni.com/support), you have access to everything from troubleshooting and application development self-help resources to email and phone assistance from NI Application Engineers.

Visit [ni.com/services](https://ni.com/services) for NI Factory Installation Services, repairs, extended warranty, and other services.

Visit [ni.com/register](https://ni.com/register) to register your NI product. Product registration facilitates technical support and ensures that you receive important information updates from NI.

A Declaration of Conformity (DoC) is our claim of compliance with the Council of the European Communities using the manufacturer's declaration of conformity. This system affords the user protection for electromagnetic compatibility (EMC) and product safety. You can obtain the DoC for your product by visiting [ni.com/certification](https://ni.com/certification). If your product supports calibration, you can obtain the calibration certificate for your product at [ni.com/calibration](https://ni.com/calibration).

NI corporate headquarters is located at 11500 North Mopac Expressway, Austin, Texas, 78759-3504. NI also has offices located around the world. For telephone support in the United States, create your service request at [ni.com/support](https://ni.com/support) or dial 1 866 ASK MYNI (275 6964). For telephone support outside the United States, visit the *Worldwide Offices* section of [ni.com/global](https://ni.com/global) to access the branch office websites, which provide up-to-date contact information, support phone numbers, email addresses, and current events.

Refer to the *NI Trademarks and Logo Guidelines* at [ni.com/trademarks](http://ni.com/trademarks) for information on NI trademarks. Other product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering NI products/technology, refer to the appropriate location: **Help»Patents** in your software, the `patents.txt` file on your media, or the *National Instruments Patent Notice* at [ni.com/patents](http://ni.com/patents). You can find information about end-user license agreements (EULAs) and third-party legal notices in the readme file for your NI product. Refer to the *Export Compliance Information* at [ni.com/legal/export-compliance](http://ni.com/legal/export-compliance) for the NI global trade compliance policy and how to obtain relevant HTS codes, ECCNs, and other import/export data. NI MAKES NO EXPRESS OR IMPLIED WARRANTIES AS TO THE ACCURACY OF THE INFORMATION CONTAINED HEREIN AND SHALL NOT BE LIABLE FOR ANY ERRORS. U.S. Government Customers: The data contained in this manual was developed at private expense and is subject to the applicable limited rights and restricted data rights as set forth in FAR 52.227-14, DFAR 252.227-7014, and DFAR 252.227-7015.

© 2016 National Instruments. All rights reserved.