

BUREAU OF INDIAN STANDARDS

INDIAN STANDARD: IS 10500 : 2012

DRINKING WATER — SPECIFICATION (SECOND REVISION) — SPECIFICATION

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002

1 SCOPE

Prescribes the requirements and methods of sampling and test for drinking water intended for human consumption.

Table 1: Physical Parameters (Clause 5.1)

SI No.	Characteristic	Acceptable Limit	Permissible Limit
1	Colour, Hazen units	5	15
2	pH Value	6.5 - 8.5	No relaxation
3	Turbidity, NTU	1	5
4	Total Dissolved Solids (TDS)	500 mg/L	2000 mg/L

Table 3: Toxic Substances (Clause 5.3)

SI No.	Toxic Substance	Acceptable Limit	Permissible Limit
1	Lead (as Pb)	0.01 mg/L	No relaxation
2	Arsenic (as As)	0.01 mg/L	0.05 mg/L
3	Cadmium (as Cd)	0.003 mg/L	No relaxation
4	Mercury (as Hg)	0.001 mg/L	No relaxation