Experimental Schedule UCLT Sheet 1
UTILITY-CONTROLLED LOAD TESTS

APPLICABILITY

Applicable to load deferral or load shedding and automatic electric power management ("Powershift") test programs where a portion of customer's electrical load is subject, on a selective basis at SCE's option, to disconnection from SCE's service by SCE through automatic control systems. This schedule is applicable only to customers selected to participate in tests at SCE designated test sites.

TERRITORY

Within the entire territory served.

RATE

The rates, as applicable under the customer's Otherwise Applicable Tariff (OAT), including any applicable load management incentive mechanisms shall apply, except the customer shall receive an annual monetary payment or bill credit for its participation on this program.

SPECIAL CONDITIONS

1. Nature of Tests: Tests to be performed under this Schedule are any load deferral or load shedding tests which involve control systems installed within the electrical circuitry either owned by SCE or the customer for purposes of determining technical, economic, and general acceptability of certain load management systems.

2. Test Events: The maximum accumulated hours of all test events combined shall not exceed 35 hours per service account in a calendar year, with the maximum duration of a single test event not to exceed 6 hours. (T)

3. Types of Load: Electric loads which may be tested under this schedule include, but are not limited to, air conditioning, water heating, space heating, and swimming pool filter pumping.

4. Period of Tests: Tests at individual sites are limited to a period of three years from the date a customer starts their participation under this Schedule.