SCHEDULE PG

EXPERIMENTAL PARALLEL GENERATION

SPECIAL CONDITIONS (Continued)

6. Interconnection Facilities: The customer shall furnish, install, operate and maintain in good order and repair and without cost to the utility, such relays, locks and seals, breakers, automatic synchronizer, and other control and protective apparatus as shall be designated by the utility as being required as suitable for the operation of the generator in parallel with the utility's system. In addition, the utility will install, own and maintain a disconnection device located near the electric meter or meters. The utility shall have the right to disconnect the customer's generating facility at the disconnection device when necessary to maintain safe electrical operating conditions. Interconnection Facilities shall be accessible at all times to utility personnel.

   The customer may be required to reimburse the utility for any equipment or facilities required as a result of the installation by the customer of generation in parallel with the utility's service.

   The customer shall notify the utility prior to the initial energizing and start-up testing of the customer-owned generator, and the utility shall have the right to have a representative present at such test.

7. Contract: The utility may at its option require a special agreement for conditions related to technical and safety aspects of parallel generation.

8. Other Applicable Tariffs: Rules 21, 23 and Schedule E-Depart apply to customers with generators. N