

Growatt OffGrid SPF5000 Modbus RS485 RTU Protocol

V0.11

2017-8-09

Growatt New Energy CO.,LTD

No.	Version	Date	Notice	Signature
1	V0.01	2016-12-27	The first version	Zhenyuan.li
2	V0.02	2017-1-12	1、 modify input reg 0, system status; 2、 add input reg 44 for send DTC to server to identify machine type;	Zhenyuan.li
3	V0.03	2017-2-6	1、 modify Holding reg 29, Model Low;	Zhenyuan.li
4	V0.04	2017-2-16	1、add Holding reg 39, battery type; 2、 modify Holding reg 0, On/Off; 3、 modify Input reg 46, Production Line Mode;	Zhenyuan.li
5	V0.05	2017-3-10	1、 modify Input reg 17、28、29, Battery Voltage;	Zhenyuan.li
6	V0.06	2017-3-15	1、 modify Holding reg 29, Model L;	Zhenyuan.li
7	V0.07	2017-5-25	1、 modify Hold reg 29; 2、 modify Input reg 36~39; 3、 add Input reg 68~82;	Zhenyuan.li
8	V0.08	2017-5-26	1、 add Input reg 90~131 for BMS infomation;	Zhenyuan.li
9	V0.09	2017-7-4	1、 add Input reg 135~179 for SolarCharger infomation;	Zhenyuan.li
10	V0.10	2017-7-12	1、add Input reg 83~86 for Machine Rate Power ;	Zhenyuan.li
11	V0.11	2017-8-09	1、 Change Machine Rate Power from Input Reg 83~86 to Holding Reg 76~79; 2、 Adjust BMS info, and add BMS2 info; 3、 Add Solar Charger Info at Input Reg 180~224;	Zhenyuan.li

-
- V0.01 2016-12-27:
1, Update the register map tables from sp3000 RTU protocol for spf3-5K;
- V0.02 2017-1-12:
1, modify input reg 0, system status;
2, add input reg 44 for send DTC to server to identify machine type;
- V0.03 2017-2-6:
1, modify Holding reg 29, model Low;
- V0.04 2017-2-16:
1, add Holding reg 39, battery type; it can be set by server;
2, modify Holding reg 0, On/Off; add remote control ac output and set standby state function;
3, modify Input reg 46, Production Line Mode; add production line mode set 2 to clear fault, decrease test time;
- V0.05 2017-3-10:
1, modify Input reg 17、28、29, Battery Voltage; change uint 0.1V to uint 0.01V;
- V0.06 2017-3-15:
1, modify Holding reg 29, Model L; Add S bit for Aging Mode;
- V0.07 2017-5-25:
1, modify Holding reg 29, Model L; U bit add two user:CPS and cODM_Haiti;
2, modify Input reg 36~39 for AC input Power;
3, add Input reg 68 for AC charge current; add Input reg 69~72 for AC discharge power; add Input reg 73~76 for battery discharge power; add Input reg 77~78 for battery power; add Input reg 80 for battery over charge flag; add Input reg 81~82 for fan speed;
- V0.08 2017-5-26:
1, add Input reg 90~131 for BMS infomation;
- V0.09 2017-7-4:
1, add Input reg 135~179 for SolarCharger infomation;
- V0.10 2017-7-12:
1, add Input reg 83~86 for Machine Rate Power;
- V0.11 2017-8-09:
1, Change Machine Rate Power from Input Reg 83~86 to Holding Reg 76~79;
2, Adjust BMS info, and add BMS2 info;
3, Add Solar Charger Info at Input Reg 180~224;

1 Data format	5
2 Command Format.....	5
3 Device Message Transmission Mode / Framing	8
4 Register map.....	9
5 Set address	21
6 Notice	22

1 Data format

Address	Function	Data	CRC check
8 bits	8 bits	N×8bits	16bits

Valid slave device addresses are in the range of 0 – 247 decimal.

The individual slave devices are assigned addresses in the range of 1 – 247.

0 is the broadcast address

It is 16bits (two bytes) unsigned integer for each holding and input register;

2 Command Format

Function 3 Read holding register

QUERY	
Field Name	Example (Hex)
Slave Address	11
Function	03
Starting Address Hi	00
Starting Address Lo	6B
No. of Points Hi	00
No. of Points Lo	03
Error Check (LRC or CRC)	—

RESPONSE	
Field Name	Example (Hex)
Slave Address	11
Function	03
Byte Count	06
Data Hi (Register 40108)	02
Data Lo (Register 40108)	2B
Data Hi (Register 40109)	00
Data Lo (Register 40109)	00
Data Hi (Register 40110)	00
Data Lo (Register 40110)	64
Error Check (LRC or CRC)	—

Response Error:

11 0x80|0x03 Erronnum CRC (Erronnum as a byte)

Function 4 Read input register

QUERY

Field Name	Example (Hex)
Slave Address	11
Function	04
Starting Address Hi	00
Starting Address Lo	08
No. of Points Hi	00
No. of Points Lo	01
Error Check (LRC or CRC)	—

RESPONSE

Field Name	Example (Hex)
Slave Address	11
Function	04
Byte Count	02
Data Hi (Register 30009)	00
Data Lo (Register 30009)	0A
Error Check (LRC or CRC)	—

Response Error:

11 0x80|0x04 Erronum CRC (Erronum as a byte)

Function 6 Preset single register

QUERY

Field Name	Example (Hex)
Slave Address	11
Function	06
Register Address Hi	00
Register Address Lo	01
Preset Data Hi	00
Preset Data Lo	03
Error Check (LRC or CRC)	—

RESPONSE

Field Name	Example (Hex)
Slave Address	11
Function	06
Register Address Hi	00
Register Address Lo	01
Preset Data Hi	00
Preset Data Lo	03
Error Check (LRC or CRC)	—

Response Error:

11 0x80|0x06 Erronnum CRC (Erronnum as a byte)

Function 16 Preset multiple register

QUERY

Field Name	Example (Hex)
Slave Address	11
Function	10
Starting Address Hi	00
Starting Address Lo	01
No. of Registers Hi	00
No. of Registers Lo	02
Byte Count	04
Data Hi	00
Data Lo	0A
Data Hi	01
Data Lo	02
Error Check (LRC or CRC)	—

RESPONSE

Field Name	Example (Hex)
Slave Address	11
Function	10
Starting Address Hi	00
Starting Address Lo	01
No. of Registers Hi	00
No. of Registers Lo	02
Error Check (LRC or CRC)	—

Response Error:

11 0x80|0x10 Erronnum CRC (Erronnum as a byte)

3 Device Message Transmission Mode / Framing

RTU Mode

When controllers are setup to communicate on a Modbus network using RTU (Remote Terminal Unit) mode, each 8-bit byte in a message contains two 4-bit hexadecimal characters. Each message must be transmitted in a continuous stream.

The format for each byte in RTU mode is:

Coding System: 8-bit binary, hexadecimal 0–9, A–F
Two hexadecimal characters contained in each
8-bit field of the message

Bits per Byte:

1 start bit
8 data bits, least significant bit sent first
None parity
1 stop bit
Error Check Field: Cyclical Redundancy Check (CRC)

The baud rate of the transmission is:

Baud Rate: 9600 bps

Minimum CMD period (RS485 Time out): 850ms.

Wait for minimum 850ms to send a new CMD after last CMD. Suggestion is 1s;

Maximum Data Length Define:

Maximum read data length is 45 words in read command;
Maximum update data length is 45 words in preset command;
Read or update registers NO. should in the range of times of 45,
eg: 1~45 or 96~123 are OK, but 40~60 is not OK;

Note:

Except the CEI0-21 and VDE-AR-N 4105 power management registers, you should refer the manufactory's suggestion when writing other registers;

4 Register map

It is 16bits (two bytes) unsigned integer for each holding and input register;

4.1 Holding Reg

Reg NO.	Variable Name	Description	Cust ome r Writ e	Value	Unit	Initial value	Note
00	On/Off	The Standby On/Off state and the AC output DisEN/EN state; The low byte is the Standby on/off(1/0), the high byte is the AC output disable/enable (1/0).		0x0000: Standby off, Output enable; 0x0001: Standby on, Output enable; 0x0100: Standby off, Output disable; 0x0101: Standby on, Output disable;		0	
01	OutputConfig	AC output set	W	0: BAT First; 1: PV First; 2: UTI First;		0	
02	ChargeConfig	Charge source set	W	0: PV first; 1: PV&UTI; 2: PV Only;		0	
03	UtiOutStart	Uti Output Start Time	W	0-23	H(hour)	0	
04	UtiOutEnd	Uti Output End Time	W	0-23	H(hour)	0	
05	UtiChargeStart	Uti Charge Start Time	W	0-23	H(hour)	0	
06	UtiChargeEnd	Uti Charge End Time	W	0-23	H(hour)	0	
07	PVModel	PV Input Mode	W	0:Independent; 1: Parallel;		0	
08	ACInModel	AC Input Mode	W	0: APL,90-280VAC; 1: UPS,170-280VAC;		0	
09	Fw version H	Firmware version (high)			ASCII		
10	Fw version M	Firmware version (middle)					
11	Fw version L	Firmware version (low)					
12	Fw version2 H	Control Firmware version (high)			ASCII		
13	Fw version2 M	Control Firmware					

		version (middle)					
14	Fw version2 L	Control Firmware version (low)					
15	LCD language	LCD language	W	0-1		1	English
16							
17							
18	OutputVoltType	Output Volt Type	W	0: 208VAC; 1: 230VAC 2: 240VAC		1	
19	OutputFreqType	Output Freq Type	W	0: 50Hz; 1: 60Hz		0	
20	OverLoadRestart	Over Load Restart	W	0:Yes; 1:No; 2: Swith to UTI;		0	Yes(over Load 1mins to restart, after over Load three times to stop output)
21	OverTempRestart	Over Temperature Restart	W	0:Yes; 1:No;		0	Yes(over Temperature to restart , after over Temperature three times to stop output)
22	BuzzerEN	Buzzer on/off enable	W	1:Enable; 0:Disable;		1	
23	Serial NO. 5	Serial number 5	W		ASCII		
24	Serial No. 4	Serial number 4	W				
25	Serial No. 3	Serial number 3	W				
26	Serial No. 2	Serial number 2	W				
27	Serial No. 1	Serial number 1	W				
28	Moudle H	Inverter Moudle (high)	W				Can be set at standy state Only
29	Moudle L	Inverter Moudle (low)	W	P-battery type: 0: Lead_Acid; 1: Lithium; 2: CustomLead_Acid; U-user type: 0: No verndor; 1: Growatt; 2: CPS; 3: Haiti;			Can be set at standy state Only

				M-power rate: 3: 3KW; 5:5KW; S-Aging: 0: Normal Mode; 1: Aging Mode;		
30	Com Address	Communicate address	W	1~254	1	
31	FlashStart	Update firmware	W	0x0001: own 0X0100: control broad		
32	Reset User Info	Reset User Information	W	0x0001		
33	Reset to factory	Reset to factory	W	0x0001		
34	MaxChargeCurr	Max Charge Current	W	10~130	1A	70
35	BulkChargeVolt	Bulk Charge Volt	W	500~580	0.1V	564
36	FloatChargeVolt	Float Charge Volt	W	500~560	0.1V	540
37	BatLowToUtiVolt	Bat Low Volt Switch To Uti	W	444~514	0.1V	464
38	FloatChargeCurr	Float Charge Current	W	0~80	0.1A	
39	Battery Type	Battery Type	W	0: Lead_Acid; 1: Lithium; 2: CustomLead_Acid;	1	Can be set at standy state Only
40	Aging Mode	Aging Mode	W	0: Normal Mode; 1: Aging Mode;	0	Can be set at standy state Only
43	DTC	Device Type Code		&*6		
44						
45	Sys Year	System time-year	W	Year offset is 2000		
46	Sys Month	System time- Month	W			
47	Sys Day	System time- Day	W			
48	Sys Hour	System time- Hour	W			
49	Sys Min	System time- Min	W			
50	Sys Sec	System time- Second	W			
51						
57						
58						
59	Manufacturer Info 8	Manufacturer information (high)			ASCII	
60	Manufacturer Info 7	Manufacturer information (middle)				
61	Manufacturer	Manufacturer				

	Info 6	information (low)					
62	Manufacturer Info 5	Manufacturer information (high)					
63	Manufacturer Info 4	Manufacturer information (middle)					
64	Manufacturer Info3	Manufacturer information (low)					
65	Manufacturer Info 2	Manufacturer information (low)					
66	Manufacturer Info 1	Manufacturer information (high)			ASCII		
67	FW Build No. 4	Control FW Build No. 2			ASCII		
68	FW Build No. 3	Control FW Build No. 1					
69	FW Build No. 2	COM FW Build No. 2					
70	FW Build No. 1	COM FW Build No. 1			ASCII		
71							
72	Sys Weekly	Sys Weekly	W	0-6			
73	ModbusVersion	Modbus Version		Eg: 207 is V2.07	Int(16bit s)		
...							
76	Rate Watt H	Rate active power(high)			0.1W		
77	Rate Watt L	Rate active power(low)			0.1W		
78	Rate VA H	Rate apparent power (high)			0.1VA		
79	Rate VA L	Rate apparent power (low)			0.1VA		
80	Factory	The ODM Info code					
....							
161							
162	BLVersion2	Boot loader version2	R			M3 bootloader version	

4.2 Input Reg

(Some of input Registers can be wrote by Manufacturer, write address offset is 0x1000, start at 0x1000. can not be wrote by customer.)

Reg NO.	Variable Name	Description	Value	Unit	Note

00	System Status	System run state	0: Standby; 1; (No Use) 2: Discharge; 3: Fault; 4: Flash; 5: PV charge; 6: AC charge; 7: Combine charge; 8: Combine charge and Bypass; 9: PV charge and Bypass; 10: AC charge and Bypass; 11: Bypass; 12: PV charge and Discharge;		
01	Vpv1	PV1 voltage	0.1V		
02	Vpv2	PV2 voltage	0.1V		
03	Ppv1 H	PV1 charge power (high)	0.1W		
04	Ppv1 L	PV1 charge power (low)	0.1W		
05	Ppv2 H	PV2 charge power (high)	0.1W		
06	Ppv2 L	PV2 charge power (low)	0.1W		
07	Buck1Curr	Buck1 current	0.1A		
08	Buck2Curr	Buck2 current	0.1A		
09	OP_Watt H	Output active power (high)	0.1W		
10	OP_Watt L	Output active power (low)	0.1W		
11	OP_VA H	Output apparent power (high)	0.1VA		
12	OP_VA L	Output apparent power (low)	0.1VA		
13	ACChr_Watt H	AC charge watt (high)	0.1W		
14	ACChr_Watt L	AC charge watt (low)	0.1W		
15	ACChr_VA H	AC charge apparent power (high)	0.1VA		
16	ACChr_VA L	AC charge apparent power (low)	0.1VA		
17	Bat Volt	Battery volt (M3)	0.01V		
18	BatterySOC	Battery SOC	0~100	1%	
19	Bus Volt	Bus Voltage		0.1V	
20	Grid Volt	AC input Volt		0.1V	
21	Line Freq	AC input frequency		0.01Hz	
22	OutputVolt	AC output Volt		0.1V	
23	OutputFreq	AC output frequency		0.01Hz	
24	Ouput DCV	Ouput DC Volt		0.1V	

25	InvTemp	Inv Temperature		0.1C	
26	DcDc Temp	DC-DC Temperature		0.1C	
27	LoadPercent	Load Percent	0~1000	0.1%	
28	Bat_s_Volt	Battery-port volt (DSP)		0.01V	
29	Bat_Volt_DSP	Battery-bus volt (DSP)		0.01V	
30	Time total H	Work time total (high)		0.5S	
31	Time total L	Work time total (low)		0.5S	
32	Buck1_NTC	Buck1 Temperature		0.1C	
33	Buck2_NTC	Buck2 Temperature		0.1C	
34	OP_Curr	Output Current		0.1A	
35	Inv_Curr	Inv Current		0.1A	
36	AC_InWatt H	AC input watt (high)		0.1W	
37	AC_InWatt L	AC input watt (low)		0.1W	
38	AC_InVA H	AC input apparent power (high)		0.1VA	
39	AC_InVA L	AC input apparent power (low)		0.1VA	
40	Fault bit	fault bit	&*1		
41	Warning bit	Warning bit	&*1		
42	fault value	fault value			
43	warning value	warning value			
44	DTC	Device Type Code	&*6		
45	Check Step	Product check step	1:PV1 charge power check; 2:PV2 charge power check; 3:AC charge Power check		
46	Production Line Mode	Production Line Mode	0: Not at Production Line Mode; 1: Production Line Mode; 2: Production Line Clear Fault Mode;		
47	ConstantPowerOKFlag	Constant Power OK Flag	0: Not OK; 1: OK;		
48	Epv1_today H	PV Energy today			
49	Epv1_today L	PV Energy today		0.1kW h	
50	Epv1_total H	PV Energy total			
51	Epv1_total L	PV Energy total		0.1kW h	
52	Epv2_today H	PV Energy today			

53	Epv2_today L	PV Energy today		0.1kW h	
54	Epv2_total H	PV Energy total			
55	Epv2_total L	PV Energy total		0.1kW h	
56	Eac_chrToday H	AC charge Energy today			
57	Eac_chrToday L	AC charge Energy today		0.1kW h	
58	Eac_chrTotal H	AC charge Energy total			
59	Eac_chrTotal L	AC charge Energy total		0.1kW h	
60	Ebat_dischrToday H	Bat discharge Energy today			
61	Ebat_dischrToday L	Bat discharge Energy today		0.1kW h	
62	Ebat_dischrTotal H	Bat discharge Energy total			
63	Ebat_dischrTotal L	Bat discharge Energy total		0.1kW h	
64	Eac_dischrToday H	AC discharge Energy today			
65	Eac_dischrToday L	AC discharge Energy today		0.1kW h	
66	Eac_dischrTotal H	AC discharge Energy total			
67	Eac_dischrTotal L	AC discharge Energy total		0.1kW h	
68	ACChrCurr	AC Charge Battery Current		0.1A	
69	AC_DisChrWatt H	AC discharge watt (high)		0.1W	
70	AC_DisChrWatt L	AC discharge watt (low)		0.1W	
71	AC_DisChrVA H	AC discharge apparent power (high)		0.1VA	
72	AC_DisChrVA L	AC discharge apparent power (low)		0.1VA	
73	Bat_DisChrWatt H	Bat discharge watt (high)		0.1W	
74	Bat_DisChrWatt L	Bat discharge watt (low)		0.1W	
75	Bat_DisChrVA H	Bat discharge apparent power (high)		0.1VA	
76	Bat_DisChrVA L	Bat discharge apparent power (low)		0.1VA	
77	Bat_Watt H	Bat watt (high)	(signed int 32) Positive:Battery Discharge Power; Negative: Battery Charge Power;	0.1W	
78	Bat_Watt L	Bat watt (low)		0.1W	
79	Reserved	Not Used			
80	BatOverCharge	Battery Over Charge Flag	0:Battery not over		

			charge; 1:Battery over charge;		
81	MpptFanSpeed	Fan speed of MPPT Charger	0~100	1%	
82	InvFanSpeed	Fan speed of Inverter	0~100	1%	
90	BMS_Status	Status from BMS	Detail information, refer to document: Growatt xxSxxP ESS Protocol;		
91	BMS_Error	Error infomation from BMS			
92	BMS_WarnInfo	Warning info from BMS			
93	BMS_SOC	SOC from BMS			
94	BMS_BatteryVolt	Battery voltage from BMS			
95	BMS_BatteryCurr	Battery current from BMS			
96	BMS_BatteryTemp	Battery temperature from BMS			
97	BMS_MaxCurr	Max. charge/discharge current from BMS			
98	BMS_ConstantVolt	CV voltage from BMS			
99	BMS_BMSInfo	BMS Information from BMS			
100	BMS_PackInfo	Pack Information from BMS			
101	BMS_UsingCap	Using Cap from BMS			
102	BMS_Cell1_Volt	Cell1_Voltage from BMS			
...			
117	BMS_Cell16_Volt	Cell16_Voltage from BMS			
118	BMS2_Status	Status from BMS2	Detail information, refer to document: Growatt xxSxxP ESS Protocol;		
119	BMS2_Error	Error infomation from BMS			
120	BMS2_WarnInfo	Warning info from BMS2			
121	BMS2_SOC	SOC from BMS2			
122	BMS2_BatteryVolt	Battery voltage from BMS2			
123	BMS2_BatteryCurr	Battery current from BMS2			
124	BMS2_BatteryTemp	Battery temperature from BMS2			
125	BMS2_MaxCurr	Max. charge/discharge current from BMS2			
126	BMS2_ConstantVolt	CV voltage from BMS2			
127	BMS2_BMSInfo	BMS Information from BMS2			
128	BMS2_PackInfo	Pack Information from BMS2			
129	BMS2_UsingCap	Using Cap from BMS2			
130	BMS2_Cell1_Volt	Cell1_Voltage from BMS2			
...			
145	BMS2_Cell16_Volt	Cell16_Voltage from BMS2			
180	Solar1_Status	Solar Charger1 Status			
181	Solar1_FaultCode	Solar Charger1 FaultCode			
182	Solar1.WarningCode	Solar Charger1 WarningCode			

183	Solar1_BatVolt	Solar Charger1 battery voltage		0.01V	
184	Solar1_PV1Volt	Solar Charger1 PV1 voltage		0.1V	
185	Solar1_PV2Volt	Solar Charger1 PV2 voltage		0.1V	
186	Solar1_Buck1Curr	Solar Charger1 Buck1 current		0.1A	
187	Solar1_Buck2Curr	Solar Charger1 Buck2 current		0.1A	
188	Solar1_PV1ChrPower H	Solar Charger1 PV1 charge Power High 16 bit		0.1W	
189	Solar1_PV1ChrPower H	Solar Charger1 PV1 charge Power Low 16 bit		0.1W	
190	Solar1_PV2ChrPower H	Solar Charger1 PV2 charge Power High 16 bit		0.1W	
191	Solar1_PV2ChrPower H	Solar Charger1 PV2 charge Power Low 16 bit		0.1W	
192	Solar1_HS1Temp	Solar Charger1 Buck1 Temperature		0.1C	
193	Solar1_HS2Temp	Solar Charger1 Buck2 Temperature		0.1C	
194	Solar1_Epv1_today	Solar Charger1 PV1 Energy today		0.1k Wh	
195	Solar1_Epv2_today L	Solar Charger1 PV2 Energy today		0.1k Wh	
196	Solar1_Epv1_total H	Solar Charger1 PV1 Energy total High 16 bit		0.1k Wh	
197	Solar1_Epv1_total L	Solar Charger1 PV1 Energy total Low 16 bit		0.1k Wh	
198	Solar1_Epv2_total H	Solar Charger1 PV2 Energy total High 16 bit		0.1k Wh	
199	Solar1_Epv2_total L	Solar Charger1 PV2 Energy total Low 16 bit		0.1k Wh	
200	Solar2_Status	Solar Charger2 Status			
201	Solar2_FaultCode	Solar Charger2 FaultCode			
202	Solar2_WarningCode	Solar Charger2 WarningCode			
203	Solar2_BatVolt	Solar Charger2 battery voltage		0.01V	
204	Solar2_PV1Volt	Solar Charger2 PV1 voltage		0.1V	
205	Solar2_PV2Volt	Solar Charger2 PV2 voltage		0.1V	
206	Solar2_Buck1Curr	Solar Charger2 Buck1 current		0.1A	
207	Solar2_Buck2Curr	Solar Charger2 Buck2 current		0.1A	
208	Solar2_PV1ChrPower H	Solar Charger2 PV1 charge Power High 16 bit		0.1W	
209	Solar2_PV1ChrPower H	Solar Charger2 PV1 charge Power Low 16 bit		0.1W	
210	Solar2_PV2ChrPower H	Solar Charger2 PV2 charge Power High 16 bit		0.1W	

211	Solar2_PV2ChrPower H	Solar Charger2 PV2 charge Power Low 16 bit		0.1W	
212	Solar2_HS1Temp	Solar Charger2 Buck1 Temperature		0.1C	
213	Solar2_HS2Temp	Solar Charger2 Buck2 Temperature		0.1C	
214	Solar2_Epv1_today	Solar Charger2 PV1 Energy today		0.1k Wh	
215	Solar2_Epv2_today	Solar Charger2 PV2 Energy today		0.1k Wh	
216	Solar2_Epv1_total H	Solar Charger2 PV1 Energy total High 16 bit		0.1k Wh	
217	Solar2_Epv1_total L	Solar Charger2 PV1 Energy total Low 16 bit		0.1k Wh	
218	Solar2_Epv2_total H	Solar Charger2 PV2 Energy total High 16 bit		0.1k Wh	
219	Solar2_Epv2_total L	Solar Charger2 PV2 Energy total Low 16 bit		0.1k Wh	
220	Solar_ConnectOKFlag	Slave Solar Connect OK Flag	1: Solar Charger1; 2: Solar Charger2; 3: Solar Charger1 和 2;		
221	Solar_BatVoltConsistFlag	Check Slave Solar Battery Voltage Consist OK Flag	1: Check Solar Charger1 电池电压 OK; 2: Check Solar Charger2 电池电压 OK; 3: Check Solar Charger1 和 2 电池电压 OK;		
222	Solar_TypeSwState	Solar Charger Type Swtich State	0:Master SolarCharger; 1:Slaver SolarCharger;		
223	Solar_ModeSwState	Solar Charger Mode Swtich State	0: Parallel Mode; 1:Single Mode;		
224	Solar_AddrSwState	Solar Charger Addr Swtich State	2~3;		
360	BMS_GaugeRM	Gauge RM from BMS	Detail information, refer to document: Growatt xxSxxP ESS Protocol;		
361	BMS_GaugeFCC	Gauge FCC from BMS			
362	BMS_FW	BMS_FW			
363	BMS_DeltaVolt	Delta V from BMS			
364	BMS_CycleCnt	Cycle Count from BMS			
365	BMS_SOH	SOH from BMS			
366	BMS_GaugeICCurr	Gauge IC current from BMS			
367	BMS MCUVersion	MCU Software version from BMS			

368	BMS_GaugeVersion	Gauge Version from BMS		
369	BMS_wGaugeFRVersion_L	Gauge FR Version L16 from BMS		
370	BMS_wGaugeFRVersion_H	Gauge FR Version H16 from BMS		
371	BMS2_GaugeRM	Gauge RM from BMS2	Detail information, refer to document: Growatt xxSxxP ESS Protocol;	
372	BMS2_GaugeFCC	Gauge FCC from BMS2		
373	BMS2_FW	BMS2_FW		
374	BMS2_DeltaVolt	Delta V from BMS2		
375	BMS2_CycleCnt	Cycle Count from BMS2		
376	BMS2_SOH	SOH from BMS2		
377	BMS2_GaugeICCurr	Gauge IC current from BMS2		
378	BMS2 MCUVersion	MCU Software version from BMS2		
379	BMS2_GaugeVersion	Gauge Version from BMS2		
380	BMS2_wGaugeFRVersion_L	Gauge FR Version L16 from BMS2		
381	BMS2_wGaugeFRVersion_H	Gauge FR Version H16 from BMS2		

&*1: Off Grid Inverter fault code Bit(See &*8):

Fault type value	Means(The message showed on the inverter when the inverter has fault)
1~7、11~24、 28~32	" Error: 99+x ",
8	Bat Voltage High
9	Over Temperature
10	Over Load
25	MOV Break
26	Over Current
27	Li-Bat Over Load

&*5: Inverter Model: A , could be show: "T0 Q0 PF U1 M5 S1" or "00F151"

```

Tx=(A&0XF00000)>>20
Qx=(A&0XF0000)>>16
Px=(A&0x00F000)>>12
Ux=(A&0x000F00)>>8
Mx=(A&0x0000F0)>>4
Sx=(A&0x00000F)

```

&*6: DTC(Device type code)

Code No.	Device type	Note
001xx	Inverter	1 tracker and 1phase Grid connect PV inverter TL
002xx	Inverter	2 tracker and 1phase Grid connect PV inverter TL
003xx	Inverter	1 tracker and 1phase Grid connect PV inverter HF
004xx	Inverter	2 tracker and 1phase Grid connect PV inverter HF
005xx	Inverter	1 tracker and 1phase Grid connect PV inverter LF
006xx	Inverter	2 tracker and 1phase Grid connect PV inverter LF
007xx	Inverter	1 tracker and 3phase Grid connect PV inverter TL
008xx	Inverter	2 tracker and 3phase Grid connect PV inverter TL
009xx	Inverter	1 tracker and 3phase Grid connect PV inverter LF
010xx	Inverter	2 tracker and 3phase Grid connect PV inverter LF
.....		
10001	Data logger	RF-ShineVersion
10002	Data logger	Web-ShinePano
10003	Data logger	Web-ShineWebBox
10004	Data logger	WL-WIFI Module
.....		
11001	Confluence box	Confluence box 1
.....		
031xx	PV Storage	Front 1 tracker PV Storage
034xx	OffGrid	OffGrid SPF 3-5K

&*7: Grid network power control command password:

Inverter is in lock state after power on; change the power control by network command should unlock inverter first; default pw is XXXXXX;

Unlock: send 0 to 3-135, then send password to 3-136~138; inverter will auto lock in 5min after unlocked;

Change PW: unlock first, then send 1 to 3-135, then send new password to 3-136~138;

Lock: send 0 or 2 to 3-135;

&*8: Off Grid Inverter fault code and warning code

Fault code		Warning code	
0x00000001	\	0x0001	Battery voltage low warning
0x00000002	CPU A to B Communication error	0x0002	Over temprature warning
0x00000004	Battery sample inconsistent	0x0004	Over load warning
0x00000008	BUCK over current	0x0008	Fail to read EEPROM.
0x00000010	BMS communication fault	0x0010	Firmware version unmacth
0x00000020	Battery unnormal	0x0020	Fail to write EEPROM.
0x00000040	\	0x0040	BMS warning
0x00000080	Battery voltage high	0x0080	Li-Battery over load warning
0x00000100	Over temprature	0x0100	Li-Battery aging warning
0x00000200	Over load	0x0200	Fan lock warning
0x00000400	\	0x0400	\
0x00000800	\	0x0800	\
0x00001000	\	0x1000	\
0x00002000	\	0x2000	\
0x00004000	\	0x4000	\
0x00008000	\	0x8000	\
0x00010000	Battery reverse connection		
0x00020000	BUS soft start fail		
0x00040000	DC-DC unnormal		
0x00080000	DC voltage high		
0x00100000	CT detect failed		
0x00200000	CPU B to A Communication error		
0x00400000	BUS voltage high		
0x00800000	\		
0x01000000	MOV break		
0x02000000	Output short circuit		
0x04000000	Li-Battery over load		
0x08000000	Output voltage high		
0x10000000	\		
0x20000000	\		
0x40000000	\		
0x80000000	\		

5 Set address

Refer to the Inverter user manual. Always is :

GROWATT NEW ENERGY CO.,LTD
No. 12 Building, Xicheng Industrial
Zone, Bao'an District, Shenzhen
518102. China.

格瑞特新能源有限公司
中国深圳市宝安区西乡街道西成工
业区 12 栋 邮编 518102

Tel: 86 755 27471063
info@ginverter.com
www.ginverter.com

Knock the pv inverter to let the lcd display to the “COM Addr: xxx”, then double knock, if displays “Move”, you should another double knock, until it displays a address number, then you can give a single knock to change the address, this address will be remembered when the lcd backlight off.

6 Notice

- 1) It can drive mostly 32 pv inverters for one rs485 comport.
- 2) There are only read input and hold registers commands even the newest version.
- 3) App user could only care the input register.
- 4) App user could not care the holding registers.
- 5) Except the CEI0-21 and VDE-AR-N 4105 power management registers, you should refer the manufactory's suggestion when writing the other registers;