

Grid Interconnection Application Form

Distribution connection — generation

PROJECT ID: DX-GEN-004

PROJECT NAME: Greenholt Solar Park

APPLICANT: Greenholt Solar Ltd

LEVEL: distribution

CONNECTION TYPE: generation

CAPACITY: 24 MW solar PV (G99 Type C)

STATUS: Under review

DATE SUBMITTED: 2026-05-08

SECTION 1: Applicant

REQUIREMENT:

Customer name, address, agent / installer details. Source: G99 Design Phase.

SUBMITTED:

Greenholt Solar Ltd, Unit 4 Maltings Business Park, Shrewsbury, SY1 4QD. Installer: Severn EPC Ltd (NICEIC approved). Agent contact: J. Marsh, grid connections.

SUPPORTING DOCS:

none

SECTION 2: Project type

REQUIREMENT:

G99 classification — Type A (≤ 1 MW), B (1-10 MW), C (10-50 MW), D (≥ 50 MW or TX-connected). Source: G99 §2.2.

SUBMITTED:

24 MW registered capacity at 33 kV, classified as G99 Type C (10-50 MW). Connection to the WPD/National Grid Electricity Distribution 33 kV network at Greenholt primary.

SUPPORTING DOCS:

none

SECTION 3: Connection point

REQUIREMENT:

Proposed metering location plus maximum capacity (kVA) at each point. Source: G99 Design Phase.

SUBMITTED:

Single point of connection at Greenholt 33 kV primary substation. Maximum export capacity 24 MVA; import (auxiliaries) 0.5 MVA.

SUPPORTING DOCS:

single_line_diagram.pdf

SECTION 4: PGMD (Type B/C/D)

REQUIREMENT:

Power Generating Module Document — compliance statement plus full technical data sheet evidencing every G99 criterion. Source: G99 Construction Phase.

SUBMITTED:

A complete Power Generating Module Document is enclosed, confirming compliance with all relevant G99 criteria for the inverter fleet and the site as a whole.

SUPPORTING DOCS:

none

SECTION 5: Protection & islanding

REQUIREMENT:

Relay settings and the anti-islanding scheme — critical for safety of DNO field staff. Source: G99 §16-19.

SUBMITTED:

Interface protection at the 33 kV point of connection with under/over voltage and under/over frequency elements per G99 Table 10.1. Settings schedule attached.

SUPPORTING DOCS:

protection_settings.pdf

SECTION 6: Type-test evidence

REQUIREMENT:

Manufacturer certification that the unit passes the relevant G99 type test. Source: G99 Construction Phase; DCode DPC §7.

SUBMITTED:

Inverter type-test certificates to G99 Issue 1 are enclosed for the Sungrow SG3600UD-MV power units.

SUPPORTING DOCS:

type_test_certificate.pdf