

# Interface Protection Settings Schedule

Greenholt Solar Park — 33 kV point of connection

|                     |                             |
|---------------------|-----------------------------|
| Point of connection | Greenholt 33 kV             |
| Scheme              | G99 interface protection    |
| Standard            | EN50471 Issue 1, Table 10.1 |
| Issued by           | Severn EPC Ltd              |

## 1. Scope

This schedule lists the interface-protection settings applied at the 33 kV point of connection. The voltage and frequency elements are co-ordinated with the DNO network protection.

## 2. Loss-of-mains note

2.1 The loss-of-mains (RoCoF) element and its stability setting are to be confirmed at the commissioning stage and are NOT included in this schedule. No vector-shift or RoCoF setting is therefore specified in the table below.

### Settings table (as submitted)

| Function              | Stage   | Setting | Time delay           |
|-----------------------|---------|---------|----------------------|
| Undervoltage U<       | Stage 1 | -13%    | 2.5 s                |
| Undervoltage U<       | Stage 2 | -20%    | 0.5 s                |
| Overvoltage U>        | Stage 1 | +10%    | 1.0 s                |
| Overvoltage U>        | Stage 2 | +13%    | 0.5 s                |
| Underfrequency f<     | Stage 1 | 47.5 Hz | 20 s                 |
| Underfrequency f<     | Stage 2 | 47.0 Hz | 0.5 s                |
| Overfrequency f>      | Stage 1 | 51.5 Hz | 90 s                 |
| Overfrequency f>      | Stage 2 | 52.0 Hz | 0.5 s                |
| Loss of mains (RoCoF) | —       | not set | TBC at commissioning |