

Single-Line Diagram — Greenholt Solar Park

24 MW PV connection to Greenholt 33 kV primary

Connection point	Greenholt 33 kV primary busbar
Export capacity	24 MVA
Import (auxiliary)	0.5 MVA
Drawing ref	GH-SLD-04, Rev A

1. Array arrangement

The PV array comprises 6 x 4 MW blocks, each with a 4 MVA 0.69/33 kV transformer, combined onto a 33 kV switchboard.

2. Point of connection

A single point of connection is made to the DNO 33 kV busbar at Greenholt primary via a metered circuit breaker fitted with interface protection. Maximum export 24 MVA; site auxiliary import 0.5 MVA.

Block schedule

Block	DC rating	Inverter	Transformer
B1-B6 (each)	4.6 MWp	4 MW Sungrow	4 MVA 0.69/33 kV
Site total	27.6 MWp	24 MW AC	24 MVA export