

Type Test Certificate — Sungrow SG3600UD-MV

ENA Engineering Recommendation G99 compliance

Equipment	Sungrow SG3600UD-MV power unit
Standard	ENA G99 Issue 1
Certificate ref	SGR-G99-2024-0417
Laboratory	Accredited test laboratory (UKAS)

1. Certification statement

This certifies that the Sungrow SG3600UD-MV power unit has been tested in accordance with the type-test requirements of ENA Engineering Recommendation G99 Issue 1.

2. Verified capabilities

Verified capabilities: reactive power capability across the required range; voltage ride-through to the G99 profile; frequency response (LFSM-O and LFSM-U); and correct operation of protection functions.

Test results summary

Test	Requirement	Result
Reactive capability	0.95 lead/lag	Pass
Voltage ride-through	G99 profile	Pass
Frequency response	LFSM-O / LFSM-U	Pass
Protection operation	Table 10.1	Pass