

Site Control Philosophy — Meadowbank

Dispatch and curtailment logic

Site controller	Master PPC with ANM interface
Firm export limit	15 MW
ANM response time	2 s

1. Dispatch priority

Priority 1: export available PV up to the 15 MW firm limit. Priority 2: charge the BESS from surplus PV above the firm limit. Priority 3: discharge the BESS into the evening peak within the firm limit.

2. Curtailment

The controller responds to DNO ANM curtailment signals within two seconds, reducing combined export to the instructed set-point. Curtailment is shared between PV and BESS to preserve state of charge where possible.

3. Charge-source control (software)

3.1 The control philosophy states an intention to charge the BESS from surplus PV. This is a software set-point only; the physical single-line arrangement does not preclude grid charging, and the two documents should be read together when assessing the export-only declaration.