

Grid Interconnection Application Form

Distribution connection — storage

PROJECT ID: DX-STO-005

PROJECT NAME: Riverside Battery Storage

APPLICANT: Riverside Flex Ltd

LEVEL: distribution

CONNECTION TYPE: storage

CAPACITY: 8 MW / 16 MWh BESS (G99 Type B)

STATUS: Under review

DATE SUBMITTED: 2026-05-11

SECTION 1: Project type

REQUIREMENT:

G99 classification and pathway. Source: G99 §2.2.

SUBMITTED:

8 MW / 16 MWh battery energy storage system at 11 kV, classified as G99 Type B (1-10 MW).

SUPPORTING DOCS:

none

SECTION 2: Energy capacity

REQUIREMENT:

Energy storage capacity (MWh) and rated duration. Source: G99 (PGM with Electricity Storage).

SUBMITTED:

16 MWh usable energy capacity, rated duration 2 hours at 8 MW. LFP chemistry with augmentation planned at year 7.

SUPPORTING DOCS:

none

SECTION 3: Import + export capacity

REQUIREMENT:

Both import and export capacity declared. Source: DCUSA.

SUBMITTED:

Export capacity 8 MW; import (charge) capacity 8 MW. Charging from the grid permitted for arbitrage and balancing services.

SUPPORTING DOCS:

single_line_diagram.pdf

SECTION 4: Threshold check

REQUIREMENT:

Confirmation that export per phase exceeds 3.68 kW (the G99 trigger). Source: G99 / G98 split.

SUBMITTED:

Export far exceeds the 3.68 kW per phase G98/G99 threshold; G99 application pathway confirmed.

SUPPORTING DOCS:

none

SECTION 5: Grid-forming declaration

REQUIREMENT:

Whether the inverter is grid-following (default) or grid-forming. Source: G99 Issue 2.

SUBMITTED:

The inverters are grid-forming, providing virtual inertia and fault-level support to the local 11 kV network.

SUPPORTING DOCS:

type_test_certificate.pdf

SECTION 6: Anti-islanding (storage-specific)

REQUIREMENT:

Anti-islanding settings appropriate to a bidirectional asset. Source: G99 §16-19 (Issue 2 storage clauses).

SUBMITTED:

Loss-of-mains protection by RoCoF set at 1.0 Hz/s with a 0.5 s confirmation time, co-ordinated with the DNO 11 kV scheme. No on-site generation to co-ordinate with.

SUPPORTING DOCS:

protection_settings.pdf