

Single-Line Diagram — Riverside BESS

8 MW / 16 MWh connection to 11 kV

Connection point	DNO 11 kV ring main unit
Inverter skids	4 x 2 MW inverter-transformer
Charge path	Grid-charging path provided
Drawing ref	RV-SLD-02, Rev A

1. Connection arrangement

Four 2 MW inverter-transformer skids are combined onto an 11 kV switchboard, connected to the DNO 11 kV network via a metered ring main unit. The site auxiliary supply is taken from the LV board of skid 1.

2. Bidirectional flow

A grid-charging path is provided: the BESS can import from the 11 kV network as well as export. Both import and export are metered at the ring main unit.

Skid schedule

Skid	Inverter	Transformer	Mode
S1-S4 (each)	2 MW	2 MVA 0.4/11 kV	bidirectional
Site total	8 MW	8 MVA	import + export